



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAAP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

July 12, 2006

U-100-06

Subject: Sampling of Water Well JW-14

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (JW-14) on 3/21/06. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, CSSA Environmental Program Manager, at (210) 698-5208.

Sincerely,

  
Jason D. Shirley  
Installation Manager

Attachments

cc: Ms. Glare Sanchez, CSSA Environmental Program Manager  
Mr. Greg Lyssy, EPA Region 6  
Mr. Sonny Rayos, TCEQ Central Office  
Mr. Henry Karnei, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons  
Ms. Kimberly Vaughn, Parsons

## Data Anomalies

All sampling conducted by CSSA follows the quality assurance procedures of both AFCEE and CSSA. As part of those quality assurance plans, chemists review all data packages submitted by laboratories after analysis is complete. Whenever conditions of the quality assurance plans require a flag to be added to a result, chemists will refer to other pages within a data package for further information on a data flag. The reviewing chemists will refer to the other page within the data package with a note, such as "see page" on the bottom of the affected results page. CSSA is including an explanation of this data anomaly here for your convenience, instead of the extra pages of the results package.

Methylene chloride was detected at a concentration of 1.10F ppb. This result is below the MCL for methylene chloride (5 ppb). Methylene chloride has been reported periodically in samples from both on- and off-post wells since 1992. Each time methylene chloride was detected, it was also present in the analysis method blank, indicating the analyte was introduced as a laboratory contaminant and was not present in the groundwater. Methylene chloride is considered a common laboratory contaminant and there are no known historical uses of methylene chloride on-post. Toluene was also detected at a concentration of 0.14 ppb (F flagged) in your well. The "F" flag is assigned to those results that are above the method detection limit (MDL) but below the reporting limit (RL) for the laboratory method. This concentration of 0.14 ppb is below the applicable maximum contaminant level (MCL) for toluene of 1,000 ppb and does not affect usability of your well. Toluene has been detected sporadically in on-post monitoring wells and no concentrations on-post have been above the MCL. Toluene is a common groundwater contaminant associated with the widespread use of fuels and motor oils, usually associated with benzene, ethyl benzene, and/or xylene(s) contamination. The low levels of toluene detected in your well are not currently believed to be associated with CSSA activities.

A data qualifier, M, was placed on the analytes methylene chloride and naphthalene for your well. The laboratory is required to follow certain quality assurance procedures, including a set of matrix spike and matrix spike duplicate analyses for every twenty wells sampled. The matrix spike and/or matrix spike duplicate analysis had methylene chloride and naphthalene recovered below the acceptance criteria in one of the other samples from the same data package. Although the results are still considered usable, all methylene chloride and naphthalene results for samples in this data package were flagged with an "M" in accordance with the CSSA Quality Assurance Project Plan (QAPP) requirements.

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B    Preparatory Method: 5030B    AAB #: 060404AM-98424  
 Lab Name: APPL, Inc    Contract #: F41624-03-D-8613, TO 08  
 Field Sample ID: JW-14    Lab Sample ID: AX37819    Matrix: Water  
 % Solids: NA    Initial Calibration ID: M060330  
 Date Received: 22-Mar-06    Date Prepared: 04-Apr-06    Date Analyzed: 04-Apr-06  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Bromodichloromethane	0.06	0.8	0.06	1		U
Bromoform	0.13	1.2	0.13	1		U
Chloroform	0.06	0.3	0.06	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
Dibromochloromethane	0.06	0.5	0.06	1		U
Dichlorodifluoromethane	0.11	1.0	0.11	1		U
Methylene chloride	0.51	2.0	1.10	1		M <del>X</del>
Naphthalene	0.07	0.4	0.07	1		M <del>X</del>
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Toluene	0.06	1.1	0.14	1		F
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

*KAP 4/17/06*

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	106	69-139	
4-Bromofluorobenzene(S)	100	75-125	
Dibromofluoromethane(S)	90.9	75-125	
Toluene-D8(S)	102	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments: ARF: 50065

*See comment on p. 50. KAP 4/17/06*