



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, RRAD
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

February 29, 2008

U-094-08

25360 Old Fredericksburg Road
Boerne, TX 78015

Subject: Sampling of Water Well RFR-11, Located at 25360 Old
Fredericksburg Road

Dear _____

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (RFR-11) on 12/3/07. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCL) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided in the table below.

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well RFR-11, 25360 Old Fredericksburg Road			
12/3/07	Tetrachloroethene (PCE)	1.31F	5
	Trichloroethene (TCE)	1.17	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, levels of the VOCs PCE and TCE were identified in water samples from your well. These concentrations were below the applicable MCL and do not affect usability of your well. The concentrations reported for VOCs PCE and TCE were above the MCLs in the past. Therefore, a filtration system was installed on your well.

The filtration system was installed by Carbonair Environmental Systems of San Marcos, Texas. The system will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will be responsible for all costs associated with operation and maintenance of this system. CSSA will send a representative on a biweekly basis to exchange the five-micron pre-and post-filters in the system.


Carbonair performed maintenance on the system on December 5, 2007. Maintenance will be scheduled approximately every six months.

Carbonair will exchange the first carbon canister and perform other routine maintenance operations at each six-month visit. If you experience any problems with the system, please let the installer or CSSA know immediately. Carbonair is very responsive and can make additional maintenance visits if needed. Post-GAC samples were collected in September 2007 and are scheduled to be collected again in March 2008.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact me at 295-7416.

Sincerely,


Jason D. Shirley
Installation Manager

Attachments

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons
Ms. Samantha Elliott, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 071216AC-118903
 Lab Name: APPL, Inc Contract #: W91278-06-D-0026/DY02
 Field Sample ID: RFR-11 Lab Sample ID: AX71630 Matrix: Water
 % Solids: NA Initial Calibration ID: C071215
 Date Received: 05-Dec-07 Date Prepared: 16-Dec-07 Date Analyzed: 16-Dec-07
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	1.17	1		
Tetrachloroethene	0.06	1.4	1.31	1		F
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	105	69-139	
4-Bromofluorobenzene(S)	102	75-125	
Dibromofluoromethane(S)	102	75-125	
Toluene-D8(S)	102	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments:

ARF: 55042