DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

August 18, 2010

U-135-10

SUBJECT: Sampling of SAWS Water Well HS-3, Located at Falcon View at Rocky Hill Rd.

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from the above well (HS-3) on 6/4/10. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the water sample from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well will be sampled again in September 2010.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Gabriel Moreno-Fergusson, Environmental Program Manager, at (210) 698-5208.

Sincerely,

Jason D. Shirley
Installation Manager

Enclosures

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 100608AC-143962
Lab Name: APPL, Inc Contract #: W9126G07D00280050
Field Sample ID: HS-3 Lab Sample ID: AY16481 Matrix: Water
% Solids: NA Initial Calibration ID: C100608
Date Received: 08-Jun-10 Date Prepared: 09-Jun-10 Date Analyzed: 09-Jun-10
Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	103	69-139	
Surrogate: 4-Bromofluorobenzene (S)	92.4	75-125	
Surrogate: Dibromofluoromethane (S)	104	75-125	
Surrogate: Toluene-D8 (S)	87.3	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 61793