



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

August 5, 2011

U-121-11

[REDACTED]
Westex Capital LTD
307 East 10th St.
Del Rio, TX 78840

SUBJECT: Sampling of Water Well RFR-12, Located at 25284 IH-10 West

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from your well (RFR-12) on 6/15/11. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well RFR-12, located at 25284 IH-10 West			
6/15/11	Tetrachloroethene (PCE)	0.20F	5
	Trichloroethene (TCE)	0.63F	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, low levels of the VOCs PCE and TCE were identified in the water sample from your well RFR-12. These levels are below the applicable MCLs and do not affect usability of your well. Results from the laboratory analysis are provided as an attachment for the event included in the summary table above.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well is scheduled to be sampled again in March 2012.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you

informed. If you have any questions concerning this letter, please contact Gabriel Moreno-Fergusson, Environmental Program Manager, at (210) 698-5208.

Sincerely,



Jason D. Shirley
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Kirk Coulter, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 110617AS-156801
 Lab Name: APPL, Inc Contract #: 2010*1286022*000
 Field Sample ID: RFR-12 Lab Sample ID: AY39833 Matrix: Water
 % Solids: NA Initial Calibration ID: S110617
 Date Received: 16-Jun-11 Date Prepared: 18-Jun-11 Date Analyzed: 18-Jun-11
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.63	1		F
TETRACHLOROETHENE	0.06	1.4	0.20	1		F
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	101	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	101	75-125	
SURROGATE: DIBROMOFLUOROMETH	100	75-125	
SURROGATE: TOLUENE-D8 (S)	98.4	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 64899