



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAAP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

January 19, 2012

U-010-12

[REDACTED]  
[REDACTED]  
28703 IH-10 West  
Boerne, TX 78006

SUBJECT: Sampling of Water Well I10-4, Located at 25690 IH-10 West

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from the above listed well (I10-4) on 12/6/11. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:


| Date Sampled                            | VOC Compound                         | Result (ppb)       | MCL (ppb) |
|---|--------------------------------------|--------------------|-----------|
| Well I10-4, located at 25690 IH-10 West |                                      |                    |           |
| 12/6/11                                 | Tetrachloroethene (PCE)              | 6.87               | 5         |
|   | Trichloroethene (TCE)                | 2.85               | 5         |
|   | <i>cis</i> -1,2-Dichloroethene (DCE) | <0.07 (non-detect) | 70        |

Based on the analytical data, levels of the VOCs PCE and TCE were identified in the water sample from your well I10-4. The PCE level is above the applicable MCL and does affect usability of your well. We have received your correspondence notifying CSSA that there are no future plans to use this well. However, in the future should this well be put back into service, a filtration system will need to be installed. Please notify Camp Stanley prior to use of the well and a granular activated carbon (GAC) filtration system will be installed at the expense of Camp Stanley. CSSA will be responsible for all costs associated with operation and maintenance of this system. The GAC filtration system will clean the VOC contaminants from the water before delivery for consumption. Results from the laboratory analysis are provided as an attachment for the event included in the summary table above.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on-and off-post. As part of this effort, your well is scheduled to be sampled again in March 2012.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Gabriel Moreno-Fergusson, Environmental Program Manager, at (210) 698-5208.

Sincerely,



Jason D. Shirley  
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6  
Mr. Kirk Coulter, TCEQ Central Office  
Mr. Henry Karnei, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 111207AT-162218  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: I10-4      Lab Sample ID: AY51515      Matrix: Water  
 % Solids: NA      Initial Calibration ID: T111207  
 Date Received: 07-Dec-11      Date Prepared: 08-Dec-11      Date Analyzed: 08-Dec-11  
 Concentration Units: ug/L

| Analyte           | MDL  | RL  | Concentration | Dilution | Confirm | Qualifier |
|-------------------|------|-----|---------------|----------|---------|-----------|
| 1,1-DCE           | 0.12 | 1.2 | 0.12          | 1        |         | U         |
| CIS-1,2-DCE       | 0.07 | 1.2 | 0.07          | 1        |         | U         |
| TCE               | 0.05 | 1.0 | 2.85          | 1        |         |           |
| TETRACHLOROETHENE | 0.06 | 1.4 | 6.87          | 1        |         |           |
| TRANS-1,2-DCE     | 0.08 | 0.6 | 0.08          | 1        |         | U         |
| VINYL CHLORIDE    | 0.08 | 1.1 | 0.08          | 1        |         | U         |

| Surrogate                      | Recovery | Control Limits | Qualifier |
|--------------------------------|----------|----------------|-----------|
| SURROGATE: 1,2-DICHLOROETHANE- | 99.8     | 69-139         |           |
| SURROGATE: 4-BROMOFLUOROBENZ   | 89.1     | 75-125         |           |
| SURROGATE: DIBROMOFLUOROMETH   | 97.5     | 75-125         |           |
| SURROGATE: TOLUENE-D8 (S)      | 88.6     | 75-125         |           |

| Internal Std                | Qualifier |
|-----------------------------|-----------|
| 1,4-DICHLOROBENZENE-D4 (IS) |           |
| CHLOROBENZENE-D5 (IS)       |           |
| FLUOROBENZENE (IS)          |           |

Comments:

ARF: 66455