

DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, RRAD  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

25 July 2002

U-038-02

Executive Director  
Texas Natural Resources Conservation Commission  
P.O. Box 13087 MC-148  
Austin, Texas 78711-3087  
Attn.: Ms. Jan Sills  
Wastewater Compliance Section


Subject: Camp Stanley Storage Activity, TNRCC Permit 03849  
Self-Reporting of an Exceedance for Our Monthly Daily  
Flow Average Permit Limit

Dear Executive Director:

Per your requirements set forth in 30 TAC §§319.4-319.12, Camp Stanley Storage Activity, permit number 03849, is self-reporting that Outfall 001 exceeded our maximum allowable daily flow from July 16 and July 17, 2002. This outfall averaged 84,143 gallons per day (gpd) over the referenced time period, which exceeds our allowable daily maximum of 60,000 gpd. The elevated flow levels were a direct result of heavy rains that have fallen in our area. Our permit limitation is for 30,000 gpd average daily flow. CSSA will provide the Monthly Effluent Report under a separate mailing after the July reporting period is completed.

If you have any questions or comments, please feel free to contact me at (210) 295-7416.

Sincerely,



JASON D. SHIRLEY  
Lieutenant Colonel, U.S. Army  
Commanding Officer

cc: Mr. Greg Lyssy  
EPA Region 6

Mr. Tom Haberle  
TNRCC Region 13

Mr. Kent Grubb  
U.S. Army, Army Medical Command, Fort Sam Houston, Staff  
Judge Advocate

Ms. Karuna Mirchandani  
Parson