August 8, 2002

Via Federal Express
Herman Stinson
Camp Stanley Storage Activity
25800 Ralph Fair Road
Boerne, TX 78015-4800

Subject: July 2002 Outfall 002 Discharge Monitoring Report
TPDES Permit TX0064505
Camp Stanley Storage Activity, Texas
Contract F41624-00-D-8024, Delivery Order 0042
Parsons job # 740911

Dear Mr. Stinson:

Enclosed please find one original copy of the above-referenced Discharge Monitoring Report (DMR) for CSSA Outfall 002. A total of 3,867 gallons of groundwater was released through the outfall during three treatment operations during July 2002. No exceedences of the permit-mandated measurement parameters of pH, PCE, TCE, and total flow occurred during the monitoring period.

Please call me at (512) 719-6087 if you have questions or comments.

Sincerely,

Scott Pearson

Scott Pearson
Task Manager

Attachment

Brian Murphy, CSSA
Karuna Mirchandani, Parsons – Austin
740911 Project Files

ADDRESS CBR-CFFA
25800 RALPH FAIR ROAD
BOERNE TX 78015-4800

FACILITY CAMP STANLEY STORAGE ACTIVITY
LOCATION BOERNE TX 78015-4800

ATTN: LTC JASON D. SHIRLEY,COMMANDER

PERMIT NUMBER: TX0064505

DISCHARGE NUMBER: 002 A

MONITORING PERIOD

	YEAR	MO	DAY		YEAR	MO	DAY
FROM	02	07	01	TO	02	07	31

F - FINAL
GROUNDWATER - 002
EFFLUENT
*** NO DISCHARGE | | ***

NOTE: Read instructions before completing this form.

PARAMETER		QUANTITY OR LOADING AVERAGE	QUANTITY OR LOADING MAXIMUM	QUANTITY OR LOADING UNITS	QUALITY OR CONCENTRATION MINIMUM	QUALITY OR CONCENTRATION AVERAGE	QUALITY OR CONCENTRATION MAXIMUM	QUALITY OR CONCENTRATION UNITS	NO. EX	FREQUENCY OF ANALYSIS	SAMPLE TYPE
PH	SAMPLE MEASUREMENT	******	******		7.32	******	8.30	(12)	0	Daily	Grab
00400 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	6.0 MINIMUM	******	9.0 MAXIMUM	SU		DAILY	GRAB
TETRACHLOROETHYLENE	SAMPLE MEASUREMENT	******	******		******	0	0	(19)	0	2/7	Grab
34475 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	0.036 DAILY AV	0.077 DAILY MX	MG/L		TWICE/WEEK	GRAB
TRICHLOROETHYLENE	SAMPLE MEASUREMENT	******	******		******	0	0	(19)	0	2/7	Grab
39180 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	******	******	**** ****	******	0.036 DAILY AV	0.077 DAILY MX	MG/L		TWICE/WEEK	GRAB
FLOW, IN CONDUIT OR THRU TREATMENT PLANT	SAMPLE MEASUREMENT	0.001289	0.001929	(03)	******	******	******		0	Daily	Instan
50050 1 0 0 EFFLUENT GROSS VALUE	PERMIT REQUIREMENT	0.030 DAILY AV	0.060 DAILY MX	MGD	******	******	******	**** ****		DAILY	INSTAN
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										
	SAMPLE MEASUREMENT										
	PERMIT REQUIREMENT										

NAME/TITLE PRINCIPAL EXECUTIVE OFFICER

TYPED OR PRINTED

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

SIGNATURE OF PRINCIPAL EXECUTIVE OFFICER OR AUTHORIZED AGENT

TELEPHONE: AREA CODE | NUMBER

DATE: YEAR | MO | DAY

COMMENTS AND EXPLANATION OF ANY VIOLATIONS *(Reference all attachments here)*

WHEN DISCHARGE OCCURS. RECEIVED NOTIFICATION LETTER OUTFALL 002 ACTIVE EFFECTIVE.

TPDES 03849 (MB)

EPA Form 3320-1 (Rev. 3/99) Previous editions may be used.

This is a 4-part form.

00323/020114-1947

J:\740\740911\OUTFALL 002 DATA\2002\07-2002\JULY 2002 DMR LETTER.DOC