

PARSONS ENGINEERING, SCIENCE, INC.

3000 Centre Park Drive, Suite 200 • Austin, Texas 78751 • (512) 719-6000 • Fax: (512) 719-6099

July 14, 1995

Via facsimile (512) 239-1330

Karen M. Bullard
Office of Air Quality/NSR Program/Coatings Section
Texas Natural Resources Conservation Commission
P.O. Box 13087
Austin, Texas 78711-3087

Re: Standard Exemption Registration Requests for Camp Stanley Storage Activity

Dear Karen:


This letter supplies the additional information you requested on June 19, 1995 in order to process the above referenced standard exemption requests. Each item of concern is restated below, and is followed by our response.

1. Documentation from the filter manufacturer listing the filtration efficiency. This information is located on page 3 of the enclosed attachment labeled Airguard Paint Arrestor Pads. The two models used are FB 203 and FB 204, as indicated by asterisk on page 3.
2. A list of all other sources at your site. Please include an estimate of the type and amount of emissions as well as the authorization (permit, standard exemption, etc.) for each source. These data are included in the attached summary spreadsheet labeled Summary of Sources and Authorization Activities. Emissions estimates are not included for sources which are not specifically required to be estimated by their respective exemptions.
3. The capacity of the booth ventilation fans in cubic feet per minute. Also, please include the dimensions of the booths as well as the cross sectional area of the air inlet openings to the booths. Building 27 spray booth ventilation fan capacity is 1086 cfm; Building 200 spray booth ventilation fan capacity is approximately 1200 cfm. Dimensions for Building 27 booth are 15 ft wide, 30 ft deep, 8 ft tall; total inlet surface area is 80 sq ft. Dimensions for Building 200 booth are 7 ft wide, 7 ft deep, 8 ft tall. There are three inlets for Building 200 booth with dimensions as follows: 1) 7 ft x 8 ft; 2) 2 ft x 3 ft; 3) 2 ft x 3 ft.

I trust that this information will allow you to continue the processing of the standard exemption requests for Camp Stanley Storage Activity. Please call me at (512) 719-6000 if you have any questions.

2552545

Sincerely,



Glynis H. Fowler

cc: Brian Murphy
Susan Roberts

