



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

July 13, 2007

U-085-07

Mr.
25300 IH-10 West
San Antonio, TX 78257

Subject: Sampling of Water Wells I10-2 and RFR-12, Located at 25300
IH-10 West (IH-10 at Ralph Fair Road)

Dear Mr. _____


Camp Stanley Storage Activity (CSSA) collected groundwater samples from your wells (I10-2 and RFR-12) on 3/20/07. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your wells. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the wells listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, CSSA Environmental Program Manager, at (210) 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Attachments

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons
Ms. Kimberly Vaughn, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 070323AH-110806
 Lab Name: APPL, Inc Contract #: F41624-03-D-08613
 Field Sample ID: I10-2 Lab Sample ID: AX58800 Matrix: Water
 % Solids: NA Initial Calibration ID: H070321
 Date Received: 21-Mar-07 Date Prepared: 23-Mar-07 Date Analyzed: 23-Mar-07
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	104	69-139	
4-Bromofluorobenzene(S)	103	75-125	
Dibromofluoromethane(S)	99.3	75-125	
Toluene-D8(S)	98.1	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments:

ARF: 53035

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 070323AH-110806
 Lab Name: APPL, Inc Contract #: F41624-03-D-08613
 Field Sample ID: RFR-12 Lab Sample ID: AX58801 Matrix: Water
 % Solids: NA Initial Calibration ID: H070321

Date Received: 21-Mar-07 Date Prepared: 23-Mar-07 Date Analyzed: 23-Mar-07

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	106	69-139	
4-Bromofluorobenzene(S)	99.1	75-125	
Dibromofluoromethane(S)	104	75-125	
Toluene-D8(S)	99.2	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments:

ARF: 53035