**DEPARTMENT OF THE ARMY**
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

May 4, 2011

U-078-11

SUBJECT: Sampling of Water Well I10-8, Located at 25930 IH-10 West

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from the above well (I10-8) on 3/1/11. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the water sample from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well will be sampled again in June 2011.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Gabriel Moreno-Fergusson, Environmental Program Manager, at (210) 698-5208.

Sincerely,

Jason D. Shirley
Installation Manager

Enclosures

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Kirk Coulter, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 110307AM-152772
Lab Name: APPL, Inc Contract #: 2010*1286022*000
Field Sample ID: I10-8 Lab Sample ID: AY33459 Matrix: Water
% Solids: NA Initial Calibration ID: M110303
Date Received: 04-Mar-11 Date Prepared: 07-Mar-11 Date Analyzed: 07-Mar-11
Concentration Units: ug/L

| Analyte | MDL | RL | Concentration | Dilution | Confirm | Qualifier |
|---|---|---|---|---|---|---|
| 1,1-DCE | 0.12 | 1.2 | 0.12 | 1 | | U |
| CIS-1,2-DCE | 0.07 | 1.2 | 0.07 | 1 | | U |
| TCE | 0.05 | 1.0 | 0.05 | 1 | | U |
| TETRACHLOROETHENE | 0.06 | 1.4 | 0.06 | 1 | | U |
| TRANS-1,2-DCE | 0.08 | 0.6 | 0.08 | 1 | | U |
| VINYL CHLORIDE | 0.08 | 1.1 | 0.08 | 1 | | U |

| Surrogate | Recovery | Control Limits | Qualifier |
|---|---|---|---|
| SURROGATE: 1,2-DICHLOROETHANE- | 104 | 69-139 | |
| SURROGATE: 4-BROMOFLUOROBENZ | 89.2 | 75-125 | |
| SURROGATE: DIBROMOFLUOROMETH | 104 | 75-125 | |
| SURROGATE: TOLUENE-D8 (S) | 97.4 | 75-125 | |

| Internal Std | Qualifier |
|---|---|
| 1,4-DICHLOROBENZENE-D4 (IS) | |
| CHLOROBENZENE-D5 (IS) | |
| FLUOROBENZENE (IS) | |

Comments:

ARF: 64070