



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

August 5, 2011

U-128-11

[REDACTED]
7820 Covey Roost
Boerne, TX 78015

SUBJECT: Sampling of Water Well JW-30, Located at 7820 Covey Roost

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from your well (JW-30) on 6/3/11. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the water sample from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well is scheduled to be sampled again in March 2012.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Gabriel Moreno-Fergusson, Environmental Program Manager, at (210) 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Kirk Coulter, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 110610AS-156353
 Lab Name: APPL, Inc Contract #: 2010*1286022*000
 Field Sample ID: JW-30 Lab Sample ID: AY39205 Matrix: Water
 % Solids: NA Initial Calibration ID: S110608
 Date Received: 07-Jun-11 Date Prepared: 10-Jun-11 Date Analyzed: 10-Jun-11
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	99.7	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	96.0	75-125	
SURROGATE: DIBROMOFLUOROMETH	102	75-125	
SURROGATE: TOLUENE-D8 (S)	102	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 64827

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 110610AS-156353
 Lab Name: APPL, Inc Contract #: 2010*1286022*000
 Field Sample ID: JW-30 FD Lab Sample ID: AY39206 Matrix: Water
 % Solids: NA Initial Calibration ID: S110608
 Date Received: 07-Jun-11 Date Prepared: 10-Jun-11 Date Analyzed: 10-Jun-11
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	102	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	98.0	75-125	
SURROGATE: DIBROMOFLUOROMETH	102	75-125	
SURROGATE: TOLUENE-D8 (S)	101	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 64827