

Table 1.1
Sampling Rationale for December 2003

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Jun-03	Sep-03	Dec-03	Sampling Frequency:
DOM-2		NS		NS	NS	NS		NS	NS	NS	As needed, once annually
FO-8	NS	NS		NS	NS	NS		NS	NS	NS	As needed, once annually
FO-17	NS	NS		NS	NS	NS		NS	NS	NS	As needed, once annually
FO-22		NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
FO-J1										Yes	Qtrly, 1 year thru Dec 04
FO-J1, EP	NS	NS	NS		NS	NS	NS	NS	NS	NS	suggest removing from list
HS-2	NS									Yes	Qtrly, 1 year thru Dec 04
HS-3	NS		NS		NS	NS	NS		NS	NS	As needed, once annually
I10-2										Yes	Qtrly, 1 year thru Mar 04
I10-4	NS									NS	As needed, once annually
I10-5	NS	NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
I10-7	NS	NS		NS	NS	NS		NS	NS	NS	As needed, once annually
I10-7-NP	NS	NS	NS	NS	NS	NS		NS	NS	NS	As needed
JW-6		NS	NS		NS	NS	NS		NS	NS	As needed, once annually
JW-7		NS		Yes	Qtrly, 1 year thru Dec 04						
JW-8	NS	NS	NS	NS	NS	NS				Yes	Qtrly, 1 year thru Dec 04
JW-9										Yes	Qtrly
JW-9-A2*	NS	NS	NS	NS	NS		NS	NS	NS	NS	As needed
JW-12		NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
JW-13		NS	NS	NS	NS		NS		NS	NS	As needed, once annually
JW-14										Yes	Qtrly, 1 year thru Dec 04
JW-14-NP	NS	NS	NS	NS	NS	NS		NS	NS	NS	As needed
JW-26	NS	NS		NS						Yes	Qtrly, 1 year thru Dec 04
JW-27	NS		NS	NS	As needed, once annually						
JW-28	NS		Yes	Qtrly, 1 year thru Dec 04							
JW-29	NS			Yes	Qtrly, 1 year thru Jun 04						
JW-30	NS	NS	NS	NS	NS	NS				Yes	Qtrly, 1 year thru Dec 04
LS-1										Yes	Qtrly, 1 year thru Dec 04
LS-2										Yes	Qtrly, 1 year thru Dec 04
LS-2/LS-3-A1	NS	NS	NS	NS		NS		NS		NS	Bi-annually (Mar & Sept)
LS-3										Yes	Qtrly, 1 year thru Dec 04
LS-2/LS-3-A2	NS	NS		NS		NS		NS		NS	Bi-annually (Mar & Sept)

	VOCs detected are greater than 90% of the MCL. Monthly sampling, followed by quarterly sampling after GAC installation.		VOCs detected are greater than 80% of the MCL. The well will be placed on a monthly sampling schedule.	Yes	To be sampled in December 2003
	VOCs detected are less than 80% of the MCL (<4.0 ppb and >0.11 ppb for PCE & <4.0 ppb >0.14 ppb for TCE). Four quarters of concentrations below the MDL detections will be necessary to remove the well from quarterly sampling.		This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months. A1 - after GAC canister #1 A2 - after GAC canister #2 *JW-9-A2 is the well owner's filtration system, not a CSSA-installed GAC.	FT	First event for sampling by CSSA.
				NS	Not sampled for that event.
					No VOCs detected. Sample on an as needed basis.

**Table 1.1
Sampling Rationale for December 2003**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Jun-03	Sep-03	Dec-03	Sampling Frequency:
LS-4										Yes	Qtrly, 1 year thru Dec 04
LS-5										Yes	Qtrly, 1 year thru Dec 04
LS-6										Yes	Qtrly, 1 year thru Dec 04
LS-6-A2				NS		NS		NS		NS	Bi-annually (Mar & Sept)
LS-7										Yes	Qtrly, 1 year thru Dec 04
LS-7-A2				NS		NS		NS		NS	Bi-annually (Mar & Sept)
LS-7-NP	NS	NS	NS	NS	NS	NS		NS	NS	NS	As needed
OFR-1	NS									Yes	Qtrly, 1 year thru Dec 04
OFR-2	NS	NS								Yes	Qtrly, 1 year thru Dec 04
OFR-3										Yes	Qtrly, 1 year thru Dec 04
OFR-3-A2	NS	NS		NS		NS		NS		NS	Bi-annually (Mar & Sept)
OFR-4	NS			NS	As needed, once annually						
RFR-3	NS	NS	NS	NS	NS		NS	NS	NS	Yes	Qtrly, 1 year thru Dec 04
RFR-6		NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
RFR-7		NS	NS		NS	NS	NS	NS	NS	Yes	As needed, once annually
RFR-8		NS	NS		NS	NS	NS		NS	NS	As needed, once annually
RFR-9			NS		NS	NS	NS			NS	As needed, once annually
RFR-10										Yes	Qtrly, 1 year thru Dec 04
RFR-10-A2				NS		NS		NS		NS	Bi-annually (Mar & Sept)
RFR-10-B2				NS	NS	NS	NS	NS		NS	Bi-annually (Mar & Sept)
RFR-11										Yes	Qtrly, 1 year thru Dec 04
RFR-11-A2				NS		NS		NS		NS	Bi-annually (Mar & Sept)
RFR-12										Yes	Qtrly, 1 year thru Dec 04

Total samples to collect December 2003:	30
Total Pre GAC	30
Total Post GAC	0
First Time Samples	0
Total number of samples:	30

	VOCs detected are greater than 90% of the MCL. Monthly sampling, followed by quarterly sampling after GAC installation.		VOCs detected are greater than 80% of the MCL. The well will be placed on a monthly sampling schedule.	Yes	To be sampled in December 2003
				FT	First event for sampling by CSSA.
	VOCs detected are less than 80% of the MCL (<4.0 ppb and >0.11 ppb for PCE & <4.0 ppb >0.14 ppb for TCE). Four quarters of concentrations below the MDL detections will be necessary to remove the well from quarterly sampling.		This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months. A1 - after GAC canister #1 A2 - after GAC canister #2 *JW-9-A2 is the well owner's filtration system, not a CSSA-installed GAC.	NS	Not sampled for that event.
					No VOCs detected. Sample on an as needed basis.