



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

September 5, 2006

U-141-06

Subject: Sampling of Water Well JW-14


Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (JW-14) on 6/20/06. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Ms. Glare Sanchez, CSSA Environmental Program Manager, at (210) 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Attachments

cc: Ms. Glare Sanchez, CSSA Environmental Program Manager
Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons
Ms. Kimberly Vaughn, Parsons

Data Anomalies

A data qualifier, M, was placed on the analytes bromodichloromethane, *cis*-1,2-DCE, dichlorodifluoromethane, methylene chloride and naphthalene for your well. The laboratory is required to follow certain quality assurance procedures, including a set of matrix spike and matrix spike duplicate analyses for every twenty wells sampled. The matrix spike and/or matrix spike duplicate analysis had the above-mentioned analytes recovered below the acceptance criteria in one of the other samples from the same data package. Although the results are still considered usable, all above mentioned analyte results for samples in this data package were flagged with an "M" in accordance with the CSSA Quality Assurance Project Plan (QAPP) requirements.

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 060628AM-101767
 Lab Name: APPL, Inc Contract #: F41624-03-D-8613, TO 08
 Field Sample ID: JW-14 Lab Sample ID: AX43907 Matrix: Water
 % Solids: NA Initial Calibration ID: M060628
 Date Received: 21-Jun-06 Date Prepared: 29-Jun-06 Date Analyzed: 29-Jun-06
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Bromodichloromethane	0.06	0.8	0.06	1	M	X
Bromoform	0.13	1.2	0.13	1		U
Chloroform	0.06	0.3	0.06	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1	M	X
Dibromochloromethane	0.06	0.5	0.06	1		U
Dichlorodifluoromethane	0.11	1.0	0.11	1	M	X
Methylene chloride	0.51	2.0	0.51	1	M	X
Naphthalene	0.07	0.4	0.07	1	M	X
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Toluene	0.06	1.1	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

7c
7/14/06

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	95.3	69-139	
4-Bromofluorobenzene(S)	87.6	75-125	
Dibromofluoromethane(S)	97.5	75-125	
Toluene-D8(S)	101	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments: ARF: 50950