



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, RRAD  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

May14, 2009

U-102-09

SUBJECT: Sampling of Water Well LS-5, Located at 7579 Curres Rd.

1

Camp Stanley Storage Activity (CSSA) collected groundwater samples from the above listed well (LS-5) on 3/3/09. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-5, located at 7579 Curres Rd.			
3/3/09	Tetrachloroethene (PCE)	<0.06 (non-detect)	5
	Trichloroethene (TCE)	2.04	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

\*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.


Based on the analytical data, low levels of the VOC TCE was identified in the water sample from your well. This level is below the applicable MCL and do not affect usability of your well. Results from the laboratory analysis are provided as an attachment for the event included in the summary table above.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any

questions concerning this letter, please contact Glare Sanchez, Environmental Program Manager, at (210) 698-5208.

Sincerely,



Jason D. Shirley  
Installation Manager

Attachment

cc: Mr. Greg Lyssy, EPA Region 6  
Mr. Sonny Rayos, TCEQ Central Office  
Mr. Henry Karnei, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 090311AS-130713  
 Lab Name: APPL, Inc      Contract #: W9126G07D00280011  
 Field Sample ID: LS-5      Lab Sample ID: AX91942      Matrix: Water  
 % Solids: NA      Initial Calibration ID: S090305  
 Date Received: 04-Mar-09      Date Prepared: 11-Mar-09      Date Analyzed: 11-Mar-09  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	2.04	1		
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	117	69-139	
Surrogate: 4-Bromofluorobenzene (S)	102	75-125	
Surrogate: Dibromofluoromethane (S)	100	75-125	
Surrogate: Toluene-D8 (S)	97.4	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 58282