



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

April 26, 2010

U-063-10

SUBJECT: Sampling of Water Well LS-7, Located at 7529 Curres Creek Road

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from your well (LS-7) on 3/1/10. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-7, Located at 7529 Curres Creek Road			
3/1/10	Tetrachloroethene (PCE)	0.99F	5
	Trichloroethene (TCE)	0.50F	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, low levels of the VOCs PCE and TCE were identified in the water sample from your well before granular activated carbon (GAC) filtration. These levels are below the applicable MCLs and do not affect usability of your well. The concentrations reported for these VOCs were above the MCL in the past. Therefore, a filtration system was installed on your well.

Carbonair Environmental Systems of San Marcos, Texas installed the filtration system on your well. The system will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will be responsible for all costs associated with operation and maintenance of this system. CSSA will send a representative every three weeks to exchange the five-micron pre-and post-filters in the system.

Carbonair exchanged the first carbon canister and performed other routine maintenance on your system in January 2010. If you experience any problems with the system, please let the installer or CSSA know immediately. Carbonair is very responsive and can make additional maintenance visits if needed.

On 3/1/10, CSSA collected a sample from your well (LS-7) after the water was processed through the granular activated carbon (GAC) filter system. This sample is representative of the water being delivered to your house for daily use. Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the sample after the second carbon canister (A2). A summary of the post-GAC analytical results is provided below. Copies of the laboratory data sheets are attached. CSSA will collect additional confirmation samples on a 6- month basis to confirm the system remains effective.

Date Sampled	VOC compound	Result (ppb)	MCL (ppb)
Well LS-7-A2, located at 7529 Curren Creek Road			
3/1/10	PCE	<0.06 (non-detect)	5
	TCE	<0.05 (non-detect)	5
	cis-1,2-DCE	<0.07 (non-detect)	70
Well LS-7-A2, field duplicate			
3/1/10	PCE	<0.06 (non-detect)	5
	TCE	<0.05 (non-detect)	5
	cis-1,2-DCE	<0.07 (non-detect)	70

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, a groundwater sample will be collected from your well in June 2010.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, Environmental Program Manager, at (210) 698-5208.

Sincerely,



Jason D. Shirley
Installation Manager

Enclosure

- cc: Mr. Greg Lyssy, EPA Region 6
 Mr. Sonny Rayos, TCEQ Central Office
 Mr. Henry Karnei, TCEQ Region 13
 Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
 Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 100303AS-141263
 Lab Name: APPL, Inc Contract #: W9126G07D00280011
 Field Sample ID: LS-7 Lab Sample ID: AY12129 Matrix: Water
 % Solids: NA Initial Calibration ID: S100227
 Date Received: 03-Mar-10 Date Prepared: 03-Mar-10 Date Analyzed: 03-Mar-10
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.50	1		F
Tetrachloroethene	0.06	1.4	0.99	1		F
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	101	69-139	
Surrogate: 4-Bromofluorobenzene (S)	99.1	75-125	
Surrogate: Dibromofluoromethane (S)	105	75-125	
Surrogate: Toluene-D8 (S)	105	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 61048

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 100303AS-141263
 Lab Name: APPL, Inc Contract #: W9126G07D00280011
 Field Sample ID: LS-7-A2 FD Lab Sample ID: AY12130 Matrix: Water
 % Solids: NA Initial Calibration ID: S100227
 Date Received: 03-Mar-10 Date Prepared: 03-Mar-10 Date Analyzed: 03-Mar-10
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	102	69-139	
Surrogate: 4-Bromofluorobenzene (S)	99.6	75-125	
Surrogate: Dibromofluoromethane (S)	105	75-125	
Surrogate: Toluene-D8 (S)	106	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 61048

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 100303AS-141263

Lab Name: APPL, Inc Contract #: W9126G07D00280011

Field Sample ID: LS-7-A2 Lab Sample ID: AY12131 Matrix: Water

% Solids: NA Initial Calibration ID: S100227

Date Received: 03-Mar-10 Date Prepared: 03-Mar-10 Date Analyzed: 03-Mar-10

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	103	69-139	
Surrogate: 4-Bromofluorobenzene (S)	103	75-125	
Surrogate: Dibromofluoromethane (S)	106	75-125	
Surrogate: Toluene-D8 (S)	109	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 61048