



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, RRAD
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

February 23, 2004

U-042-04

RE: Sampling of Water Well I10-2 and RFR-12,

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (I10-2 and RFR-12) on 12/02/03. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC compound	Result (ppb)	MCL (ppb)
Well I10-2,			
12/02/03	Tetrachloroethene (PCE)	<0.06 (non-detect)	5
	Trichloroethene (TCE)	<0.05 (non-detect)	5
	<i>cis</i> -1,2-dichloroethene (DCE)	<0.07 (non-detect)	70
Well RFR-12,			
12/02/03	PCE	0.23F	5
	TCE	0.18F	5
	<i>cis</i> -1,2-DCE	<0.07 (non-detect)	70

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.


Based on the analytical data, low levels of the VOCs PCE and TCE were identified in water samples from your well RFR-12. No VOCs were identified in water samples from well I10-2. Results from the laboratory analysis are provided as an attachment for the 12/02/03 event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for your well listed above.



Again, we would like to thank you for your cooperation. If you have any questions concerning this letter, please contact me at 295-7416.

Sincerely,


Jason D. Shirley
Installation Manager

Attachments

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons



AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 031204AS-71044
 Lab Name: APPL, Inc Contract #: F41624-03-D-8613, TO 08
 Field Sample ID: I10-2 Lab Sample ID: AP62071 Matrix: Water
 % Solids: NA Initial Calibration ID: S031204
 Date Received: 03-Dec-03 Date Prepared: 05-Dec-03 Date Analyzed: 05-Dec-03
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Bromodichloromethane	0.06	0.8	0.06	1		U
Bromoform	0.13	1.2	0.13	1		U
Chloroform	0.06	0.3	0.06	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
Dibromochloromethane	0.06	0.5	0.06	1		U
Dichlorodifluoromethane	0.11	1.0	0.11	1		U
Methylene chloride	0.51	1.0	0.51	1		U
Naphthalene	0.07	0.4	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Toluene	0.06	1.1	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	105	69-139	
4-Bromofluorobenzene(S)	101	75-125	
Dibromofluoromethane(S)	97.4	75-125	
Toluene-D8(S)	106	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D1S	
Chlorobenzene-D5(S)	
Fluorobenzene(S)	

Comments: ARF: 43264

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 031209AN-71048
 Lab Name: APPL, Inc Contract #: F41624-03-D-8613, TO 08
 Field Sample ID: RFR-12 Lab Sample ID: AP62081 Matrix: Water
 % Solids: NA Initial Calibration ID: N031208
 Date Received: 03-Dec-03 Date Prepared: 09-Dec-03 Date Analyzed: 09-Dec-03
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Bromodichloromethane	0.06	0.8	0.06	1		U
Bromoform	0.13	1.2	0.13	1		U
Chloroform	0.06	0.3	0.06	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
Dibromochloromethane	0.06	0.5	0.06	1		U
Dichlorodifluoromethane	0.11	1.0	0.11	1		U
Methylene chloride	0.51	1.0	0.51	1		U
Naphthalene	0.07	0.4	0.07	1		U
TCE	0.05	1.0	0.18	1		F
Tetrachloroethene	0.06	1.4	0.23	1		F
Toluene	0.06	1.1	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	103	69-139	
4-Bromofluorobenzene(S)	109	75-125	
Dibromofluoromethane(S)	97.7	75-125	
Toluene-D8(S)	102	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments: ARF: 43264