



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

December 29, 2006

U-035-07

[REDACTED]
26753 Ralph Fair Road
Boerne, TX 78015

Subject: Sampling of Water Well JW-12, Located at 26753 Ralph Fair Road

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (JW-12) on 9/20/06. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Ms. Glare Sanchez, CSSA Environmental Program Manager, at 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Attachment

cc: Ms. Glare Sanchez, CSSA Environmental Program Manager
Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons
Ms. Kimberly Vaughn, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 061003AN-105448
Lab Name: APPL, Inc Contract #: F41624-03-D-08613
Field Sample ID: JW-12 Lab Sample ID: AX49279 Matrix: Water
% Solids: NA Initial Calibration ID: N060930
Date Received: 21-Sep-06 Date Prepared: 03-Oct-06 Date Analyzed: 03-Oct-06
Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	102	69-139	
4-Bromofluorobenzene(S)	98.8	75-125	
Dibromofluoromethane(S)	106	75-125	
Toluene-D8(S)	104	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D(IS)	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments: ARF: 51698