



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAAP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

January 10, 2008

U-070-08

60 High Crescent  
San Antonio, TX 78257

Subject: Sampling of Water Well I10-7, Located at 25840 IH 10 West )

Dear . . . :


Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (I10-7) on 9/18/07. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, CSSA Environmental Program Manager, at (210) 698-5208.

Sincerely,

  
Jason D. Shirley  
Installation Manager

Attachment

cc: Ms. Glare Sanchez, CSSA Environmental Program Manager  
Mr. Greg Lyssy, EPA Region 6  
Mr. Sonny Rayos, TCEQ Central Office  
Mr. Henry Karnei, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons  
Ms. Kimberly Vaughn, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 070927BC-116431  
 Lab Name: APPL, Inc      Contract #: W91278-06-D-0026/DY02  
 Field Sample ID: I10-7      Lab Sample ID: AX67542      Matrix: Water  
 % Solids: NA      Initial Calibration ID: C070925  
 Date Received: 19-Sep-07      Date Prepared: 28-Sep-07      Date Analyzed: 28-Sep-07  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
1,2-DCA-D4(S)	98.6	69-139	
4-Bromofluorobenzene(S)	100.0	75-125	
Dibromofluoromethane(S)	101	75-125	
Toluene-D8(S)	101	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D1S	
Chlorobenzene-D5(IS)	
Fluorobenzene(IS)	

Comments:

ARF: 54385