



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, RRAD
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

April 2, 2009

U-074-09

RE: Sampling of two SAWS Water Wells: HS-1, and HS-2,
Located at Falcon View at Rocky Hill Road

Camp Stanley Storage Activity (CSSA) collected groundwater samples from the above wells (HS-1 and HS-2) on 12/4/08. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the wells listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, Environmental Program Manager, at (210) 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Attachments

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 081210AH-128817
 Lab Name: APPL, Inc Contract #: W91278-06-D-0026/DY02
 Field Sample ID: HS-1 Lab Sample ID: AX88400 Matrix: Water
 % Solids: NA Initial Calibration ID: H081209
 Date Received: 05-Dec-08 Date Prepared: 11-Dec-08 Date Analyzed: 11-Dec-08
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	117	69-139	
Surrogate: 4-Bromofluorobenzene (S)	105	75-125	
Surrogate: Dibromofluoromethane (S)	109	75-125	
Surrogate: Toluene-D8 (S)	101	75-125	
Internal Std	Qualifier		
1,4-Dichlorobenzene-D4 (IS)			
Chlorobenzene-D5 (IS)			
Fluorobenzene (IS)			

Comments:

ARF: 57677

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 081210AH-128817

Lab Name: APPL, Inc Contract #: W91278-06-D-0026/DY02

Field Sample ID: HS-2 Lab Sample ID: AX88401 Matrix: Water

% Solids: NA Initial Calibration ID: H081209

Date Received: 05-Dec-08 Date Prepared: 11-Dec-08 Date Analyzed: 11-Dec-08

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	117	69-139	
Surrogate: 4-Bromofluorobenzene (S)	102	75-125	
Surrogate: Dibromofluoromethane (S)	109	75-125	
Surrogate: Toluene-D8 (S)	100	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments:

ARF: 57677

