



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, RRAD
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

April 2, 2009

U-071-09

RE: Sampling of Water Well JW-30,
Located at 7820 Covey Roost


Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (JW-30) on 12/4/08. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in water samples from your well. Results from the laboratory analysis are provided as an attachment for the above sampling event. Within the attached laboratory analysis sheet you will notice the 'M' flags have been changed to 'U' flags. The "M" flag indicates a possible high bias to the reported value based on the analysis of a spiked sample. However, because the analyte was not detected in the sample, data quality was not affected and the "M" flag was removed. This is part of our data validation process to ensure the data we are reporting is accurate.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, we may contact you in the future to schedule another sampling event for the well listed above.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Glare Sanchez, Environmental Program Manager, at (210) 698-5208.

Sincerely,


Jason D. Shirley
Installation Manager

Attachment

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Sonny Rayos, TCEQ Central Office
Mr. Henry Karnei, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 081207AN-128818
 Lab Name: APPL, Inc Contract #: W91278-06-D-0026/DY02
 Field Sample ID: JW-30 Lab Sample ID: AX88403 Matrix: Water
 % Solids: NA Initial Calibration ID: N081207
 Date Received: 05-Dec-08 Date Prepared: 07-Dec-08 Date Analyzed: 07-Dec-08
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1-DCE	0.12	1.2	0.12	1		M U
Cis-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
Tetrachloroethene	0.06	1.4	0.06	1		U
Trans-1,2-DCE	0.08	0.6	0.08	1		M U
Vinyl chloride	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
Surrogate: 1,2-Dichloroethane-d4 (S)	90.2	69-139	
Surrogate: 4-Bromofluorobenzene (S)	86.8	75-125	
Surrogate: Dibromofluoromethane (S)	91.6	75-125	
Surrogate: Toluene-D8 (S)	90.9	75-125	

Internal Std	Qualifier
1,4-Dichlorobenzene-D4 (IS)	
Chlorobenzene-D5 (IS)	
Fluorobenzene (IS)	

Comments: M = Matrix effect.

ARF: 57677 = M for 1,1-DCE was removed by Parsons data validator due to minor exceedance of MS/R. = M for Trans-1,2-DCE also was removed by Parsons data validator due to high R_s < MDL result of the parent sample. MS/MSD has not impact to the AFCEE FORM O-2 TC 1/20/09