

### DEPARTMENT OF THE ARMY CAMP STANLEY STORAGE ACTIVITY, MCAAP 25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

February 29, 2016

U-050-16

SUBJECT: Sampling of Water Wells: SLD-01 and SLD-02, Located at 25665 Boerne Stage Road



San Antonio, TX 78255

Dear

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your wells (SLD-01 & SLD-02) on 12/2/15. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the water samples from your wells. Results from the laboratory analysis are provided as an attachment for the above sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post.

Again, we would like to thank you for your cooperation. We remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Felicia Kraintz, Environmental Program Manager, at (210) 295-7067.

Sincerely,

Jason D. Shirley

Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6

Ms. Amanda Pirani, TCEQ Central Office

Mr. Jorge Salazar, TCEQ Region 13

Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.

Ms. Julie Burdey, Parsons

# AFCEE ORGANIC ANALYSES DATA SHEET 2 RESULTS

Analytical Method: EPA 8260B

Preparatory Method: 5030B

AAB #: 151208BT-203135

Lab Name: APPL, Inc

Contract #: \*G012

Field Sample ID: SLD-01

Lab Sample ID: AZ25765

Matrix: Water

% Solids: NA

Initial Calibration ID: T151204

Date Received: 03-Dec-15

Date Prepared: 09-Dec-15

Date Analyzed: 09-Dec-15

Concentration Units: ug/L

| Analyte           | MDL  | RL  | Concentration | Dilution | Confirm | Qualifier |
|-------------------|------|-----|---------------|----------|---------|-----------|
| I,1-DCE           | 0.12 | 1.2 | 0.12          | 1        |         | U         |
| CIS-1,2-DCE       | 0.07 | 1.2 | 0.07          | 1        |         | υ         |
| TCE               | 0.05 | 1.0 | 0.05          | 1        |         | u         |
| TETRACHLOROETHENE | 0.06 | 1.4 | 0.06          | 1        |         | U         |
| TRANS-1,2-DCE     | 0.08 | 0.6 | 0.08          | 1        |         | U         |
| VINYL CHLORIDE    | 0.08 | 1.1 | 0.08          | 1        |         | U         |

| Surrogate                      | Recovery | Control Limits | Qualifier |
|--------------------------------|----------|----------------|-----------|
| SURROGATE: 1,2-DICHLOROETHANE- | 98.0     | 69-139         |           |
| SURROGATE: 4-BROMOFLUOROBENZ   | 99.4     | 75-125         |           |
| SURROGATE: DIBROMOFLUOROMETH   | 97.6     | 75-125         |           |
| SURROGATE: TOLUENE-D8 (S)      | 101      | 75-125         |           |

| Internal Std                | Qualifier |
|-----------------------------|-----------|
| 1,4-DICHLOROBENZENE-D4 (IS) |           |
| CHLOROBENZENE-D5 (IS)       |           |
| FLUOROBENZENE (IS)          |           |

| Comments:  |   |  |
|------------|---|--|
| ARF: 78072 | *************************************** |  |
|            |   |  |

# AFCEE ORGANIC ANALYSES DATA SHEET 2 RESULTS

Analytical Method: EPA 8260B

Preparatory Method: 5030B

AAB #: 151208BT-203135

Lab Name: APPL, Inc

Contract #: \*G012

Field Sample ID: SLD-02

Lab Sample ID: AZ25766

Matrix: Water

% Solids: NA

Initial Calibration ID: T151204

Date Received: 03-Dec-15

Date Prepared: 09-Dec-15

Date Analyzed: 09-Dec-15

Concentration Units: ug/L

| Analyte           | MDL  | RL  | Concentration | Dilution | Confirm   | Qualifier |
|-------------------|------|-----|---------------|----------|-----------|-----------|
| 1,1-DCE           | 0.12 | 1.2 | 0.12          | 1        |           | U         |
| CIS-1,2-DCE       | 0.07 | 1.2 | 0,07          | 1        |           | U         |
| TCE               | 0.05 | 1.0 | 0.05          | 1        |           | U         |
| TETRACHLOROETHENE | 0.06 | 1.4 | 0.06          | 1        | -         | Ŭ         |
| TRANS-1,2-DCE     | 0.08 | 0.6 | 0.08          | 1        |           | U         |
| VINYL CHLORIDE    | 0.08 | 1.1 | 0.08          | 1        | , , , , , | U         |

| Surrogate                      | Recovery | Control Limits | Qualifier |
|--------------------------------|----------|----------------|-----------|
| SURROGATE: 1,2-DICHLOROETHANE- | 99.2     | 69-139         |           |
| SURROGATE: 4-BROMOFLUOROBENZ   | 95.4     | 75-125         |           |
| SURROGATE: DIBROMOFLUOROMETH   | 97.6     | 75-125         |           |
| SURROGATE: TOLUENE-D8 (S)      | 97.1     | 75-125         |           |

| Internal Std                | Qualifier |
|-----------------------------|-----------|
| I,4-DICHLOROBENZENE-D4 (IS) |           |
| CHLOROBENZENE-D5 (IS)       |           |
| FLUOROBENZENE (IS)          |           |

| Comments:  |  |
|------------|--|
| ARF: 78072 |  |
|            |  |

#### Qualifiers for laboratory data report:

U - The analyte was analyzed for, but not detected. The associated numerical value is at or below the MDL.

F - Indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

#### Abbreviations:

MDL – method detection limit RL – reporting limit DCE – Dichloroethene TCE – Trichloroethene