



DEPARTMENT OF THE ARMY
 CAMP STANLEY STORAGE ACTIVITY, MCAAP
 25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

August 10, 2017

U-054-17

SUBJECT: Sampling of Water Wells LS-5, Located at 7579 Curres Creek Road and LS-6, Located at 7655 Curres Creek Road

[Redacted Name]

[Redacted Address Line 1]

Boerne, TX 78015

Dear [Redacted Name]

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your wells (LS-5 and LS-6) on 6/5/17. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis.

This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort. An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-5, serves home located at 7579 Curres Creek Road			
6/5/17	Tetrachloroethene (PCE)	1.07F	5
	Trichloroethene (TCE)	2.40	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70
Well LS-6, serves church located at 7655 Curres Creek Road			
6/5/17	Tetrachloroethene (PCE)	0.80F	5
	Trichloroethene (TCE)	0.52F	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, levels of the VOCs TCE and PCE were identified in the water samples from your wells LS-5 and LS-6 before granular activated carbon (GAC) filtration. Results from the laboratory analyses are provided as an attachment for the above sampling event. These levels are below the applicable MCLs and do not affect usability of your wells. The concentrations reported in your wells LS-5 and LS-6 were above or approaching the MCL for VOCs in the past. Therefore, a filtration system was installed on each well.

ProAct Services Corporation (formerly Carbonair Environmental Systems) of San Marcos, Texas installed the GAC filtration systems on your wells. The systems will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will continue to be responsible for all costs associated with operation and maintenance of these systems. CSSA will continue to send a representative every three weeks to exchange the five-micron pre-and post-filters in the system.

ProAct exchanged the first carbon canister and performed other routine maintenance on your systems March 28, 2017. If you experience any problems with the systems, please let the installer or CSSA know immediately. ProAct is very responsive and can make additional maintenance visits if needed. Post-GAC samples were not collected this event but are scheduled to be collected again during the September 2017 sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your wells are scheduled to be sampled again in September 2017.

Again, we would like to thank you for your cooperation. We regret that your wells have been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Felicia Kraintz, Environmental Program Manager, at (210) 295-7067.

Sincerely,



Jason D. Shirley
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Paul Gregorio, TCEQ Central Office
Mr. Jorge Salazar, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170608AT-219496
 Lab Name: APPL, Inc Contract #: *G012
 Field Sample ID: LS-5 Lab Sample ID: AZ56107 Matrix: Water
 % Solids: NA Initial Calibration ID: T170525
 Date Received: 06-Jun-17 Date Prepared: 08-Jun-17 Date Analyzed: 08-Jun-17
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	2.40	1		
TETRACHLOROETHENE	0.06	1.4	1.07	1		F
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	106	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	97.6	75-125	
SURROGATE: DIBROMOFLUOROMETH	107	75-125	
SURROGATE: TOLUENE-D8 (S)	101	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 83024

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170608AT-219496
 Lab Name: APPL, Inc Contract #: *G012
 Field Sample ID: LS-6 Lab Sample ID: AZ56106 Matrix: Water
 % Solids: NA Initial Calibration ID: T170525
 Date Received: 06-Jun-17 Date Prepared: 08-Jun-17 Date Analyzed: 08-Jun-17
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.52	1		F
TETRACHLOROETHENE	0.06	1.4	0.80	1		F
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	103	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	100	75-125	
SURROGATE: DIBROMOFLUOROMETH	108	75-125	
SURROGATE: TOLUENE-D8 (S)	105	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 83024

Qualifiers for laboratory data report:

U - The analyte was analyzed for, but not detected. The associated numerical value is at or below the MDL.

F - Indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Abbreviations:

MDL – method detection limit

RL – reporting limit

DCE – Dichloroethene

TCE – Trichloroethene

PCE – Tetrachloroethene

FD – field duplicate