



DEPARTMENT OF THE ARMY
CAMP STANLEY STORAGE ACTIVITY, MCAAP
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

January 20, 2017

U-025-17

SUBJECT: Sampling of Water Well LS-7 and Located at 7529 Curres Creek, and the Showerhead from [REDACTED] at the same address

[REDACTED]
[REDACTED]
Boerne, TX 78015-6501

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected a regularly scheduled groundwater sample from your well (LS-7) on 12/5/16, and additional samples including the well, treatment unit, and [REDACTED] showerhead on 12/30/16. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of the analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-7, located at 7529 Curres Creek Road			
12/5/16	Tetrachloroethene (PCE)	<0.06 (non-detect)	5
	Trichloroethene (TCE)	<0.05 (non-detect)	5
	cis-1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the water sample from your well on 12/5/16. Results from the laboratory analysis are provided as an attachment for the above sampling event.

At the request of [REDACTED] additional samples from the well and the showerhead in her home were collected on 12/30/16 in response to her concerns that she noticed an odor coming from the shower. These samples were analyzed for a comprehensive list of VOCs, which included 60 target analytes. An abbreviated summary of the analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-7, located at 7529 Curres Creek Road			
12/30/16	Tetrachloroethene (PCE)	0.97F	5
	Trichloroethene (TCE)	0.24F	5
	58 compounds listed on attached datasheet	non-detect	

*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, very low levels of the VOCs PCE and TCE were identified in the water sample from your well before granular activated carbon (GAC) filtration. These levels are below the applicable MCL and do not affect usability of your well. None of the other 58 VOC analytes tested for were present in your groundwater well. Results from the laboratory analysis are provided as an attachment for the above sampling event.

Carbonair Environmental Systems of San Marcos, Texas installed the filtration system on your well. The system will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will continue to be responsible for all costs associated with operation and maintenance of this system. CSSA will continue to send a representative every three weeks to exchange the five-micron pre-and post-filters in the system.

Carbonair exchanged the first carbon canister and performed other routine maintenance on your system September 6, 2016. If you experience any problems with the system, please let the installer or CSSA know immediately. Carbonair is very responsive and can make additional maintenance visits if needed.

On 12/30/16, CSSA also collected a sample from your well LS-7 after the water was processed through the granular activated carbon (GAC) filter system, and we also collected a sample of water from [REDACTED] showerhead. The post-GAC sample is representative of the water being delivered to both homes for daily use. Based on the analytical data, no VOCs were identified in either the treated well water sample, or her showerhead sample. This shows that the wellhead GAC treatment continues to be effective. Copies of post-GAC and showerhead analytical results of the laboratory data sheets are attached. CSSA will continue to collect post-GAC confirmation samples on a 6-month basis to confirm the system remains effective.

The sample results indicate that VOC contamination at Camp Stanley is not causing the showerhead odor reported by [REDACTED]. The lack of these contaminants after the GAC treatment unit and in the showerhead sample support this conclusion. Aging hot water heaters can cause odors in household water systems as scale and mineral deposits accumulate, coupled with the degradation of the water heater anode.

We have suggested to [REDACTED] to consider inspecting her hot water heater to see if these conditions might be causing the odor she reported.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well is scheduled to be sampled again March 2017.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted, but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Felicia Kraintz, Environmental Program Manager, at (210) 295-7067.

Sincerely,



Jason D. Shirley
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6
Mr. Paul Gregorio, TCEQ Central Office
Mr. Jorge Salazar, TCEQ Region 13
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.
Ms. Julie Burdey, Parsons

Qualifiers for laboratory data report:

U - The analyte was analyzed for, but not detected. The associated numerical value is at or below the MDL.

F - Indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Abbreviations:

MDL – method detection limit

RL – reporting limit

DCE – Dichloroethene

TCE – Trichloroethene

PCE – Tetrachloroethene

**AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS**

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 161210AL-214543
Lab Name: APPL, Inc Contract #: *G012
Field Sample ID: LS-7 Lab Sample ID: AZ46812 Matrix: Water
% Solids: NA Initial Calibration ID: 161210
Date Received: 06-Dec-16 Date Prepared: 11-Dec-16 Date Analyzed: 11-Dec-16
Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U
Surrogate	Recovery	Control Limits	Qualifier			
SURROGATE: 1,2-DICHLOROETHANE-	103	69-139				
SURROGATE: 4-BROMOFLUOROBENZ	94.9	75-125				
SURROGATE: DIBROMOFLUOROMETH	104	75-125				
SURROGATE: TOLUENE-D8 (S)	98.4	75-125				
Internal Std	Qualifer					
1,4-DICHLOROBENZENE-D4 (IS)						
CHLOROBENZENE-D5 (IS)						
FLUOROBENZENE (IS)						

Comments:

ARF: 81653

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc

Contract #: *G012

Field Sample ID: LS-7

Lab Sample ID: AZ48450 Matrix: Water

% Solids: NA

Initial Calibration ID: T161227

Date Received: 04-Jan-17

Date Prepared: 05-Jan-17

Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1,1,2-TETRACHLOROETHANE	0.09	0.5	0.09	1		U
1,1,1-TCA	0.03	0.8	0.03	1		U
1,1,2,2-TETRACHLOROETHANE	0.07	0.4	0.07	1		U
1,1,2-TCA	0.06	1.0	0.06	1		U
1,1-DCA	0.07	0.4	0.07	1		U
1,1-DCE	0.12	1.2	0.12	1		U
1,1-DICHLOROPROPENE	0.10	1.0	0.10	1		U
1,2,3-TRICHLOROBENZENE	0.24	0.3	0.24	1		U
1,2,3-TRICHLOROPROPANE	0.17	3.2	0.17	1		U
1,2,4-TRICHLOROBENZENE	0.16	0.4	0.16	1		U
1,2,4-TRIMETHYLBENZENE	0.04	1.3	0.04	1		U
1,2-DCA	0.05	0.6	0.05	1		U
1,2-DCB	0.02	0.3	0.02	1		U
1,2-DIBROMO-3-CHLOROPROPANE	0.76	2.6	0.76	1		U
1,2-DICHLOROPROPANE	0.06	0.4	0.06	1		U
1,2-EDB	0.06	0.6	0.06	1		U
1,3,5-TRIMETHYLBENZENE	0.04	0.5	0.04	1		U
1,3-DCB	0.03	1.2	0.03	1		U
1,3-DICHLOROPROPANE	0.05	0.4	0.05	1		U
1,4-DCB	0.07	0.3	0.07	1		U
1-CHLOROHEXANE	0.04	0.5	0.04	1		U
2,2-DICHLOROPROPANE	0.10	3.5	0.10	1		U
2-CHLOROTOLUENE	0.04	0.4	0.04	1		U
4-CHLOROTOLUENE	0.04	0.6	0.04	1		U
BENZENE	0.07	0.4	0.07	1		U
BROMOBENZENE	0.06	0.3	0.06	1		U
BROMOCHLOROMETHANE	0.11	0.4	0.11	1		U
BROMODICHLOROMETHANE	0.06	0.8	0.06	1		U
BROMOFORM	0.13	1.2	0.13	1		U
BROMOMETHANE	0.08	1.1	0.08	1		U
CARBON TETRACHLORIDE	0.06	2.1	0.06	1		U
CHLOROBENZENE	0.04	0.4	0.04	1		U
CHLOROETHANE	0.07	1.0	0.07	1		U
CHLOROFORM	0.06	0.3	0.06	1		U
CHLOROMETHANE	0.16	1.3	0.16	1		U

Comments:

ARF: 81902

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc

Contract #: *G012

Field Sample ID: LS-7

Lab Sample ID: AZ48450

Matrix: Water

% Solids: NA

Initial Calibration ID: T161227

Date Received: 04-Jan-17

Date Prepared: 05-Jan-17

Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
CIS-1,3-DICHLOROPROPENE	0.03	1.0	0.03	1		U
DIBROMOCHLOROMETHANE	0.06	0.5	0.06	1		U
DIBROMOMETHANE	0.06	2.4	0.06	1		U
DICHLORODIFLUOROMETHANE	0.11	1.0	0.11	1		U
ETHYLBENZENE	0.05	0.6	0.05	1		U
HEXACHLOROBUTADIENE	0.17	1.1	0.17	1		U
ISOPROPYLBENZENE	0.04	0.5	0.04	1		U
M&P-XYLENE	0.07	0.5	0.07	1		U
METHYLENE CHLORIDE	0.35	1.0	0.35	1		U
N-BUTYLBENZENE	0.17	1.1	0.17	1		U
N-PROPYLBENZENE	0.03	0.4	0.03	1		U
NAPHTHALENE	0.07	0.4	0.07	1		U
O-XYLENE	0.06	1.1	0.06	1		U
P-ISOPROPYLtolUENE	0.05	1.2	0.05	1		U
SEC-BUTYLBENZENE	0.05	1.3	0.05	1		U
STYRENE	0.08	0.4	0.08	1		U
TCE	0.05	1.0	0.24	1		F
TERT-BUTYLBENZENE	0.04	1.4	0.04	1		U
TETRACHLOROETHENE	0.06	1.4	0.97	1		F
TOLUENE	0.06	1.1	0.06	1		U
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
TRANS-1,3-DICHLOROPROPENE	0.04	1.0	0.04	1		U
TRICHLOROFUOROMETHANE	0.07	0.8	0.07	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	123	69-139	
SURROGATE: 4-BROMOFUOROBENZ	97.3	75-125	
SURROGATE: DIBROMOFUOROMETH	104	75-125	
SURROGATE: TOLUENE-D8 (S)	104	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 81902

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc

Contract #: *G012

Field Sample ID: LS-7-A2

Lab Sample ID: AZ48451

Matrix: Water

% Solids: NA

Initial Calibration ID: T161227

Date Received: 04-Jan-17

Date Prepared: 05-Jan-17

Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1,1,2-TETRACHLOROETHANE	0.09	0.5	0.09	1		U
1,1,1-TCA	0.03	0.8	0.03	1		U
1,1,2,2-TETRACHLOROETHANE	0.07	0.4	0.07	1		U
1,1,2-TCA	0.06	1.0	0.06	1		U
1,1-DCA	0.07	0.4	0.07	1		U
1,1-DCE	0.12	1.2	0.12	1		U
1,1-DICHLOROPROPENE	0.10	1.0	0.10	1		U
1,2,3-TRICHLOROBENZENE	0.24	0.3	0.24	1		U
1,2,3-TRICHLOROPROPANE	0.17	3.2	0.17	1		U
1,2,4-TRICHLOROBENZENE	0.16	0.4	0.16	1		U
1,2,4-TRIMETHYLBENZENE	0.04	1.3	0.04	1		U
1,2-DCA	0.05	0.6	0.05	1		U
1,2-DCB	0.02	0.3	0.02	1		U
1,2-DIBROMO-3-CHLOROPROPANE	0.76	2.6	0.76	1		U
1,2-DICHLOROPROPANE	0.06	0.4	0.06	1		U
1,2-EDB	0.06	0.6	0.06	1		U
1,3,5-TRIMETHYLBENZENE	0.04	0.5	0.04	1		U
1,3-DCB	0.03	1.2	0.03	1		U
1,3-DICHLOROPROPANE	0.05	0.4	0.05	1		U
1,4-DCB	0.07	0.3	0.07	1		U
1-CHLOROHEXANE	0.04	0.5	0.04	1		U
2,2-DICHLOROPROPANE	0.10	3.5	0.10	1		U
2-CHLOROTOLUENE	0.04	0.4	0.04	1		U
4-CHLOROTOLUENE	0.04	0.6	0.04	1		U
BENZENE	0.07	0.4	0.07	1		U
BROMOBENZENE	0.06	0.3	0.06	1		U
BROMOCHLOROMETHANE	0.11	0.4	0.11	1		U
BROMODICHLOROMETHANE	0.06	0.8	0.06	1		U
BROMOFORM	0.13	1.2	0.13	1		U
BROMOMETHANE	0.08	1.1	0.08	1		U
CARBON TETRACHLORIDE	0.06	2.1	0.06	1		U
CHLOROBENZENE	0.04	0.4	0.04	1		U
CHLOROETHANE	0.07	1.0	0.07	1		U
CHLOROFORM	0.06	0.3	0.06	1		U
CHLOROMETHANE	0.16	1.3	0.16	1		U

Comments:

ARF: 81902

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc

Contract #: *G012

Field Sample ID: LS-7-A2

Lab Sample ID: AZ48451 Matrix: Water

% Solids: NA

Initial Calibration ID: T161227

Date Received: 04-Jan-17

Date Prepared: 05-Jan-17

Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
CIS-1,3-DICHLOROPROPENE	0.03	1.0	0.03	1		U
DIBROMOCHLOROMETHANE	0.06	0.5	0.06	1		U
DIBROMOMETHANE	0.06	2.4	0.06	1		U
DICHLORODIFLUOROMETHANE	0.11	1.0	0.11	1		U
ETHYLBENZENE	0.05	0.6	0.05	1		U
HEXACHLOROBUTADIENE	0.17	1.1	0.17	1		U
ISOPROPYLBENZENE	0.04	0.5	0.04	1		U
M&P-XYLENE	0.07	0.5	0.07	1		U
METHYLENE CHLORIDE	0.35	1.0	0.35	1		U
N-BUTYLBENZENE	0.17	1.1	0.17	1		U
N-PROPYLBENZENE	0.03	0.4	0.03	1		U
NAPHTHALENE	0.07	0.4	0.07	1		U
O-XYLENE	0.06	1.1	0.06	1		U
P-ISOPROPYLTOLUENE	0.05	1.2	0.05	1		U
SEC-BUTYLBENZENE	0.05	1.3	0.05	1		U
STYRENE	0.08	0.4	0.08	1		U
TCE	0.05	1.0	0.05	1		U
TERT-BUTYLBENZENE	0.04	1.4	0.04	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
TOLUENE	0.06	1.1	0.06	1		U
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
TRANS-1,3-DICHLOROPROPENE	0.04	1.0	0.04	1		U
TRICHLOROFUOROMETHANE	0.07	0.8	0.07	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	122	69-139	
SURROGATE: 4-BROMOFUOROBENZ	100	75-125	
SURROGATE: DIBROMOFUOROMETH	103	75-125	
SURROGATE: TOLUENE-D8 (S)	107	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 81902

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc Contract #: *G012

Field Sample ID: LS-7-SHOWER TAP Lab Sample ID: AZ48452 Matrix: Water

% Solids: NA Initial Calibration ID: T161227

Date Received: 04-Jan-17 Date Prepared: 05-Jan-17 Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
1,1,1,2-TETRACHLOROETHANE	0.09	0.5	0.09	1		U
1,1,1-TCA	0.03	0.8	0.03	1		U
1,1,2,2-TETRACHLOROETHANE	0.07	0.4	0.07	1		U
1,1,2-TCA	0.06	1.0	0.06	1		U
1,1-DCA	0.07	0.4	0.07	1		U
1,1-DCE	0.12	1.2	0.12	1		U
1,1-DICHLOROPROPENE	0.10	1.0	0.10	1		U
1,2,3-TRICHLOROBENZENE	0.24	0.3	0.24	1		U
1,2,3-TRICHLOROPROPANE	0.17	3.2	0.17	1		U
1,2,4-TRICHLOROBENZENE	0.16	0.4	0.16	1		U
1,2,4-TRIMETHYLBENZENE	0.04	1.3	0.04	1		U
1,2-DCA	0.05	0.6	0.05	1		U
1,2-DCB	0.02	0.3	0.02	1		U
1,2-DIBROMO-3-CHLOROPROPANE	0.76	2.6	0.76	1		U
1,2-DICHLOROPROPANE	0.06	0.4	0.06	1		U
1,2-EDB	0.06	0.6	0.06	1		U
1,3,5-TRIMETHYLBENZENE	0.04	0.5	0.04	1		U
1,3-DCB	0.03	1.2	0.03	1		U
1,3-DICHLOROPROPANE	0.05	0.4	0.05	1		U
1,4-DCB	0.07	0.3	0.07	1		U
1-CHLOROHEXANE	0.04	0.5	0.04	1		U
2,2-DICHLOROPROPANE	0.10	3.5	0.10	1		U
2-CHLOROTOLUENE	0.04	0.4	0.04	1		U
4-CHLOROTOLUENE	0.04	0.6	0.04	1		U
BENZENE	0.07	0.4	0.07	1		U
BROMOBENZENE	0.06	0.3	0.06	1		U
BROMOCHLOROMETHANE	0.11	0.4	0.11	1		U
BROMODICHLOROMETHANE	0.06	0.8	0.06	1		U
BROMOFORM	0.13	1.2	0.13	1		U
BROMOMETHANE	0.08	1.1	0.08	1		U
CARBON TETRACHLORIDE	0.06	2.1	0.06	1		U
CHLOROBENZENE	0.04	0.4	0.04	1		U
CHLOROETHANE	0.07	1.0	0.07	1		U
CHLOROFORM	0.06	0.3	0.06	1		U
CHLOROMETHANE	0.16	1.3	0.16	1		U

Comments:

ARF: 81902

AFCEE
ORGANIC ANALYSES DATA SHEET 2
RESULTS

Analytical Method: EPA 8260B Preparatory Method: 5030B AAB #: 170105AT-215286

Lab Name: APPL, Inc Contract #: *G012

Field Sample ID: LS-7-SHOWER TAP Lab Sample ID: AZ48452 Matrix: Water

% Solids: NA Initial Calibration ID: T161227

Date Received: 04-Jan-17 Date Prepared: 05-Jan-17 Date Analyzed: 05-Jan-17

Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
CIS-1,3-DICHLOROPROPENE	0.03	1.0	0.03	1		U
DIBROMOCHLOROMETHANE	0.06	0.5	0.06	1		U
DIBROMOMETHANE	0.06	2.4	0.06	1		U
DICHLORODIFLUOROMETHANE	0.11	1.0	0.11	1		U
ETHYLBENZENE	0.05	0.6	0.05	1		U
HEXACHLOROBUTADIENE	0.17	1.1	0.17	1		U
ISOPROPYLBENZENE	0.04	0.5	0.04	1		U
M&P-XYLENE	0.07	0.5	0.07	1		U
METHYLENE CHLORIDE	0.35	1.0	0.35	1		U
N-BUTYLBENZENE	0.17	1.1	0.17	1		U
N-PROPYLBENZENE	0.03	0.4	0.03	1		U
NAPHTHALENE	0.07	0.4	0.07	1		U
O-XYLENE	0.06	1.1	0.06	1		U
P-ISOPROPYLtolUENE	0.05	1.2	0.05	1		U
SEC-BUTYLBENZENE	0.05	1.3	0.05	1		U
STYRENE	0.08	0.4	0.08	1		U
TCE	0.05	1.0	0.05	1		U
TERT-BUTYLBENZENE	0.04	1.4	0.04	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
TOLUENE	0.06	1.1	0.06	1		U
TRANS-1,2-DCE	0.08	0.6	0.08	1		U
TRANS-1,3-DICHLOROPROPENE	0.04	1.0	0.04	1		U
TRICHLOROFUOROMETHANE	0.07	0.8	0.07	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	126	69-139	
SURROGATE: 4-BROMOFUOROBENZ	96.1	75-125	
SURROGATE: DIBROMOFUOROMETH	105	75-125	
SURROGATE: TOLUENE-D8 (S)	106	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 81902