



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAAP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

January 28, 2020

U-028-20

SUBJECT: Sampling of Water Wells LS-5, Located at 7579 Curres Creek Road and LS-6, Located at 7655 Curres Creek Road

[REDACTED]  
Boerne, TX 78015

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your wells (LS-5 and LS-6) on 12/2/19. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis.

This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort. An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well LS-5, serves 7655 & 7579 Curres Creek Road			
12/2/19	Tetrachloroethene (PCE)	0.97F	5
	Trichloroethene (TCE)	3.02	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70
Well LS-6, serves 7655 Curres Creek Road			
12/2/19	Tetrachloroethene (PCE)	1.07F	5
	Trichloroethene (TCE)	1.05	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

\*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, levels of the VOCs PCE and TCE were identified in the water samples from your wells LS-5 and LS-6 before granular activated carbon (GAC) filtration. Results from the laboratory analyses are provided as an attachment for the above sampling event. These levels are below the applicable MCLs and do not affect usability of your wells. The concentrations reported in your wells LS-5 and LS-6 were above or approaching the MCL for VOCs in the past. Therefore, a filtration system was installed on each well.

ProAct Services Corporation of Houston, Texas provides maintenance for the GAC filtration systems on your wells. The systems will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will continue to be responsible for all costs associated with operation and maintenance of these systems. CSSA will continue to send a representative every three weeks to exchange the five-micron pre-and post-filters in the system.

ProAct exchanged the first carbon canister and performed other routine maintenance on your systems September 16, 2019. If you experience any problems with the systems, please let the installer or CSSA know immediately. ProAct is very responsive and can make additional maintenance visits if needed. Post-GAC samples were not collected this event but are scheduled to be collected again during the March 2020 sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your wells are scheduled to be sampled again in March 2020.

Again, we would like to thank you for your cooperation. We regret that your wells have been impacted but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Margarita Loya, Environmental Program Manager, at (210) 295-7067.

Sincerely,



Jason D. Shirley  
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6  
Mr. Timothy Brown, TCEQ Central Office  
Mr. Jorge Salazar, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 191205AM-247998  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: LS-5      Lab Sample ID: BA04016      Matrix: Water  
 % Solids: NA      Initial Calibration ID: M191203  
 Date Received: 03-Dec-19      Date Prepared: 05-Dec-19      Date Analyzed: 05-Dec-19  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	3.02	1		
TETRACHLOROETHENE	0.06	1.4	0.97	1		F
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	109	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	94.1	75-125	
SURROGATE: DIBROMOFLUOROMETH	99.1	75-125	
SURROGATE: TOLUENE-D8 (S)	98.2	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 90906

AFCEE FORM O-2

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 191205AM-247998  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: LS-6      Lab Sample ID: BA04017      Matrix: Water  
 % Solids: NA      Initial Calibration ID: M191203  
 Date Received: 03-Dec-19      Date Prepared: 05-Dec-19      Date Analyzed: 05-Dec-19  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	1.05	1		
TETRACHLOROETHENE	0.06	1.4	1.07	1		F
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	108	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	92.8	75-125	
SURROGATE: DIBROMOFLUOROMETH	98.6	75-125	
SURROGATE: TOLUENE-D8 (S)	95.0	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 90906