



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAAP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

January 28, 2020

U-022-20

SUBJECT: Sampling of Water Well RFR-11, Located at 25360 Old Fredericksburg Road

Mr. [REDACTED]  
[REDACTED]  
Boerne, TX 78015

Dear [REDACTED]

Camp Stanley Storage Activity (CSSA) collected a groundwater sample from your well (RFR-11) on 12/2/19. This sample was submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

| Date Sampled  | VOC Compound                         | Result (ppb)       | MCL (ppb) |
|---|--------------------------------------|--------------------|-----------|
| Well RFR-11, located at 25360 Old Fredericksburg Road |                                      |                    |           |
| 12/2/19   | Tetrachloroethene (PCE)              | 1.43               | 5         |
|   | Trichloroethene (TCE)                | 2.01               | 5         |
|   | <i>cis</i> -1,2-Dichloroethene (DCE) | <0.07 (non-detect) | 70        |

Based on the analytical data, levels of the VOCs PCE and TCE were identified in the water sample from your well before granular activated carbon (GAC) filtration. Results from the laboratory analysis are provided as an attachment for the above sampling event. These levels are below the applicable MCL and does not affect usability of your well. The concentrations reported for the VOC PCE was above the MCL in the past. Therefore, a filtration system was installed on your well.

ProAct Services Corporation of Houston, Texas provides maintenance for the GAC filtration system on your well. The system will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will continue to be responsible for all costs associated with operation and maintenance of this system. CSSA will continue to send a

representative every three weeks to exchange the five-micron pre-and post-filters in the system.

ProAct exchanged the first carbon canister and performed other routine maintenance on your system September 16, 2019. If you experience any problems with the system, please let the installer or CSSA know immediately. ProAct is very responsive and can make additional maintenance visits if needed. Post-GAC samples were not collected this event but are scheduled to be collected again during the March 2020 sampling event.

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well is scheduled to be sampled again in March 2020.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Margarita Loya, Environmental Program Manager, at (210) 295-7067.

Sincerely,



Jason D. Shirley  
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6  
Mr. Timothy Brown, TCEQ Central Office  
Mr. Jorge Salazar, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 191205AM-247998  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: RFR-11      Lab Sample ID: BA04020      Matrix: Water  
 % Solids: NA      Initial Calibration ID: M191203  
 Date Received: 03-Dec-19      Date Prepared: 05-Dec-19      Date Analyzed: 05-Dec-19  
 Concentration Units: ug/L

| Analyte           | MDL  | RL  | Concentration | Dilution | Confirm | Qualifier |
|-------------------|------|-----|---------------|----------|---------|-----------|
| CIS-1,2-DCE       | 0.07 | 1.2 | 0.07          | 1        |         | U         |
| TCE               | 0.05 | 1.0 | 2.01          | 1        |         |           |
| TETRACHLOROETHENE | 0.06 | 1.4 | 1.43          | 1        |         |           |
| VINYL CHLORIDE    | 0.08 | 1.1 | 0.08          | 1        |         | U         |

| Surrogate                      | Recovery | Control Limits | Qualifier |
|--------------------------------|----------|----------------|-----------|
| SURROGATE: 1,2-DICHLOROETHANE- | 116      | 69-139         |           |
| SURROGATE: 4-BROMOFLUOROBENZ   | 95.2     | 75-125         |           |
| SURROGATE: DIBROMOFLUOROMETH   | 103      | 75-125         |           |
| SURROGATE: TOLUENE-D8 (S)      | 95.1     | 75-125         |           |

| Internal Std                | Qualifier |
|-----------------------------|-----------|
| 1,4-DICHLOROBENZENE-D4 (IS) |           |
| CHLOROBENZENE-D5 (IS)       |           |
| FLUOROBENZENE (IS)          |           |

Comments:

ARF: 90906