



DEPARTMENT OF THE ARMY  
 CAMP STANLEY STORAGE ACTIVITY, MCAAP  
 25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

April 29, 2020

U-035-20

SUBJECT: Sampling of Water Well RFR-11, Located at 25360 Old Fredericksburg Road

[Redacted]

Boerne, TX 78015

Dear [Redacted]

Camp Stanley Storage Activity (CSSA) collected groundwater samples from your well (RFR-11) on 3/11/20 and 4/20/20. These samples were submitted to a laboratory contracted by CSSA's environmental contractor for volatile organic compound (VOC) analysis. This letter provides you with the VOC data from the laboratory results and a formal thank you for your assistance in this groundwater monitoring effort.

An abbreviated summary of analytical results compared to maximum contaminant levels (MCLs) allowed in drinking water by the U.S. EPA under the Safe Drinking Water Act is provided below:

Date Sampled	VOC Compound	Result (ppb)	MCL (ppb)
Well RFR-11, located at 25360 Old Fredericksburg Road			
3/11/20	Tetrachloroethene (PCE)	1.21F	5
	Trichloroethene (TCE)	1.87	5
	<i>cis</i> -1,2-Dichloroethene (DCE)	<0.07 (non-detect)	70

\*The "F" qualifier indicates the value is above the laboratory method detection limit, but below the laboratory reporting limit for the compound.

Based on the analytical data, levels of the VOCs PCE and TCE were identified in the water sample from your well before granular activated carbon (GAC) filtration. Results from the laboratory analysis are provided as an attachment for the above sampling event. These levels are below the applicable MCL and do not affect usability of your well. The concentrations reported for the VOC PCE were above the MCL in the past. Therefore, a filtration system was installed on your well.

ProAct Services Corporation of Houston, Texas provides maintenance for the GAC filtration system on your well. The system will remain in operation for the foreseeable future or until significant reductions in contamination levels are seen in the water in your well before it enters the filtration system. As we discussed at the time of installation, CSSA will continue to be responsible for all costs associated with operation and maintenance of this system. CSSA will continue to send a

representative every three weeks to exchange the five-micron pre- and post-filters in the system.

ProAct exchanged the first carbon canister and performed other routine maintenance on your system March 31, 2020. If you experience any problems with the system, please let the installer or CSSA know immediately. ProAct is very responsive and can make additional maintenance visits if needed.

On 3/11/20, CSSA collected a sample from your well RFR-11 after the water was processed through the granular activated carbon (GAC) filter system. An additional sample was collected 4/20/20 after ProAct performed the carbon exchange service on 3/31/20. These samples are representative of the water being delivered to you for daily use. Based on the analytical data, no VOCs related to CSSA's groundwater investigation were identified in the samples after the second carbon canister (A2). A summary of the post-GAC analytical results is provided below. Copies of the laboratory data sheets are attached. CSSA will collect additional confirmation samples on a 6-month basis to confirm the system remains effective.

<b>Date Sample</b>	<b>VOC compound</b>	<b>Result (ppb)</b>	<b>MCL (ppb)</b>
RFR-11-A2, located at 25360 Old Fredericksburg Road			
3/11/20	PCE	<0.06 (non-detect)	5
	TCE	<0.05 (non-detect)	5
	<i>cis-1,2-DCE</i>	<0.07 (non-detect)	70
RFR-11-A2, located at 25360 Old Fredericksburg Road			
4/20/20	PCE	<0.06 (non-detect)	5
	TCE	<0.05 (non-detect)	5
	<i>cis-1,2-DCE</i>	<0.07 (non-detect)	70

As part of the ongoing CSSA environmental program, we are continuing to investigate and cleanup VOC source areas on the installation and to track these compounds in groundwater on- and off-post. As part of this effort, your well is scheduled to be sampled again in June 2020.

Again, we would like to thank you for your cooperation. We regret that your well has been impacted but remain committed to making sure your water is safe to use and keeping you informed. If you have any questions concerning this letter, please contact Margarita Loya, Environmental Program Manager, at (210) 295-7067.

Sincerely,



Jason D. Shirley  
Installation Manager

Enclosure

cc: Mr. Greg Lyssy, EPA Region 6  
Mr. Timothy Brown, TCEQ Central Office  
Mr. Jorge Salazar, TCEQ Region 13  
Ms. Kyle Cunningham, San Antonio Metropolitan Health Dist.  
Ms. Julie Burdey, Parsons

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 200320AL-251007  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: RFR-11      Lab Sample ID: BA08522      Matrix: Water  
 % Solids: NA      Initial Calibration ID: 200319  
 Date Received: 13-Mar-20      Date Prepared: 21-Mar-20      Date Analyzed: 21-Mar-20  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	1.87	1		
TETRACHLOROETHENE	0.06	1.4	1.21	1		F
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	95.5	69-139	
SURROGATE: 4-BROMOFLUOROBENZE	95.3	75-125	
SURROGATE: DIBROMOFLUOROMETH	107	75-125	
SURROGATE: TOLUENE-D8 (S)	103	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 91676

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: 200320AL-251007  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: RFR-11-A2      Lab Sample ID: BA08523      Matrix: Water  
 % Solids: NA      Initial Calibration ID: 200319  
 Date Received: 13-Mar-20      Date Prepared: 21-Mar-20      Date Analyzed: 21-Mar-20  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	93.2	69-139	
SURROGATE: 4-BROMOFLUOROBENZE	90.0	75-125	
SURROGATE: DIBROMOFLUOROMETH	93.6	75-125	
SURROGATE: TOLUENE-D8 (S)	98.8	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 91676

AFCEE FORM O-2

AFCEE  
ORGANIC ANALYSES DATA SHEET 2  
RESULTS

Analytical Method: EPA 8260B      Preparatory Method: 5030B      AAB #: AT200421-251912  
 Lab Name: APPL, Inc      Contract #: \*G012  
 Field Sample ID: RFR-11-A2      Lab Sample ID: BA09849      Matrix: Water  
 % Solids: NA      Initial Calibration ID: T200414  
 Date Received: 21-Apr-20      Date Prepared: 21-Apr-20      Date Analyzed: 21-Apr-20  
 Concentration Units: ug/L

Analyte	MDL	RL	Concentration	Dilution	Confirm	Qualifier
CIS-1,2-DCE	0.07	1.2	0.07	1		U
TCE	0.05	1.0	0.05	1		U
TETRACHLOROETHENE	0.06	1.4	0.06	1		U
VINYL CHLORIDE	0.08	1.1	0.08	1		U

Surrogate	Recovery	Control Limits	Qualifier
SURROGATE: 1,2-DICHLOROETHANE-	103	69-139	
SURROGATE: 4-BROMOFLUOROBENZ	94.6	75-125	
SURROGATE: DIBROMOFLUOROMETH	106	75-125	
SURROGATE: TOLUENE-D8 (S)	98.2	75-125	

Internal Std	Qualifier
1,4-DICHLOROBENZENE-D4 (IS)	
CHLOROBENZENE-D5 (IS)	
FLUOROBENZENE (IS)	

Comments:

ARF: 91927