



DEPARTMENT OF THE ARMY  
CAMP STANLEY STORAGE ACTIVITY, MCAPP  
25800 RALPH FAIR ROAD, BOERNE, TX 78015-4800

July 17, 2013

U-096-13

Mr. Bryan Smith  
Texas Commission on Environmental Quality  
Industrial and Hazardous Waste Permits Section  
P.O. Box 13087 (MC-130)  
Austin, TX 78711-3087

Subject: Annual Status Report (Month 61 - Month 72, May 1, 2012 - April 30, 2013) of the Pilot Study Class V Aquifer Remediation Injection Wells at Camp Stanley Storage Activity, Boerne, Texas, TCEQ Authorization No. 5X2600431; WWC12002216; CN602728206/RN104431655

Dear Mr. Smith:

The Camp Stanley Storage Activity (CSSA), McAlester Army Ammunition Plant, U.S. Army Field Support Command, Army Materiel Command, U.S. Army, is submitting this annual report summarizing the injection activities performed at the on-post Solid Waste Management Unit (SWMU) B-3 site. The activities performed are part of the planned SWMU B-3 Pilot Study being performed to evaluate the effectiveness of enhanced anaerobic biodegradation (EAB) for treatment of chlorinated compounds in groundwater. The pilot study activities include the injection of recovered groundwater into mulch/gravel filled bioreactor trenches.


This annual report contains data as specified by the Texas Commission on Environmental Quality (TCEQ) Underground Injection Control (UIC) permit for the months of May, 2012 through April, 2013 (Months 61-72). The annual reporting data includes monthly and quarterly samples of the injected groundwater for volatile organic concentrations (VOCs) and total dissolved solids (TDS) and field collected parameters including injection volumes, injection pressures and the pH of recovered groundwater. Data indicates that concentrations of contaminants did not exceed limits specified in 40 CFR §261.24 Table 1 as referenced in CSSA's UIC permit authorization.

Between May 1, 2012 and April 30, 2013 approximately 15,218,814 gallons of groundwater from wells CS-MW16-CC (~5,332,600 gallons), CS-MW16-LGR (~1,575,100 gallons), B3-EXW-01 (~2,152,000 gallons), B3-EXW-02 (~2,579,200 gallons), B3-EXW-03 (~1,464,000 gallons), B3-EXW-04 (~1,096,000 gallons), and B3-EXW-05 (~937,500 gallons) were injected into SWMU B-3 bioreactor trenches 1 and 6. A total of 73,841,268 gallons of recovered groundwater from CS-MW16-LGR, CS-MW16-CC, B3-EXW01, B3-EXW02, B3-EXW03, B3-EXW04, and B3-EXW05 have been injected into bioreactor trenches since normal bioreactor operations began. During this period, sampling efforts associated with this UIC permit was reduced from a monthly to a quarterly basis as authorized in TCEQ

correspondence dated February 17, 2012. Samples of the injected groundwater, for this reporting period, were collected on May 29, June 26, July 26 and October 29, 2012, and January 16, and April 15, 2013. Results of analysis are summarized in the attached Table 1. An additional 14,860 gallons of recovered groundwater were injected into the bioreactor. This additional water was generated from well drilling efforts located on post (12,100 gallons from B3-EXW-05, and 150 gallons from each ISCO Injection Well installed at AOC-65 as authorized by TCEQ Authorization No. 5X2600645) and well development efforts on post (2,160 gallons from CS-MW2-LGR). The laboratory data packages for characterization of the managed water for the newly drilled wells are included in the accompanying CD as is the most recent data package for CS-MW2-LGR prior to development. Field forms which contain operating pressures and pH readings for the reporting period are attached and the laboratory data packages are included in the accompanying CD.

If you have any questions regarding the information contained in this letter, please feel free to contact Gabriel Moreno-Fergusson, CSSA Environmental Program Manager, at (210) 295-7453 or Ken Rice, Parsons, at (512) 719-6050.

Sincerely,



Jason D. Shirley  
Installation Manager

Enclosures

cc: Gabriel Moreno-Fergusson, CSSA Environmental Program Manager  
Julie Burdey, Parsons (ltr only)  
Ken Rice, Parsons  
File: 748350.01100

Table 1

**SWMU B3 UIC Analytical Summary Table**  
May 2012 - April 2013

	B3-UIC Criteria (RCRA Haz.)		Results	Flags	Dilution	Results	Flags	Dilution	Results	Flags	Dilution	Results	Flags	Dilution	Results	Flags	Dilution
	Lab	MDL	PQL	(RCRA Haz.)													
SW8260B (µg/l)	cis-DCE	0.07	1.2	--	114	2	94	10	80	1	76	1	117	5	120	1	
	trans-DCE	0.08	0.6	--	3.2	1	2.8	1	4.2	1	3.3	1	3.4	1	2.3	1	
	TCE	0.05	1.0	500	107	2	84	10	60	1	71	1	113	5	116	1	
	PCE	0.06	1.4	700	93	1	69	1	49	1	55	1	86	1	89	1	
	Toluene	0.06	1.1	--	0.06	U	1										
	Vinyl chloride	0.08	1.1	200	0.08	U	1										
EPA 160.1 (mg/l)					354	1	352	1	395	1	368	1	368	1	384	1	
TDS		4.4	10	--													

Tables present all laboratory results for analytes.

Data packages for laboratory results are presented in Attachment 1.

All samples were analyzed by APL Laboratory Services.

pH results reported were field measured.

UIC criteria specified in 40 CFR 261.24 Table 1.

**Abbreviations:**

MDL	Method Detection Limit
PQL	Practical Quantitation Limit
N1	Environmental Sample
UIC	Underground Injection Control

**Data Qualifiers:**  
U - The analyte was analyzed for, but not detected. The associated numerical value is the MDL.

**TCEQ Correspondence**

Bryan W. Shaw, Ph.D., *Chairman*  
Buddy Garcia, *Commissioner*  
Carlos Rubinstein, *Commissioner*  
Mark R. Vickery, P.G., *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

February 17, 2012

Mr. Jason Shirley  
Installation Manager  
U.S. Army, Camp Stanley Storage Activity  
25800 Ralph Fair Road  
Boerne, TX 78015

Re: Amendment to Class V Authorization  
TCEQ Authorization No. 5X2600431  
CN602728206/RN104431655  
Camp Stanley Storage Activity  
25800 Ralph Fair Road  
Boerne, TX 78015

Dear Mr. Shirley:

The Underground Injection Control (UIC) staff has completed review of the modification request dated August 29, 2011 requesting approval to change the data collection and reporting requirements for the above authorization. The following change has been made to the above Class V authorization.

Injection volumes, pressures, and concentrations of contaminants (including pH and total dissolved solids) in the injected groundwater shall be sampled quarterly at the point of reinjection (prior to fluids being released into the trenches). The concentration of contaminates in the trench bioreactor monitoring sums and the surrounding monitoring wells shall be sampled semiannually. All monitoring and sampling data shall be submitted to the UIC Permits Team, Radioactive Materials Divisions, at mail code MC 233 on an annual basis. All other requirements of the above mentioned authorization remain in effect.

If you have any questions regarding this matter, please contact me at (512) 239-6075. If you will be corresponding by mail, please use mail code MC 233.

Sincerely,

A handwritten signature in black ink, appearing to read "Bryan S. Smith".

Bryan S. Smith  
Underground Injection Control Permits Team  
Radioactive Materials Division

BSS/nlc

cc: Mr. Ken Rice, Parsons, 8000 Centre Park Drive, Suite 200, Austin, TX 78754

## **Field Forms**

## Bioreactor Monitoring

Personnel: Elliott

## Trench Sumps Water Levels ('BTOC)

Sump ID	Sump Depth ('BTOC)	Sump Water Level ('BTOC)	pH	Temp (deg C)	Second (mS/cm)	ORP	DO (mg/L)	Trench Currently Being Used (✓)	Notes
B3-T1-1	12.9	7.97	6.51	25.01	0.439	-154.7	0.23		
B3-T1-2	12.4	7.52	6.73	24.87	0.549	-118.1	0.10		
B3-T1-3	12.85	7.89	6.54	25.79	0.473	-130.8	0.09	✓	
B3-T2-1	9.67	9.04	6.85	30.11	1.746	-195.4	0.22		
B3-T2-2	10.01	8.90	6.45	26.64	0.804	-145.7	0.12		
B3-T3-1	9.96	9.10							
B3-T3-2	7.4	dry							
B3-T4-1	6.32	dry							
B3-T5-1	9.33	9.16							
B3-T5-2	7.98	2.89							
B3-T6-1	11.45	9.31	6.40	24.84	0.666	-138.7	0.05		
B3-T6-2	12.34	9.10	6.41	24.45	0.704	-153.7	0.04	✓	
B3-UIC									

## B-3 Transfer System Monitoring

Meter	Monday	Tuesday	Wednesday	Thursday	Friday
Date/Time:	7/9/12 0850	7/10/12 0830	7/11/12	7/12/12	7/13/12
T-1	22.3	2854450	23.3	7885104	
T-2					
T-3					
T-4					
T-5					
T-6	16.1	3552433	17.0	3574934	
B-3 (Total)					
CS-MNW16-LGR	5.98	976144	6.04	934847	6.48
CS-MNW16-CC	11.14	695521	11.22	711292	11.55
B3-EXW01	9.24	381615	3.77	387031	5.51
B3-EXW02	5.88	24801083	5.67	7493032	0
PB-1 - PB-2 =					7505795
Notes:	MW16LGR MW16CC B3EXW01 B3EXW02 SCADA	Quick trends = ✓	PB-1 - PB-2 =	Note: If using MW16CC then PB-1 = PB-2 = 0 = 10psi change after	PB-1 - PB-2 = PB-1 - PB-2 = Quick Trends = ✓

Week 27

Personnel	<i>Elliott + Lindley</i>					
Weekly Water Level Monitoring						
Well Interval	Sampling Port Depth (ft BTOC)	Sample Date	Sample Time	Pressure at TOC (psi)	Pressure in MP (psi)	Zone Pressure (psi)
CS-WB05-LGR-01	99	7/12/12	0930	14.06 14.15 14.17 15.66 22.22 44.84 59.18 89.58 101.75	14.10 14.10 14.18 15.46 22.04 44.71 59.07 89.49 101.64	19.78 14.09 14.08 15.24 19.22 41.71 56.79 62.95 75.34
CS-WB05-LGR-02	182		0929			
CS-WB05-LGR-03A	216		0928			
CS-WB05-LGR-03B	262		0927			
CS-WB05-LGR-04A	277		0926			
CS-WB05-LGR-04B	329		0924			
CS-WB05-BS-01	362		0921			
CS-WB05-CC-01	432		0920			
CS-WB05-CC-02	460		0919			
CS-WB06-UGR-01	20		0854			
CS-WB06-LGR-01	93		0853	14.00	14.10 14.10	16.25 16.36
CS-WB06-LGR-02	174		0852		14.15	19.84
CS-WB06-LGR-03A	207		0851		14.19	21.93
CS-WB06-LGR-03B	260		0850		25.77	44.86
CS-WB06-LGR-04	320		0849		51.82	40.62
CS-WB07-UGR-01	14		0910		51.81	
CS-WB07-LGR-01	90		0909	14.01	14.09 14.13 14.17 14.16	14.13 34.12 27.48 13.70
CS-WB07-LGR-02	175		0907		14.07	
CS-WB07-LGR-03A	208		0905		14.09	
CS-WB07-LGR-03B	257		0904		14.14	30.90
CS-WB07-LGR-04	318		0903		24.24	40.33
CS-WB08-UGR-01	38		0839		24.20	
CS-WB08-LGR-01	115		0838	13.98	14.05 14.02 14.07 14.10	18.22 19.29 20.52 13.66
CS-WB08-LGR-02	193		0837		14.13	
CS-WB08-LGR-03A	228		0835		14.15	
CS-WB08-LGR-03B	273		0834		14.18	
CS-WB08-LGR-04	341	↓	0833		24.20 53.77	13.70 41.79

Week 27 (JN)

Personnel: S. Dauenhauer

### Trench Sumps Water Levels ('BTTOC)

Sump ID	Sump Depth (ft BTTOC)	Sump Water Level (ft BTTOC)	pH	Temp. (deg C)	Sp.Cand. (mS/cm)	ORP	Do (mg/l)	Trench Currently Being Used (%)	Notes
Date: 10.9.17	12.9	7.48	6.11	24.59	9.1380	-25.0	0.07		
B3-T1-1	12.4	4.43	6.21	22.09	0.195	105.4	0.11		
B3-T1-2	12.85	4.52	7.00	24.58	0.195	17.0	0.07		
B3-T1-3	9.67	4.54	4.55	29.67	1.613	108.6	0.14		
B3-T2-2	10.01	4.54	6.96	24.61	1.5741	-17.7	0.11		
B3-T3-1	9.96	6.19	7.07	29.75	1.062	116.7	0.19		
B3-T3-2	7.4	DR							
B3-T4-1	6.32	DR							
B3-T5-1	9.33	3.82							
B3-T5-2	7.98	4.87							
B3-T6-1	11.45	7.56	6.24	22.44	0.593	38.0	0.07		
B3-T6-2	12.34	7.35	6.29	22.67	0.673	-18.6	0.01		
B3-UIC									

### B-3 Transfer System Monitoring

Meter	Monday	Tuesday	Wednesday	Thursday	Friday		
Date/Time:	10.9.17	10.9.17	10.10.17	10.11.17	10.12.17		
CS-MW16-LGR	162.317	8.97	163.756	8.30	164.715	8.58	
CS-MW16-CC	9.17.161	1.55	9.16078	1.55	9.16523	1.49	
B3-EXW01	8.42	1.91.0037	0.83	10.23598	8.23	10.321609	9.09
B3-EXW02	9.34.53	8.135267	9.34	9.150412	9.20	9.16055	9.31
B3-EXW03							
B3-EXW04							
B3-EXW05							
T-1	13.4	407.7443	13.5	429.501	13.2	443.435	13.8
T-6	5.77	4.083.950	6.16	409.117	6.60	41.00.824	6.91
Meter In:							
Meter Out:	15.3603	380.0	430.0	480.0	520	560.0	600.0
Tank Levels:							
Bag Filter Pressure (In/Out):	14	8	7	3	3	3	3
Change BF	150 μ	75 μ	150 μ	75 μ	150 μ	75 μ	150 μ
Notes:	Siphon hit line for new wells. Turned off wells @ 0915. Turned on @ 1140.					Hillbix @ 13 fixing tanks - fixed manifolds outside and tanks inside @ 1400	
①	1/3	2/3	3/3	3/3	3/3	3/3	3/3
	After change of all trenches open T9 until next week, same levels					Tank levels @ 1400	

Personnel	Elliott + Bouch					
	Weekly Water Level Monitoring					
Well Interval	Sampling Port Depth (ft BTOC)	Sample Date	Sample Time	Pressure at TOC (psi)	Pressure in MP (psi)	Zone Pressure (psi)
CS-WB05-LGR-01	99	10-9-12	1121	14.02	14.10 14.11	19.72
CS-WB05-LGR-02	182		1120		14.15 14.15	14.14
CS-WB05-LGR-03A	216		1119		14.17 14.18	14.34
CS-WB05-LGR-03B	262		1118		15.66 15.22	31.16
CS-WB05-LGR-04A	277		1116		22.22 21.75	38.144
CS-WB05-LGR-04B	329		1115		44.84 44.40	61.16
CS-WB05-BS-01	362		1114		59.18 58.77	74.48
CS-WB05-CC-01	432		1113		89.58 89.18	65.26
CS-WB05-CC-02	460		1112		101.75 101.35	77.58
CS-WB06-UGR-01	20		1149		14.10 14.04	17.54
CS-WB06-LGR-01	93		1148	14.05	14.14 14.09	16.44
CS-WB06-LGR-02	174		1147		14.15 14.14	32.29
CS-WB06-LGR-03A	207		1146		14.19 14.17	24.87
CS-WB06-LGR-03B	260		1145		25.77 25.71	49.83
CS-WB06-LGR-04	320		1144		51.82 51.80	62.71
CS-WB07-UGR-01	14		1135		14.09 14.08	15.52
CS-WB07-LGR-01	90		1134	14.08	14.10 14.10	31.31
CS-WB07-LGR-02	175		1133		14.17 14.13	26.90
CS-WB07-LGR-03A	208		1132		14.16 14.15	16.21
CS-WB07-LGR-03B	257		1131		14.21 14.22	37.23
CS-WB07-LGR-04	318		1130		24.24 24.19	60.38
CS-WB08-UGR-01	38		1203		14.08 14.06	19.39
CS-WB08-LGR-01	115		1202	14.03	14.13 14.10	19.23
CS-WB08-LGR-02	193		1201		14.15 14.13	22.01
CS-WB08-LGR-03A	228		1200		14.18 14.17	14.19
CS-WB08-LGR-03B	273		1159		24.20 24.15	32.52
CS-WB08-LGR-04	341	V	1158		53.77 53.73	62.87

Personnel: J. Brown, J. Elliott

### Trench Sumps Water Levels ('BTOTC)

Sump ID	Sump Depth (in BTOTC)	Sump Water Level (in BTOTC)	pH	Temp (deg C)	Spt.Cnd. (mS/cm)	ORP	DO (mg/l.)	Trench Currently Being Used (v)	Notes
B3-T1-1	12.9	11.68	9.89	23.1	1.165	-31.4	0.19	②	BTOTC
B3-T1-2	12.4	11.50	9.89	23.0	0.577	29.1	0.08	③	BTOTC
B3-T1-3	12.85	11.36	6.73	24.2	0.857	23.1	0.01	④	BTOTC
B3-T2-1	9.67	6.18	7.60	28.7	1.953	-6.3	0.11	⑤	BTOTC
B3-T2-2	10.01	6.58	7.42	23.47	1.748	37.1	0.03	⑥	BTOTC
B3-T3-1	9.96	8.74	DEY	29.82	12.0	144.4	0.31		
B3-T3-2	7.4	DEY							
B3-T4-1	6.32	DEY							
B3-T5-1	9.33	8.06							
B3-T5-2	7.98	7.89							
B3-T6-1	11.45	11.12	10.52	22.90	0.130	-39.9	-0.03	⑦	BTOTC
B3-T6-2	12.34	11.69	9.54	23.32	0.174	-4.3	-0.01	⑧	BTOTC
B3-UIC				24.95	0.581	128.9	4.58	⑨	BTOTC

### B-3 Transfer System Monitoring

Meter	Date/Time:	Monday	Tuesday	Wednesday	Thursday	Friday
CS-MW16-LGR	11.15.12 9:32	10.16.12 10:20	10.17.12 08:55	(0.1.2.12	10.18.12	10.19.12 21:5
CS-MW16-CC	11.2.3	11.1.35.7	7.46	17.18861	7.44	172.98
B3-EXW01	9.21	32.65	9.36	48073	9.26	615.30
B3-EXW02	7.30	32.4851	7.49	100.700	7.26	111.074
B3-EXW03		10.29.909	—	8.12	824.9520	No time for
B3-EXW04						7.93
B3-EXW05						8.27.30.11
T-1	15.5	5420.30	13.9	561169	14.0	5803280
T-6	4.84	4145124	6.49	4154792	7.10	411639710
Meter In:	15.3	54.248	16.11	567837	16.40	590917
Meter Out:	15.3	4300	13.00	4300	4300	15.34
Tank Levels:	4300	4300	4300	4300	4300	15.34
Bag Filter Pressure (In/Out):	13	8	8	5	5	15.34
Change BF	150 u	75 u	150 u	75 u	150 u	150 u
Notes:	1	1	1	1	1	1

1/9 7:28 AM  
 indicated no change and  
 in filter. Check off and  
 gauge on 2nd BF

Personnel: J. Boen, S. Elliott

### Weekly Piezometer Water Levels ('BTOP) and Monthly Field Parameters

Piezometer ID	ID (ft BTOP)	Date Sampled	Weekly/Monthly Writts				Monthly Field Parameters			
			Time	Water Level (ft BTOP)	pH	Temp. (deg. C)	Sp. Cond. (mS/cm)	ORP (mV)	DO (mg/l)	Notes
B3-MW26-UGR	20.32	10/15/12	1020	12.03	6.416	21.19	0.815	-170.7	0.38	
B3-MW27-UGR	17.00		1040	7.94	6.59	24.38	0.713	-86.9	0.35	CRP = 86.9
B3-MW28-UGR	18.33		1040	18.30	No	Samp 1				
B3-MW29-UGR	20.40		1052	19.48	6.62	21.43	0.765	67.5	1.82	Crust not yet all samples set all
B3-MW30-UGR	23.90		1120	22.33	6.65	21.88	0.786	118.2	3.34	
B3-MW31-UGR	39.06		1140	32.90	6.55	21.51	0.759	128.7	2.164	
B3-MW32-UGR	58.45		1320	38.62	6.74	20.99	0.594	132.7	3.49	
B3-MW33-UGR	29.55		1345	20.90	6.70	20.95	0.876	-234.2	0.28	
B3-MW34-UGR	25.40	✓	0955	17.02	6.55	21.90	0.720	-170.4	0.35	

### Quarterly Monitoring Well Field Parameters

Monitoring Well ID	Date Sampled	Sample Time	Water Level (ft BTOP)	pH	Temp. (deg. C)	Sp. Cond. (mS/cm)	ORP (mV)	DO (mg/l)	Notes	
B3-MW01	10/18/12	1105	248.3	10.07	21.32	0.985	44.3	2.99		
CS-D	1000	10/18/12	251.14	No	Samp 1					
CS-MW16-LGR	0900 ↗ 10/18/12		7.07	21.82	0.555	34.4	2.44			
CS-MW16-CC	0840 ↗ 10/18/12		7.21	22.00	0.678	-82.7	1.31			
CS-B3-EXW01	1000 ↗ 10/18/12		7.03	22.49	0.583	116.5	4.64			
CS-B3-EXW02	0940 ↗ 10/18/12		6.96	21.07	0.577	120.4	3.92			
CS-MW1-LGR	10.18.12 0900	21.93	6.90	21.39	0.520	135.3	3.91			

C-4 1020 10/18/12 241.06 7.25 21.02 0.550 134.1 4.31 Pump Depth 252.0  
VOCs only per Ken Rice

Week Quarter 21

Personnel: John

Trench Sumps Water Levels ('BTOC)

Personnel	J Bouch, E Rice					
Weekly Water Level Monitoring						
Well Interval	Sampling Port Depth (ft BTG)	Sample Date	Sample Time	Pressure at TOC (psi)	Pressure in MP (psi)	Zone Pressure (psi)
CS-WB05-LGR-01	99	1/16/13	1217	14.21	14.31	19.76
CS-WB05-LGR-02	182		1216		14.34	14.41
CS-WB05-LGR-03A	216		1215		14.38	14.51
CS-WB05-LGR-03B	262		1214		14.84	18.10
CS-WB05-LGR-04A	277		1213		21.39	28.19
CS-WB05-LGR-04B	329		1212		44.84	50.72
CS-WB05-BS-01	362		1211		50.34	64.46
CS-WB05-CC-01	432		1210		50.77	68.35
CS-WB05-CC-02	460	✓	1209		101.75	100.93
CS-WB06-UGR-01	20	✓	1136		14.39	17.85
CS-WB06-LGR-01	93		1135	14.26	14.31	16.62
CS-WB06-LGR-02	174		1134		14.36	23.90
CS-WB06-LGR-03A	207		1133		14.40	22.86
CS-WB06-LGR-03B	260		1132		25.77	45.74
CS-WB06-LGR-04	320	✓	1131		51.82	51.78
CS-WB07-UGR-01	14		1144		51.78	52.41
CS-WB07-LGR-01	90		1145		14.09	14.20
CS-WB07-LGR-02	175		1144		14.13	14.31
CS-WB07-LGR-03A	208		1143		14.17	14.33
CS-WB07-LGR-03B	257		1142		14.18	14.37
CS-WB07-LGR-04	318	✓	1141	14.25	14.21	14.41
CS-WB08-UGR-01	38	1/16/13	1119		24.24	24.30
CS-WB08-LGR-01	115		1118		14.08	14.30
CS-WB08-LGR-02	193		1117		14.13	14.35
CS-WB08-LGR-03A	228		1116		14.15	14.37
CS-WB08-LGR-03B	273		1115		14.18	14.40
CS-WB08-LGR-04	341	✓	1114		24.20	24.19
					53.77	53.75
						53.53

Personnel: Elliott, Bouc

## Trench Sumps Water Levels ('BT0C)

Date	Sump Depth (m BT0C)	Sump Water Level (m BT0C)	pH	Temp. (deg C)	SpCond (mS/cm)	ORP	DO (mg/L)	Trench Water Being Used (%)	Notes
B3-T1-1	12.9								
B3-T1-2	12.4								
B3-T1-3	12.85								
B3-T2-1	9.67								
B3-T2-2	10.01								
B3-T3-1	9.96								
B3-T3-2	7.4								
B3-T4-1	6.32								
B3-T5-1	9.33								
B3-T5-2	7.98								
B3-T6-1	11.45								
B3-T6-2	12.34								
B3-UIC									

## B-3 Transfer System Monitoring

Meter	Monday	Tuesday	Wednesday	Thursday	Friday
Date/Time:	4/13/13 0735	4/13/13 0735	4/10/13 1000	4/11/13 0730	4/12/13 0730
			Rate (gpm) / Cumulative Total (gal)		
CS-MW16-LGR	7.07	392,959	0	398,417	7.11
CS-MW16-CC	9.78	900,100	9.79	914,127	9.70
B3-EXW01	OFF		OFF	932,339	9.72
B3-EXW02	OFF		OFF	943,127	9.46
B3-EXW03	16.50	\$50,141	16.56	872,330	16.30
B3-EXW04	0	831,778	5.30	838,841	7.01
B3-EXW05	10.25	639,730	8.42	647,665	7.41
T-1	OFF			650,150	0
T-6	OFF			662,355	10.63
Meiter In:				663,500	6.71,117
Meter Out:	8	746,4043	58.19	758,5986	8.40
Tank Levels:	3600	3600	3700	3500	4000
Bag Filter	10	5	11	5	4
Pressure (In/Out):				10.5	5
Change Br:	150 $\mu$	75 $\mu$	150 $\mu$	75 $\mu$	150 $\mu$
Old MeiterOut:					
Notes					

## SWMU B-3 Tree Mulch Bioreactor

Personnel J. Bouch, S. Elliott, E. Rice					
Semi-Annual Quarterly Monitoring					
MPMWs	Sampling Port Depth (ft BTOC)	Sample Date	Sample Time	Inside Pressure	Zone Pressure
CS-WB05-LGR-01	99	4.8.13	1110	14.01	19.59
CS-WB05-LGR-02	182	4.8.13	1100	14.04	14.05
CS-WB05-LGR03A	216	4.8.13	1050	14.08	14.11
CS-WB05-LGR03B	262	4.8.13	1038	14.18	14.28
CS-WB05-LGR04A	277	4.8.13	0900	22.879	18.60
CS-WB05-LGR04B	329	4.9.13	1340	45.69	41.24
CS-WB05-BS-01	362	4.9.13	1220	60.16	55.47
CS-WB05-CC-01	432	4.9.13	1000	95.72	43.24
CS-WB05-CC-02	460	4.9.13	0900	102.97	75.56
A					ATM: 14.05
CS-WB06-UGR-01	20	4.9.13	1440	13.95	17.10
CS-WB06-LGR-01	93	4.9.13	1340	14.00	16.35
CS-WB06-LGR-02	174	4.9.13	1120	14.06	20.62
CS-WB06-LGR03A	207	4.9.13	1020	14.08	18.68
CS-WB06-LGR03B	260	4.9.13	0930	27.32	43.82
CS-WB06-LGR-04	320	4.9.13	1345	53.51	41.00
B					ATM: 13.96
CS-WB07-UGR-01	14	4.3.13	1415	14.13	15.18
CS-WB07-LGR-01	90	4.3.13	0921320	14.18	29.84
CS-WB07-LGR-02	175	4.3.13	0855	14.20	24.84
CS-WB07-LGR03A	208	4.3.13	0840	14.21	14.16
CS-WB07-LGR03B	257	4.2.13	0950	14.23	29.06
B					DRY ATM: 14.13
CS-WB07-LGR-04	318	4.2.13	0700	26.12	38.76
C					ATM: 14.11
CS-WB08-UGR-01	38	4.1.13	1427	14.07	18.81
CS-WB08-LGR-01	113	4.1.13	1325	14.13	19.24
CS-WB08-LGR-02	193	4.1.13	1105	14.24	19.59
CS-WB08-LGR03A	228	4.1.13	1055	14.23	14.18
CS-WB08-LGR03B	273	4.1.13	1020	25.90	14.23
A					DRY No Sample
CS-WB08-LGR-04	341	4.1.13	0920	55.61	41.53
					ATM: 14.13

→ checked twice with tables? - DRY

Personnel: J-Bouch S. Elliott

Weekly Piezometer Water Levels ('BTOC) and Monthly Field Parameters										
Piezometer ID	TD (ft BTOC)	Date Sampled	Weekly/Monthly Wtrlevls			Monthly Field Parameters				
			Sample Time	Water Level (ft BTOC)	pH	Temp (deg C)	SpCond (mS/cm)	ORP (mV)	DO (mg/L)	Notes
B	B3-MW26-UGR	20.32	4/12/13	09:15	13.87	6.77	19.45	0.709	172.9	0.61
C	B3-MW27-UGR	17.00	4/12/13	09:40	8.41	6.82	19.20	0.704	15.0	0.25
B	B3-MW28-UGR	18.33	4/12/13	D24	DRT					No Sampling
B	B3-MW29-UGR	20.40	4/12/13	10:00	20.62					No Sampling
C	B3-MW30-UGR	23.90	4/12/13	10:15	23.10	10.93	19.70	0.707	173.8	5.58
C	B3-MW31-UGR	39.06	4/12/13	10:40	34.81	6.61	21.95	0.815	58.2	No Flow in TDS bath
D	B3-MW32-UGR	58.45	4/12/13	11:00	40.24	7.12	21.83	0.426	12.2	0.09
D	B3-MW33-UGR	29.55	4/12/13	11:30	23.03	10.90	21.00	0.732	159.1	3.40
D	B3-MW34-UGR	25.40	4/12/13	11:50	18.10	10.93	21.14	0.717	30.5	2.04
Quarterly Monitoring Well Field Parameters										
Monitoring Well ID	Date Sampled	Sample Time	Water Level (ft BTOC)	pH	Temp (deg C)	SpCond (mS/cm)	ORP (mV)	DO (mg/L)	Notes	
B	B3-MW01	4/11/13	13:00	267.10	6.90	21.18	0.962	-39.1	1.09	
C	CS-D	4/11/13	—	259.50	Sandile					Jump @ 253
A	CS-MW16-LGR	4/11/13	10:45	272.9	7.16	21.20	0.560	71.3	2.73	Scidler DH
A	CS-MW16-CC	4/11/13	11:15	342.15	7.25	21.51	1.151	3.7	1.65	Scidler DH
C	CS-B3-EXW01									Wells off for repair - will get well when we can
C	CS-B3-EXW02									Wells off for repair - will get well when we can
C	CS-BS-EXW03	4/15/13	13:20	16.59	21.67	0.480	190.4	3.84		
C	CS-BS-EXW04	4/15/13	17:40	16.86	23.19	0.421	187.7	3.48		
C	CS-BS-EXW05	4/15/13	18:00	16.83	22.49	0.390	189.0	2.43		
C	CS-MW1-LGR	4/11/13	09:30	144.75	7.00	26.39	0.534	190.7	2.34	

Week \_\_\_\_\_

Personnel	J. Bench - E. Rice					
Weekly Water Level Monitoring						
Well Interval	Sampling Port Depth (ft BTG)	Sample Date	Sample Time	Pressure at TOC (psi)	Pressure in MP (psi)	Zone Pressure (psi)
CS-WB05-LGR-01	99	3.27.13	1133	14.28	14.10 14.35 14.15 14.39 14.17 14.41 15.66 14.83 22.22 21.37	19.45 14.37 14.35 14.40 21.37 18.70 41.20 55.59 63.74 76.04
CS-WB05-LGR-02	182		1132			
CS-WB05-LGR-03A	216		1131			
CS-WB05-LGR-03B	262		1130			
CS-WB05-LGR-04A	277		1128			
CS-WB05-LGR-04B	329		1126			
CS-WB05-BS-01	362		1124			
CS-WB05-CC-01	432		1122			
CS-WB05-CC-02	460		1120			
CS-WB06-UGR-01	20	3.27.13	1040			
CS-WB06-LGR-01	93		1039	14.25	14.10 14.30 14.14 14.33 14.15 14.37 14.19 14.41 25.77 25.72	17.05 14.58 20.53 20.89 43.80 40.71
CS-WB06-LGR-02	174		1038			
CS-WB06-LGR-03A	207		1037			
CS-WB06-LGR-03B	260		1036			
CS-WB06-LGR-04	320		1035			
CS-WB07-UGR-01	14	3.27.13	1100	14.26	14.09 14.30 14.13 14.31 14.17 14.39 14.16 14.41 14.21 24.24	15.28 29.42 24.87 14.03 14.42 24.41 (no) 24.03 (no) 29.23
CS-WB07-LGR-01	90		1059			
CS-WB07-LGR-02	175		1058			
CS-WB07-LGR-03A	208		1057			
CS-WB07-LGR-03B	257		1056			
CS-WB07-LGR-04	318		1055			
CS-WB08-UGR-01	38	3.27.13	1015	14.22	14.08 14.29 14.13 14.32 14.15 14.37 14.18 14.40 24.20 53.77	18.77 19.19 19.49 14.33 14.32 42.06
CS-WB08-LGR-01	115		1014			
CS-WB08-LGR-02	193		1013			
CS-WB08-LGR-03A	228		1012			
CS-WB08-LGR-03B	273		1011			
CS-WB08-LGR-04	341		1010			

Personnel: J. Bach; S. Elliott

### Trench Sumps Water Levels ('BTTOC)

Sump ID	Sump Depth (ft. BTTOC)	Stamp Water Level (ft. BTTOC)	pH	Temp (deg C)	SpCond (mS/cm)	ORP	DO (mg/L)	French Bottle Used (N)	Notes
Date: 4/15/13	Time: 0920								
B	B3-T1-1	12.9	6.02	21.88	1.014	-81	0.32		① 0933 V
B	B3-T1-2	12.4	5.94	21.90	1.002	-173.3	0.07		② 0150 did rot calcite
A	B3-T1-3	12.85	6.14	21.72	1.00	-80.5	0.07		③ 10.0
B	B3-T2-1	9.67	7.46	21.73	1.324	-123.7	0.21		
B	B3-T2-2	10.01	7.89	21.74	1.518	-128.0	0.03		
B	B3-T3-1	9.96	5.85	22.34	1.843	85.3	0.43		
B	B3-T3-2	7.4	Dry						
B	B3-T4-1	6.32	Dry						
B	B3-T5-1	9.33	8.09	22.17	1.044	140.2	1.14		
B	B3-T5-2	7.98	7.07						
A	B3-T6-1	11.45	7.71	22.30	0.850	57.8	2.52		④ 1045
A	B3-T6-2	12.34	7.50	21.98	0.412	17.6	0.32		⑤ 1110
A	B3-UIC			22.75	0.881	119.1	5.52		⑥ 1210

### B-3 Transfer System Monitoring

Meter	Monday	Tuesday	Wednesday	Thursday	Friday
Date/Time:	4/15/13 0800	4/16/13 0800	4/17/13 0800	4/18/13 0800	4/19/13 0800
CS-MW16-LGR	⑦ 439.454	⑧ 434.312	⑨ 443.894	⑩ 443.894	⑪ 443.894
CS-MW16-CC	⑫ 4.97	⑬ 9.99.225	⑭ 9.97	⑮ 10.3654	⑯ 9.98
B3-EXW01	Off	OFF	OFF	OFF	OFF
B3-EXW02					
B3-EXW03	17.45	100.1459	17.13	102.477	17.05
B3-EXW04	4.29	88.4440	6.10	89.1554	10.4
B3-EXW05	7.77	703.716	7.81	711.883	727.050
T-1	OFF				OFF
T-6					
Meter In:					
Meter Out:	33.43	786.0284	4.8.84	7922.742	21.17
Tank Levels:	5200	4500	4500	4500	4500
Bag Filter Pressure (In/Out):	5	5	5	5	5
Change BF	150 μ	75 μ	150 μ	75 μ	150 μ
Notes					75 μ