

Technical Memorandum

To: Gabe Moreno, CSSA
From: Parsons Staff
CC: Chris Beal, Julie Burdey, Scott Pearson, file (747145.03000)
Date: October 26, 2010

Re: Construction Summary for SWMU B-3 Extraction Well 02 (B3-EXW02) and Shallow Monitoring Wells (B3-MW26 through B3-MW34)

This Technical Memorandum summarizes construction information for nine shallow monitoring wells (B3-MW26 through B3-MW34) and one groundwater extraction well (B3-EXW02) for incorporation into the Solid Waste Management Unit (SWMU) B-3 Bioreactor system in Camp Stanley Storage Activity (CSSA), Boerne, Texas.

INTRODUCTION

Parsons received a proposal to construct a groundwater extraction well and eight shallow monitoring wells under U.S. Army Corps of Engineers - Fort Worth District, Contract W9126G-07-D-0028, delivery order 0050 (DO50), Task 3, as part of the CSSA SWMU B-3 Bioreactor Treatability Study. A ninth monitoring well was constructed under separate agreement by CSSA during a technology demonstration, and is also described herein. Services were performed in accordance with Texas Commission on Environmental Quality (TCEQ) Rules and Regulations, and the Texas Department of Licensing and Regulation (TDLR) standards.

PROJECT BACKGROUND AND OBJECTIVES

Between December 2009 and August 2010, Parsons constructed 9 groundwater monitoring wells and one groundwater extraction well around the immediate vicinity of SWMU B-3 at CSSA (Figure 1) under scoped DO50 project tasks. The wells were drilled by a licensed well service contractor, GeoProjects International (GPI) of Austin, Texas. Well construction and surface completions meet or exceed local and state regulatory requirements.

Nine shallow groundwater monitoring wells are located at various intervals around the outside perimeter of the SWMU B-3 site, and monitor groundwater present in the Upper Glen Rose (UGR) limestone. The purpose of the new wells is to provide data for a refined understanding of local groundwater occurrence and movement, additional characterization of subsurface contamination related to past and present activities at SWMU B-3, and for other general monitoring of the ongoing bioreactor pilot study.

The groundwater extraction well is located adjacent to SWMU O-1 for purposes of monitoring select groundwater parameters and water levels, and to provide groundwater to the SWMU B-3 Bioreactor treatability study system. The well produces groundwater from the Lower Glen Rose formation (LGR) of the Middle Trinity Aquifer. Under normal conditions, this well can supplement and enhance current water demands of the treatment system presently provided by wells MW16-LGR, MW16-CC, and B3-EXW01.

Before commencement of well drilling, GPI and Parsons assisted Noblis, Inc. personnel in the collection of 4 shallow bedrock samples (Figure 1). The samples were collected on April 27, 2010 by air rotary coring through hollow stem augers. One sample was taken from the floor of SWMU B-3 Trench 2, two from under Trench 1, and one background sample core from an upgradient location approximately 110 feet northwest of CS-B3-WB08.

SHALLOW MONITORING WELL CONSTRUCTION

Nine new monitoring wells were installed in the bioreactor vicinity under DO50 (Figure 1). The first well (B3-MW27) was installed on December 1, 2010 by Boart-Longyear as part of a Roto-Sonic technology demonstration for CSSA. Drilling of the remaining wells (B3-MW26 and B3-MW28 through B3-MW34) was performed by GPI under direct supervision of Parsons geologists. The wells were drilled to the base of the UGR in the Upper Trinity aquifer. The drilling of these shallow UGR monitoring wells complements the existing SWMU B-3 monitoring well network.

Drilling locations were chosen based on information from previous investigations as included in well installation reports and the CSSA Hydrogeologic Conceptual Site Model (HCSM), as well as new data generated through recent SWMU B-3 Treatability Study activities. The CSSA Environmental Office approved the drilling locations after review of Parsons' recommendations. Topography and drill rig accessibility were factors also considered for location selection. GPI mobilized to the CSSA UGR drilling site on April 27, 2010.

Typical monitor well design (Figure 2) and construction followed CSSA specifications and met TCEQ requirements. GPI drilled the shallow wells to a nominal diameter of 8 inches. Non-chlorinated water used for fluid injection during drilling was obtained from CSSA water supply well CS-12. Final drilling footage was a function of each well's location, land surface elevation, and depth to UGR-LGR contact based on correlation of area geophysical logs and from direct observations of cuttings. Geophysical logs from previously drilled wells were used to estimate local UGR/LGR contact depths and total depths of each new well. Plastic sheeting was laid around each wellhead to contain extruded subsurface materials. Boreholes were cleaned by air-lifting and surging when feasible (not all wells contained sufficient water for proper surging).

Construction materials for each well included nominal 4-inch Schedule 40 PVC with flush-threaded joints. The factory-slotted PVC well screens are constructed with a slot size of 0.050-inches (50-slot). Wells deeper than 20 feet had centralizers attached to the screen and riser. Other wells have one centralizer near the base of the screen. The annular space was filled with a 4/10-mesh filter pack from the base of the borehole to 1 to 2 feet above the top of the screened interval, depending on location. Dehydrated bentonite pellets were added to create a sealed plug above the sand. These uncoated pellets were added by hand to prevent bridging in the upper portions of the well. The bentonite pellets were hydrated per manufacturer's recommendations before proceeding with grouting of the annular space above.

In the deeper wells (MW31-UGR and MW32-UGR), the annular space was pressure-grouted with a Volclay/bentonite grout mixture by the positive displacement exterior method from the bottom of the hole to 2 feet below ground surface (bgs). In the remaining shallower wells, grouting consisted only of extending the bentonite seal up to 2 feet bgs, as this proved much more economical and efficient as opposed to mixing and applying grout to annuli less than 7 feet deep, and is an acceptable method as administered by the TDLR. The remaining 2 feet were filled with cement during well pad construction to satisfy the TDLR atmospheric barrier requirement. A monitoring well construction summary is shown in Table 1.

After materials installation the MWs were then developed by bailing when sufficient water was present. After each borehole was drilled, the drilling rig was decontaminated and washed. No geophysical logging was undertaken for the new UGR wells. All fluid and solid IDW were managed according to CSSA RCRA Facility Investigation and Interim Measures Waste Management Plan (Volume 1-1, Encyclopedia) approved by USEPA and TCEQ.

The monitoring wells were completed with risers extending approximately 3 feet above ground surface in a 4-foot square concrete pad. A 2-inch diameter brass marker stamped with the well's official identification was set into each concrete pad as a permanent benchmark. A 4-inch square, steel, locking well protector was installed over the PVC riser at each wellhead. Each cover is secured by a CSSA-supplied, corrosion-resistant steel lock. Protective bollards were also emplaced in concrete at each well. Covers and bollards were painted with two coats of OSHA safety-yellow. Surface completions meet CSSA, TDLR, and general industry specifications.

Wells were developed by bailing and pumping where sufficient water was present (Table 1). New wells on the north side of SWMU B-3 (B3-MW26, B3-MW32, B3-MW33, B3-MW34) generated much more water than wells toward the south. In addition to the volume developed from B3-MW26, approximately 1500 gallons was generated during drilling and installation. In contrast, B-3-MW28 remained dry and could not be developed. Very limited quantities of turbid water were bailed B3-MW29, B3-MW30, and B3-MW31. These wells will be subjected to additional bailing and purging prior to sampling as conditions permit.

Table 1

DO-50 B3 UGR Monitoring Wells Construction Summary Camp Stanley Storage Activity April-May 2010

		SWM	U B-3 We	ells Cons	truction S	ummary			
	Eleva	ations	Total	Top PVC	Finished	0	De	velopm	ent
Well ID	Natural Ground	Topof PVC riser	Drilled Depth	above ground	Depth TOC to Bottom	Screened Interval	Bailer	Pump	Total
	(feet MSL)	(feet MSL)	(feet bgs)	(feet)	(feet)	(feet)		(gallons)	
MW26-UGR	1,235.53	1,238.49	17.5	2.96	20.5	10 (17.5-7.5)	600	160	760
MW27-UGR	1,230.62	1,233.42	17.0	2.80	19.8	10 (17.0-7.0)	0	0	0
MW28-UGR	1,223.94	1,226.67	15.5	2.73	18.2	10 (15.5-5.5)	d	ry	0
MW29-UGR	1,230.38	1,233.25	17.5	2.87	20.4	10 (17.5-7.5)	0.5	0	0.5
MW30-UGR	1,242.83	1,246.01	20.8	3.18	24.0	10 (20.8-10.8)	2	0	2
MW31-UGR	1,254.52	1,257.20	36.0	2.68	38.7	20 (36.0-16.0)	2.6	0	2.6
MW32-UGR	1,264.00	1,266.98	56.0	2.98	59.0	30 (56.0-26.0)	540	230	770
MW33-UGR	1,247.17	1,249.55	26.0	2.38	28.4	20 (26.0-6.0)	365	105	470
MW34-UGR	1,241.51	1,244.51	22.0	3.00	25.0	10 (22.0-12.0)	825	105	930
B3-EXW02	1,246.42	1,249.55	358	3.13	361.1	casing 0-65 open 65-358	0	8,260	8,260

bgs = below ground surface MSL = Mean Sea Level TOC = top of PVC casing

Shallow UGR monitoring well sampling methods and results will be addressed in subsequent Bioreactor quarterly reports.

Well B3-MW27 was completed in December 2009 by Boart-Longyear using sonic drilling methods as part of a demonstration effort. The well contains 2-inch PVC screen and riser in a 6-inch diameter borehole, all other construction methods

and specifications equal those of the other 8 shallow wells. B3-MW27 will undergo extra bailing and purging prior to first sampling event. Surveys of all the new SWMU B-3 wells were completed by a State of Texas registered land surveyor in July 2010. State of Texas Well Reports and land surveying data are included in Attachment 1.

EXTRACTION WELL CONSTRUCTION

This second SWMU B-3 groundwater extraction well (B3-EXW02) was constructed approximately 625 feet south of SWMU B-3, on the east edge of SWMU O-1 (O-1 soil unit approved for closure in 2002). The drilling subcontractor (GPI) mobilized to the new extraction well site on May 18, 2010. A containment area consisting of 2 feet by 10 feet wood planks and heavy gauge plastic sheeting was first constructed to surround the wellhead and the drilling table to capture drilling fluids and solid cuttings. Non-chlorinated water used for fluid injection during drilling was obtained from CSSA water supply well CS-12.

B3-EXW02 was first drilled at 6¼-inch diameter to 358.3 feet bgs, penetrating approximately 27 feet of basal UGR Limestone and advancing to 13 feet below the LGR - Bexar Shale (BS) formational contact. Total depth of the pilot hole was achieved on May 28, 2010. A "TOTCO" single shot declination tool was used during drilling after every 50 feet of borehole advancement to check borehole plumbness. Borehole declination may not deviate more than 2 degrees from true vertical as per specifications. All TOTCO shots during this field effort were within specifications (Attachment 2). The borehole was cleaned by surging and air-lifting. At this time, the driller could not estimate well yield due to significant loss of returns, presumably through voids in the upper subsurface.

Drilling was paused overnight at 38 feet bgs and a groundwater sample was retrieved by bailer in order to get a general characterization of shallow inflow. Before reaming, a second bailer sample was collected from 30 feet below static level, at approximately 110 feet bgs to provide general characterization of the well water based on Bioreactor requirements. Significance of the initial B3-EXW02 water sample results will be addressed in subsequent Bioreactor quarterly reports. Laboratory analysis volatile organic compound (VOC) detections are summarized below in Table 2, and the complete results are included in Attachment 3. The samples were analyzed for full list VOCs and 10 metals (As, Ba, Cd, Cr, Cu, Hg, Mn, Ni, Pb, and Zn). No metals concentration exceeded Primary Drinking Water Standards. Arsenic and lead were not detected in the first sample, and J-flagged (concentration >MDL but <PQL) in the second, while cadmium and mercury were not detected in either sample.

Geophysical and camera logging surveys were conducted (Attachment 2) upon completion of the 6-inch pilot hole. No extraordinary geologic features (e.g., large fractures or faults) were observed. Loss of returns was presumed to be due to openings seen at 38 feet bgs. Groundwater was first seen entering the

Table 2
Results of B3-EXW02 Groundwater Sampling during Drilling
(ppb)

Volatile Organic Compound	B3-EXW02 (38' bgs)	B3-EXW02 (110' bgs)
	May 19, 2010	June 2, 2010
PCE	15	12
TCE	3.8	5.8
cis-1,2-DCE	12	10

borehole at 21.8 feet bgs. This infiltration appeared to be about 2 to 4 gallons per minute (gpm). Selection of casing depth was determined based on the geologic logs.

After logging, the borehole was reamed at 12¼ inches diameter to a depth of 65.1 feet bgs. Drilling fluids were discharged into adjacent rolloff containment. Then after settling to remove suspended solids, fluids were transported for management at SWMU B-3 Trench 1 after being pumped through a bag filter unit to further reduce turbidity.

In order to maximize yield and promote closed-loop circulation between the bioreactor and the aquifer, 8-inch diameter Certa-lok[™] schedule 40 PVC surface casing was installed to 65 feet. Two shale traps were affixed to the terminus of the surface casing and covered by a 5-foot seal of bentonite to assist the grouting of the casing. The surface casing closed off potentially unstable wall sections and several perched water-bearing zones. Beginning with 120-gallon lifts, a Volclay grout mixture was slowly pumped into the annular space using a side-discharge tremie pipe. The grout was allowed to cure more than 48 hours before further borehole reaming occurred. The hole was then reamed to nominal 8-inch diameter to total depth. The well completion is diagrammed in Figure 3.

All investigation-derived media, including soil cuttings, drilling fluids, and purged groundwater was managed within the confines of SWMU B-3. All fluid and solid IDW was disposed according to CSSA RCRA Facility Investigation and Interim Measures Waste Management Plan (Volume 1-1, Encyclopedia) approved by USEPA and TCEQ.

On June 17, 2010, GPI set a new 4-inch diameter, 5-hp submersible pump (Grundfos model 40S50-15) on 2-inch galvanized steel column pipe at 333 feet bgs in the newly constructed well. The pump operates using a 5 hp, 200 volt, 3-phase Franklin Electric electrical motor. Manufacturer information and specifications are included in Attachment 4. The pump size was determined by analyzing water level data and aquifer characteristics derived from pumping tests conducted in previous years at SWMU B-3 wells. The potential dynamic head calculated for the system was also based on this information. The system has been designed to provide between 5 and 40 gpm to the bioreactor water supply

tank. Two check valves are included in the well piping, one above the pump, and one between the eighth and ninth pipe joint at approximately 162 feet bgs. The wellhead is equipped with a brass sample spigot, pressure gauge and vacuum breaker, a 2-inch by-pass connection, and flow control/isolation valves installed by GPI. No additional water quality samples were collected at this time, and the well was not chlorinated.

On June 17, 2010 a short pumping test was conducted after pump installation. The well maintained a generally steady rate and pumping water level of 31 gpm and 232.8 feet bgs, respectively, for 2.5 hours, after an initial drawdown of 121.2 feet. The pumping rate was then increased and maintained at 35 gpm for the final 43 minutes of the test, resulting in an additional 22.7 feet of drawdown. During the last 10 minutes of this step, the pumping water level trend began to flatten at an average depth of 256.1 feet bgs.

USA Environment, L.P. (USA) of New Braunfels, Texas continued the plumbing installation where GPI's scope ended, installing 1.5-inch galvanized piping from the wellhead, a flanged flowmeter, and a connection to 2-inch HDPE pipe. The HDPE piping was laid by USA from the wellhead system to a connection in existing supply pipe at B3-EXW01, located in the southeast quadrant of the bioreactor between Trenches 5 and 6. The B3-EXW02 HDPE piping runs mostly above-grade except where buried under two unpaved tracks. At the Bioreactor tank (Figure 1) the HDPE conveyance is converted to 2-inch rigid PVC and connects to a galvanized manifold. The manifold directs groundwater from the MW16-LGR/CC wells and the two extraction wells into the Bioreactor tank.

The extraction well surface completion consists of a 12'x10'x6" square concrete pad. The pad, control panel stanchion, and electrical connections were constructed in August 2010 by Joe Sanchez Contracting, Inc. (JSCI) of San Antonio, Texas, as a tiered subcontractor to USA. Subgrade conduit was constructed beneath the pad to accommodate well pump motor leads and control wiring (Figure 4). The State of Texas Well Report and land surveying data are included in Attachment 1.

Electrical Installation

The supply well electrical controls and metering is protected by a steel stanchion structure built by JSCI. The structure holds the electrical controls and SCADA equipment. It is bolted at each end to the concrete pad. The CSSA electrical distribution system was extended to the well location. JSCI extended the existing CSSA electrical system from an existing pole-mounted transformer on the east side of SWMU O-1 underground around the north side of the SWMU O-1 cap, providing 120/208V, 3-phase power to the extraction well. The existing utility pole structure was already equipped with an electrical distribution panel. The service entrance conductors are routed 2 feet underground from the utility pole to the well pad stanchion in 2-inch diameter Schedule 80 PVC conduit. Electrical system tasks were completed in conformance with NFPA 70. Figure 1 shows the location of the existing electrical utility pole and the buried extension to the new

extraction well and controls structure.

The stanchion panel was equipped with a 100-amp, 4-wire service panel. The service panel includes a main breaker for disabling all the wellhead circuits. The subcontractor wired the service panel to 208V, three phase power, and included a triple-pole breaker for operating a 60-amp/200-volt motor and single-pole breakers for the 20-amp/120-volt Remote Telemetry Unit (RTU) panel (installed by System Controls and Instrumentation, Inc. [SCI]), and a 15-amp/120-volt GFI utility outlet.

Equipment Installation

To assist in the operation of the well, a SymCom Model 777 KW/HP PumpSaver[®] (Attachment 4) was installed by GPI in the motor control panel during pump installation. The PumpSaver module protects the submersible pump from adverse electrical conditions such as under/over voltage and/or current, as well as protection against running the pump dry. In its current configuration, well B3-EXW02 can be pumped manually or automatically to the Bioreactor storage tank for distribution to the trenches.

The well was fully incorporated into the SWMU B-3 automation system by SCI in October 2010. The well is equipped with an Endress+Hauser (E+H) FMX167 WaterPilot transducer to report the water level in the well to the SCADA system. A spare (E+H) Prowirl 72F flowmeter is also in place (installed by USA) on the discharge piping to measure and digitally record the flowrate and total discharge from the well (Figure 4). Both instruments have 4-20 milliamp (mA) output to provide the SCADA system operation with accurate water level and discharge measurements. These instruments (Attachment 4) are connected to the RTU that transmits this information and receives operational pumping commands via wireless 900 MHz radio from the GAC Shack RTU, where the Bioreactor automation is centralized. The operators also manually monitor the amount of groundwater produced from the well as part of their routine Bioreactor Operation and Maintenance (O&M).

The actuation of the well is based upon the demand of the 5000-gallon storage tank at the north end of the Bioreactor. As the tank empties water into the Bioreactor trenches, it wirelessly calls upon all the extraction wells to convey water until the tank if filled. More information regarding the operation of the extraction wells can be found in the *"B-3 Bioreactor Operations & Maintenance Manual"* in <u>Treatment Technologies and Treatability Studies</u> (Volume 4) of the CSSA Environmental Encyclopedia.

FIGURES

- FIGURE 1: Well Location Map
- FIGURE 2: Typical B-3 Monitoring Well Construction Design
- FIGURE 3: B3-EXW02 General Well Construction Design
- FIGURE 4: B3-EXW02 Surface Completion, Stanchion, and Controls As Built




Figure 2

SWMU B-3 Typical Monitoring Well Completion Camp Stanley Storage Activity






Figure 3



SWMU B-3 Groundwater Extraction Well B3-EXW02 General Construction Design Camp Stanley Storage Activity - Boerne, TX



ATTACHMENT 1

State of Texas Well Reports Survey Data

STATE WELL REPORTS

CS-MW26-UGR CS-MW27-UGR CS-MW28-UGR CS-MW29-UGR CS-MW30-UGR CS-MW31-UGR CS-MW32-UGR CS-MW33-UGR CS-MW34-UGR CS-B3-EXW02

Owner:	U.S. Government	Owner Well #:	B3-MW26-UGI
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 37" N
Well County:	Bexar	Longitude:	098° 36' 55" W
Elevation:	1235 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/4/2010 Completed: 5/4/2010		
Diameter of Hole	E: Diameter: 8 in From Surface To	17.4 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed Fro Gravel Pack Size: 6/9	om: 7 ft to 17.4 ft	
	2nd Interval: From 2 ft to 6 ft wit 3rd Interval: No Data Method Used: Poured from Surf Cemented By: Jose Landeros a	nd Evan Schaefer Concentrated Contamination: No Da	
Surface Completion:	Surface Slab Installed		
Water Level:	Static level: No Data Artesian flow: No Data		
	No Data		
Packers:	Casing or Cement/Bentonite left i	in well [.] No Data	
Packers: Plugging Info:	Casing of Cement/Demonite left		
	No Data		
Plugging Info:	-		
Plugging Info: Type Of Pump:	No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No	e any strata which contained undesir	able constituents
Plugging Info: Type Of Pump: Well Tests:	No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrate a: The driller certified that the driller supervision) and that each and al		ed under the drille nd correct. The d

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233151) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description **0 to 17.4 Upper Glen Rose Formation Limestone** Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 7 4 New SCH 40 PVC Screen set from 7 to 17.4 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	MW-27
Address:	25800 Ralph Fair Road	Grid #:	68-20-1
	Boerne, TX 78015		
Well Location:	Camp Stanley Storage Activity Boerne , TX 78015	Latitude:	29° 42' 33" N
Well County:	Bexar	Longitude:	098° 36' 54"
Elevation:	No Data	GPS Brand Used:	No Data
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 12/1/2009 Completed: 12/1/2009		
Diameter of Hole	e: Diameter: 6 in From Surface To 4	7 ft	
Drilling Method:	Other: Sonic		
Borehole Completion:	Gravel Packed From: 17 ft to 5 ft Gravel Pack Size: 10-20		
Annular Seal Da	ata: 1st Interval: From 47 ft to 17 ft wit 2nd Interval: From 17 ft to 5 ft with 3rd Interval: From 5 ft to 3 ft with 1 Method Used: poured from surfac Cemented By: Self Distance to Septic Field or other Co Distance to Property Line: No Data Method of Verification: No Data Approved by Variance: No Data	h 10-20 Sand (#sacks and materia Bentonite (#sacks and material) ce oncentrated Contamination: No Date	al)
Surface Completion:	Surface Slab Installed		
Water Level:	Static level: No Data Artesian flow: No Data		
Packers:	No Data		
Plugging Info:	Casing or Cement/Bentonite left in	well: No Data	
Type Of Pump:	No Data		
Well Tests:	No Data		
Water Quality:	Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Data Did the driller knowingly penetrate a	any strata which contained undesir	able constituent:
Certification Dat	a: The driller certified that the driller dr supervision) and that each and all c understood that failure to complete completion and resubmittal.	of the statements herein are true ar	nd correct. The o

	Peoria , AZ 85345
Driller License Number:	58094
Licensed Well Driller Signature:	Fred Hafner
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #210185) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

From (ft) To (ft) Description 0'-4' Brown silty clay 4'-6' Reddish silty clay 6'-8' yellow/brown caliche 8'-9' gypsum 9'-16' yellow/white limestone 16'-47 blue/gray clayey shale

CASING, BLANK PIPE & WELL SCREEN DATA

Dia. New/Used Type Setting From/To 2" New Plastic 17'-7 .010 Screen 2" New Plastic 7'-surface Riser

Owner:	U.S. Government	Owner Well #:	B3-MW28-UG
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road	Latitude:	29° 42' 31" N
	Boerne , TX 78015		
Well County:	Bexar	Longitude:	098° 36' 56" V
Elevation:	1223 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/4/2010 Completed: 5/4/2010		
Diameter of Hole	Diameter: 8 in From Surface To 15	5.5 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed From Gravel Pack Size: 6/9	: 4 ft to 15.5 ft	
	ta: 1st Interval: From 0 ft to 2 ft with 1 2nd Interval: From 2 ft to 4 ft with 3rd Interval: No Data Method Used: Poured from Surfac Cemented By: Jose Landeros and Distance to Septic Field or other Cc Distance to Property Line: No Data Method of Verification: No Data Approved by Variance: No Data	2-Bentonite (#sacks and materia ce I Evan Schaefer oncentrated Contamination: No Da	
Surface Completion:	Surface Slab Installed		
Water Level:	Static level: No Data Artesian flow: No Data		
	No Data		
Packers:			
Packers: Plugging Info:	Casing or Cement/Bentonite left in	well: No Data	
	Casing or Cement/Bentonite left in No Data	well: No Data	
Plugging Info:		well: No Data	
Plugging Info: Type Of Pump:	No Data		able constituents
Plugging Info: Type Of Pump: Well Tests:	No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrate a	any strata which contained undesir rilled this well (or the well was drille of the statements herein are true ar	ed under the drille nd correct. The d

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233157) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description **0 to 15.5 Upper Glen Rose Formation Limestone** Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 5 4 New SCH 40 PVC Screen set from 5 to 15.5 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW29-UG
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 31" N
Well County:	Bexar	Longitude:	098° 36' 56" V
Elevation:	1230 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/3/2010 Completed: 5/3/2010		
Diameter of Hol	le: Diameter: 8 in From Surface	e To 17.5 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed Gravel Pack Size: 6/9	l From: 6 ft to 17.5 ft	
	2nd Interval: From 2 ft to 6 ft 3rd Interval: No Data Method Used: Poured from 3 Cemented By: Jose Landerc	os and Evan Schaefer ther Concentrated Contamination: No E o Data ata	rial)
Surface Completion:	Surface Slab Installed		
	Surface Slab Installed Static level: No Data Artesian flow: No Data		
Completion:	Static level: No Data		
Completion:	Static level: No Data Artesian flow: No Data	left in well: No Data	
Completion: Water Level: Packers:	Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite	left in well: No Data	
Completion: Water Level: Packers: Plugging Info:	Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite	left in well: No Data	
Completion: Water Level: Packers: Plugging Info: Type Of Pump:	Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No		sirable constituents
Completion: Water Level: Packers: Plugging Info: Type Of Pump: Well Tests:	Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly pene ta: The driller certified that the dr supervision) and that each ar		lled under the drille and correct. The d

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233159) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description 0 to 17.5 Upper Glen Rose Formation Limestone Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 7 4 New SCH 40 PVC Screen set from 7 to 17.5 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW30-UG
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-4
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 28" N
Well County:	Bexar	Longitude:	098° 36' 49" W
Elevation:	1243 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 4/30/2010 Completed: 4/30/2010		
Diameter of Hol	e: Diameter: 8 in From Surface T	o 20.3 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed F Gravel Pack Size: 6/9	rom: 9.2 ft to 20.3 ft	
	3rd Interval: No Data Method Used: Poured from Su Cemented By: Jose Landeros	and Evan Schaefer er Concentrated Contamination: No Da Data	
- ·	Surface Slab Installed		
Surface Completion:			
	Static level: No Data Artesian flow: No Data		
Completion:			
Completion:	Artesian flow: No Data	ft in well: No Data	
Completion: Water Level: Packers:	Artesian flow: No Data No Data	ft in well: No Data	
Completion: Water Level: Packers: Plugging Info:	Artesian flow: No Data No Data Casing or Cement/Bentonite lef	ft in well: No Data	
Completion: Water Level: Packers: Plugging Info: Type Of Pump:	Artesian flow: No Data No Data Casing or Cement/Bentonite lef No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No	ft in well: No Data ate any strata which contained undes	irable constituents
Completion: Water Level: Packers: Plugging Info: Type Of Pump: Well Tests:	Artesian flow: No Data No Data Casing or Cement/Bentonite lef No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetra ta: The driller certified that the drille supervision) and that each and		led under the drille and correct. The d

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233160) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description 0 to 20.3 Upper Glen Rose Formation Limestone Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 10.3 4 New SCH 40 PVC Screen set from 10.3 to 20.3 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW31-UGF
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 33" N
Well County:	Bexar	Longitude:	098° 36' 49" W
Elevation:	1255 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 4/30/2010 Completed: 4/30/2010		
Diameter of Hole	le: Diameter: 8 in From Surface To	o 36 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed Fro Gravel Pack Size: 6/9	om: 14.5 ft to 36 ft	
	2nd Interval: From 2 ft to 14.5 ft 3rd Interval: No Data Method Used: Poured from Sur Cemented By: Jose Landeros a Distance to Septic Field or other Distance to Property Line: No Da	and Evan Schaefer Concentrated Contamination: No Da	
	Method of Verification: No Data Approved by Variance: No Data		
Surface Completion:			
Completion:	Approved by Variance: No Data		
	Approved by Variance: No Data Surface Slab Installed Static level: No Data		
Completion: Water Level:	Approved by Variance: No Data Surface Slab Installed Static level: No Data Artesian flow: No Data	in well: No Data	
Completion: Water Level: Packers:	Approved by Variance: No Data Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite left	in well: No Data	
Completion: Water Level: Packers: Plugging Info:	Approved by Variance: No Data Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite left	in well: No Data	
Completion: Water Level: Packers: Plugging Info: Type Of Pump:	Approved by Variance: No Data Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite left No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No	in well: No Data te any strata which contained undesi	rable constituents:
Completion: Water Level: Packers: Plugging Info: Type Of Pump: Well Tests:	Approved by Variance: No Data Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite left No Data No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrat ta: The driller certified that the driller supervision) and that each and a		ed under the driller nd correct. The dri

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233162) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description 0 to 36 Upper Glen Rose Formation Limestone Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 16 4 New SCH 40 PVC Screen set from 16 to 36 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW32-UGF
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 36" N
Well County:	Bexar	Longitude:	098° 36' 46" W
Elevation:	1264 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 4/28/2010 Completed: 4/29/2010		
Diameter of Hole	e: Diameter: 8 in From Surface To 5	56 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed Fron Gravel Pack Size: 6/9	n: 24.2 ft to 55.7 ft	
	3rd Interval: No Data Method Used: Poured from Surfa Cemented By: Jose Landeros an	d Evan Schaefer Concentrated Contamination: No Da	
Surface Completion:	Surface Slab Installed		
	Static level: No Data Artesian flow: No Data		
Water Level:			
Water Level: Packers:	No Data		
	No Data Casing or Cement/Bentonite left in	n well: No Data	
Packers:		n well: No Data	
Packers: Plugging Info:	Casing or Cement/Bentonite left in	n well: No Data	
Packers: Plugging Info: Type Of Pump:	Casing or Cement/Bentonite left in No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No	n well: No Data	able constituents:
Packers: Plugging Info: Type Of Pump: Well Tests:	Casing or Cement/Bentonite left in No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrate a: The driller certified that the driller of supervision) and that each and all		ed under the driller nd correct. The dri

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233164) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description 0 to 56 Upper Glen Rose Formation Limestone Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 25.7 4 New SCH 40 PVC Screen set from 25.7 to 55.7 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW33-UGR
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road	Latitude:	29° 42' 38" N
	Boerne , TX 78015	L en eitude.	000° 201 40" W
Well County:	Bexar	Longitude:	098° 36' 48" W
Elevation:	1247 ft.	GPS Brand Used:	Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/5/2010 Completed: 5/5/2010		
Diameter of Hole	e: Diameter: 8 in From Surface To	26.5 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packed From Gravel Pack Size: 6/9	m: 5 ft to 26.5 ft	
	2nd Interval: From 2 ft to 5 ft wit 3rd Interval: No Data Method Used: Poured from Surfa Cemented By: Jose Landeros ar	nd Evan Schaefer Concentrated Contamination: No Da	
Surface Completion:	Surface Slab Installed		
Water Level:	Static level: No Data Artesian flow: No Data		
	No Data		
Packers:	Casing or Cement/Bentonite left in	n well: No Data	
Packers: Plugging Info:			
	No Data		
Plugging Info:	No Data No Data		
Plugging Info: Type Of Pump:	No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No	e any strata which contained undesir	able constituents:
Plugging Info: Type Of Pump: Well Tests:	No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrate a: The driller certified that the driller supervision) and that each and al	e any strata which contained undesir drilled this well (or the well was drille I of the statements herein are true a te the required items will result in the	ed under the driller nd correct. The dri

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233165) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description **0 to 26.5 Upper Glen Rose Formation Limestone** Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 16 4 New SCH 40 PVC Screen set from 16 to 26.4 with 0.050-inch mill slot

Owner:	U.S. Government	Owner Well #:	B3-MW34-UG
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-1
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 38" N
Well County:	Bexar	Longitude:	098° 36' 50" V
Elevation:	1242 ft.	GPS Brand Use	ed: Professional
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/4/2010 Completed: 5/4/2010		
Diameter of Hol	le: Diameter: 8 in From Surfac	ce To 22.4 ft	
Drilling Method:	Air Rotary		
Borehole Completion:	Straight Wall Gravel Packe Gravel Pack Size: 6/9	ed From: 11 ft to 22.4 ft	
	3rd Interval: No Data Method Used: Poured from Cemented By: Jose Lande Distance to Septic Field or o Distance to Property Line: N Method of Verification: No D	ros and Evan Schaefer other Concentrated Contamination: No No Data Data	
	Approved by Variance: No I	Data	
Surface Completion:	Surface Slab Installed	Data	
		Data	
Completion:	Surface Slab Installed Static level: No Data	Data	
Completion:	Surface Slab Installed Static level: No Data Artesian flow: No Data		
Completion: Water Level: Packers:	Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite		
Completion: Water Level: Packers: Plugging Info:	Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite		
Completion: Water Level: Packers: Plugging Info: Type Of Pump:	Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: N	e left in well: No Data	desirable constituents
Completion: Water Level: Packers: Plugging Info: Type Of Pump: Well Tests:	Surface Slab Installed Static level: No Data Artesian flow: No Data No Data Casing or Cement/Bentonite No Data No Data Type of Water: No Data Depth of Strata: No Data Chemical Analysis Made: N Did the driller knowingly per ta: The driller certified that the of supervision) and that each a	e left in well: No Data Io netrate any strata which contained un driller drilled this well (or the well was and all of the statements herein are tr omplete the required items will result i	drilled under the drille ue and correct. The d

	Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	No Data
Apprentice Registration Number:	No Data
Comments:	No Data

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #233166) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

CASING, BLANK PIPE & WELL SCREEN DATA

From (ft) To (ft) Description **0 to 22.4 Upper Glen Rose Formation Limestone** Dia. New/Used Type Setting From/To 4 New SCH 40 PVC Casing set from +2.5 to 12 4 New SCH 40 PVC Screen set from 12 to 22.4 with 0.050-inch mill slot

STATE WELL REPORT

CS-B3-EXW02

Owner:	U.S. Government	Owner Well #:	B3-EXW02
Address:	25800 Ralph Fair Road Boerne , TX 78015	Grid #:	68-20-4
Well Location:	25800 Ralph Fair Road Boerne , TX 78015	Latitude:	29° 42' 27" N
Well County:	Bexar	Longitude:	098° 36' 48"
Elevation:	1246 ft.	GPS Brand Used:	Garmin
Type of Work:	New Well	Proposed Use:	Monitor
Drilling Date:	Started: 5/19/2010 Completed: 6/9/2010		
Diameter of Ho	e: Diameter: 12.25 in From Surface Diameter: 7 7/8 in From 65.1 ft To		
Drilling Method:	Air Rotary		
Borehole Completion:	Open Hole		
	2nd Interval: From 2 ft to 65.1 ft v 3rd Interval: No Data Method Used: Tremie Quick Grou Cemented By: Jose Landeros an	d Evan Schaefer Concentrated Contamination: No Da	
Surface Completion:	Surface Sleeve Installed		
Water Level:	Static level: No Data Artesian flow: No Data		
Packers:	No Data		
Plugging Info:	Casing or Cement/Bentonite left in	n well: No Data	
Type Of Pump:	Submersible Depth to pump bowl: 336 ft		
Well Tests:	Estimated Yield: 40 GPM with (No Data) ft d	drawdown after (No Data) hours	
	Type of Water: Fresh	Type of Water: Fresh Depth of Strata: No Data Chemical Analysis Made: No Did the driller knowingly penetrate any strata which contained undesirable constituents: No	
Water Quality:	Chemical Analysis Made: No	any strata which contained undesi	able constituents

Company Information:	Geoprojects International, Inc. 8834 Circle Drive Austin , TX 78736
Driller License Number:	2551
Licensed Well Driller Signature:	Jose Landeros
Registered Driller Apprentice Signature:	Evan Schaefer
Apprentice Registration Number:	57623
Comments:	During Drilling, lost circulation at 38.5 feet due to void that ended at 42.5 feet

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking number (Tracking #229441) on your written request.

Texas Department of Licensing & Regulation P.O. Box 12157 Austin, TX 78711 (512) 463-7880

DESC. & COLOR OF FORMATION MATERIAL

From (ft) To (ft) Description 0 to 27 Upper Glen Rose Limestone Formation 27 to 345 Lower Glen Rose Limestone Formation 345 to 358.3 Bexar Shale Formation CASING, BLANK PIPE & WELL SCREEN DATA

Dia. New/Used Type Setting From/To 8-inch New SDR-17 Certalok PVC Casing set from +2.5 to 65.1

SWMU B-3 DO-50 Survey Data Camp Stanley Storage Activity August 2010

Description	Point No.	Northing	Easting	Elevation
Description		Northing	Lasting	(feet)
B3-EXW-02_NG	302	3286432.80	537399.90	1246.42
B3-EXW-02_CONC	303	3286432.86	537399.95	1246.31
B3-EXW-02_ELINE	300	3286431.68	537399.46	1249.66
B3-EXW-02_SCADA	301	3286431.67	537399.30	1249.61
B3-EXW-02_CASING	299	3286431.65	537399.53	1249.55
B3-EXW-02_CONC/DISC AREA	298	3286431.97	537399.29	1246.42
B3-MW26-UGR NG	320	3286751.61	537221.79	1235.53
B3-MW26-UGR CONC	321	3286751.52	537221.70	1235.61
B3-MW26-UGR BRASS DISC	322	3286751.22	537221.11	1235.64
B3-MW26-UGR_PVC	323	3286751.01	537221.13	1238.49
B3-MW27-UGR_NG	316	3286644.89	537234.53	1230.62
B3-MW27-UGR_CONC	317	3286644.83	537234.44	1230.77
B3-MW27-UGR_BRASS_DISC	318	3286644.32	537233.96	1230.81
B3-MW27-UGR_PVC	319	3286644.37	537233.76	1233.42
B3-MW28-UGR NG	312	3286555.31	537190.42	1223.94
B3-MW28-UGR CONC	313	3286555.24	537190.33	1224.07
B3-MW28-UGR BRASS DISC	314	3286554.67	537189.99	1224.14
B3-MW28-UGR_PVC	315	3286554.70	537189.76	1226.67
B3-MW29-UGR_NG	308	3286516.22	537294.03	1230.38
B3-MW29-UGR_CONC	309	3286516.14	537293.96	1230.58
B3-MW29-UGR_BRASS_DISC	310	3286515.49	537293.86	1230.59
B3-MW29-UGR_PVC	311	3286515.45	537293.65	1233.25
B3-MW30-UGR NG	304	3286479.10	537374.83	1242.83
B3-MW30-UGR CONC	305	3286479.05	537374.82	1242.97
B3-MW30-UGR BRASS DISC	306	3286478.41	537374.71	1243.03
B3-MW30-UGR_PVC	307	3286478.38	537374.48	1246.01
B3-MW31-UGR_NG	336	3286619.45	537401.73	1254.52
B3-MW31-UGR_CONC	337	3286619.47	537401.68	1254.64
B3-MW31-UGR_BRASS_DISC	338	3286619.89	537400.75	1254.65
B3-MW31-UGR_BRASS_PVC	339	3286619.71	537400.90	1257.20

Monitoring well northing and eastings based on NAD 83, UTM 14N from CSSA Site Benchmarks.

Elevation datum based on CSSA Site Benchmarks converted to feet MSL.

Survey by: Survey & Appraisal Services, Marion, TX, 210-273-0946

SWMU B-3 DO-50 Survey Data Camp Stanley Storage Activity August 2010

Description	Point No.	Northing	Easting	Elevation (feet)
B3-MW32-UGR_NG	332	3286713.79	537458.16	1264.00
B3-MW32-UGR_CONC	333	3286713.75	537458.14	1264.07
B3-MW32-UGR_BRASS_CONC	334	3286712.94	537457.55	1264.18
B3-MW32-UGR_PVC	335	3286713.06	537457.71	1266.98
B3-MW33-UGR_NG	328	3286779.16	537389.86	1247.17
B3-MW33-UGR_CONC	329	3286779.10	537389.83	1246.82
B3-MW33-UGR_BRASS_DISC	330	3286778.31	537389.21	1246.85
B3-MW33-UGR_PVC	331	3286778.41	537389.40	1249.55
B3-MW34-UGR_NG	324	3286784.28	537334.86	1241.51
B3-MW34-UGR_CONC B3-MW34-UGR_BRASS_DISC	325 326	3286784.20 3286783.53	537334.78 537333.99	1241.76 1241.82
B3-MW34-UGR_PVC	327	3286783.61	537334.22	1244.51
B3-EXW-01_NG	340	3286644.68	537355.48	1241.81
B3-EXW-01_CONC	341	3286644.65	537355.43	1241.99
B3-EXW-01_ELINE	342	3286642.19	537354.16	1245.26
B3-EXW-01_SCADA	343	3286642.24	537354.15	1245.29
B3-EXW-01_CASING	297	3286642.16	537354.12	1244.96
B3-EXW-01_CONC/DISC AREA	296	3286642.15	537354.28	1241.81

Monitoring well northing and eastings based on NAD 83, UTM 14N from CSSA Site Benchmarks. Elevation datum based on CSSA Site Benchmarks converted to feet MSL.

Survey by: Survey & Appraisal Services, Marion, TX, 210-273-0946


ATTACHMENT 2


B3-EXW02 TOTCO Summary B3-EXW02 Geophysical Log B3-EXW02 Borehole Video (DVD) Short-Term Pumping Test Hydrograph


B3-EXW02 Borehole Deviation Surveys Camp Stanley Storage Activity May 2010

Depth (feet bgs)	B3-EXW02 Borehole
50'	1/4°
100'	1/2°
150'	1-1/4°
200'	1/4°
250'	3/4°
300'	1°
350'	1/4°
400'	TD = 358' bgs


All measurements were colleted by *MD TOTCO* declination tool, double-punched on 7° target. bgs = below ground surface TD = Total Depth







SWMU B-3 Groundwater Extraction Well B3-EXW02 Short-Term Pumping Test Camp Stanley Storage Activity June 17, 2010



ATTACHMENT 3

B3-EXW02 Water Sample Laboratory Results

Metals Analysis

Parsons 8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 05/19/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61700 APPL ID: AY15816

Method	Analyte	Result	PQL	MDL	Units	DF	Prep Date	Analysis Date
6010B/3010A	Arsenic (As)	Not detected	5.0	2.45	ug/L	1	05/21/10	05/21/10
6010B/3010A	Barium (Ba)	46.8	5.0	0.75	ug/L	1	05/21/10	05/21/10
6010B/3010A	Cadmium (Cd)	Not detected	5.0	0.51	ug/L	1	05/21/10	05/21/10
6010B/3010A	Chromium (Cr)	6.1	5.0	1.37	ug/L	1	05/21/10	05/21/10
6010B/3010A	Copper (Cu)	9.6	5.0	0.97	ug/L	1	05/21/10	05/21/10
6010B/3010A	Lead (Pb)	Not detected	5.0	1.58	ug/L	1	05/21/10	05/21/10
6010B/3010A	Manganese (Mn)	132	5.0	1.23	ug/L	1	05/21/10	05/21/10
7470A/7470A	Mercury (Hg)	Not detected	0.2	0.06	ug/L	1	05/21/10	05/21/10
6010B/3010A	Nickel (Ni)	6.2	5.0	0.39	ug/L	1	05/21/10	05/21/10
6010B/3010A	Zinc (Zn)	29.0 J	50.0	2.30	ug/L	1	05/21/10	05/21/10

EPA 8260B - AFCEE 3.0 (Water)

Parsons

8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 05/19/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61700

APPL ID: AY15816

QCG: #826AW-100524AS-143556

Method	Analyte	Result	PQL	MDL	Units	Extraction Date	Analysis Date
EPA 8260B	1,1,1,2-Tetrachloroethane	Not detected	0.5	0.13	ug/L	05/24/10	05/24/10
EPA 8260B	1,1,1-TCA	Not detected	0.8	0.14	ug/L	05/24/10	05/24/10
EPA 8260B	1,1,2,2-Tetrachloroethane	Not detected	0.4	0.10	ug/L	05/24/10	05/24/10
EPA 8260B	1,1,2-TCA	Not detected	1.0	0.20	ug/L	05/24/10	05/24/10
EPA 8260B	1,1-DCA	Not detected	0.4	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	1,1-DCE	Not detected	1.2	0.30	ug/L	05/24/10	05/24/10
EPA 8260B	1,1-Dichloropropene	Not detected	1.0	0.20	ug/L	05/24/10	05/24/10
EPA 8260B	1,2,3-Trichlorobenzene	Not detected	0.3	0.29	ug/L	05/24/10	05/24/10
EPA 8260B	1,2,3-Trichloropropane	Not detected	3.2	0.39	ug/L	05/24/10	05/24/10
EPA 8260B	1,2,4-Trichlorobenzene	Not detected	0.4	0.21	ug/L	05/24/10	05/24/10
EPA 8260B	1,2,4-Trimethylbenzene	Not detected	1.3	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	1,2-DCA	Not detected	0.6	0.14	ug/L	05/24/10	05/24/10
EPA 8260B	1,2-DCB	Not detected	0.3	0.17	ug/L	05/24/10	05/24/10
EPA 8260B	1,2-Dibromo-3-chloropropane	Not detected	2.6	0.76	ug/L	05/24/10	05/24/10
EPA 8260B	1,2-Dichloropropane	Not detected	0.4	0.17	ug/L	05/24/10	05/24/10
EPA 8260B	1,2-EDB	Not detected	0.6	0.20	ug/L	05/24/10	05/24/10
EPA 8260B	1,3,5-Trimethylbenzene	Not detected	0.5	0.12	ug/L	05/24/10	05/24/10
EPA 8260B	1,3-DCB	Not detected	1.2	0.11	ug/L	05/24/10	05/24/10
EPA 8260B	1,3-Dichloropropane	Not detected	0.4	0.17	ug/L	05/24/10	05/24/10
EPA 8260B	1,4-DCB	Not detected	0.3	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	1-Chlorohexane	Not detected	0.5	0.17	ug/L	05/24/10	05/24/10
EPA 8260B	2,2-Dichloropropane	Not detected	3.5	0.22	ug/L	05/24/10	05/24/10
EPA 8260B	2-Chlorotoluene	Not detected	0.4	0.14	ug/L	05/24/10	05/24/10
EPA 8260B	4-Chlorotoluene	Not detected	0.6	0.13	ug/L	05/24/10	05/24/10
EPA 8260B	Benzene	Not detected	0.4	0.16	ug/L	05/24/10	05/24/10
EPA 8260B	Bromobenzene	Not detected	0.3	0.16	ug/L	05/24/10	05/24/10
EPA 8260B	Bromochloromethane	Not detected	0.4	0.15	ug/L	05/24/10	05/24/10
EPA 8260B	Bromodichloromethane	Not detected	0.8	0.14	ug/L	05/24/10	05/24/10
EPA 8260B	Bromoform	Not detected	1.2	0.14	ug/L	05/24/10	05/24/10
EPA 8260B	Bromomethane	Not detected	1.1	0.24	ug/L	05/24/10	05/24/10
EPA 8260B	Carbon tetrachloride	Not detected	2.1	0.10	ug/L	05/24/10	05/24/10
EPA 8260B	Chlorobenzene	Not detected	0.4	0.21	ug/L	05/24/10	05/24/10
EPA 8260B	Chloroethane	Not detected	1.0	0.21	ug/L	05/24/10	05/24/10
EPA 8260B	Chloroform	Not detected	0.3	0.07	ug/L	05/24/10	05/24/10
EPA 8260B	Chloromethane	Not detected	1.3	0.31	ug/L	05/24/10	05/24/10
EPA 8260B	Cis-1,2-DCE	12	1.2	0.16	ug/L	05/24/10	05/24/10
EPA 8260B	Cis-1,3-Dichloropropene	Not detected	1.0	0.15	ug/L	05/24/10	05/24/10

These results are preliminary and represent information available on 6/2/10 at 11:49am

Quant Method: S826AW.M Run #: 0524S20 Instrument: Sweetpea Sequence: S100521 Dilution Factor: 1 Initials: SV

Printed: 06/02/10 11:49:27 AM APPL-F1-SC-MCRes/MCPQL-REG MDLs

EPA 8260B - AFCEE 3.0 (Water)

Parsons

8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 05/19/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61700

APPL ID: AY15816

QCG: #826AW-100524AS-143556

Mathad	Analyta	Beault	DOI	MDI	Unito	Extraction Date	Analysis Date
Method	Analyte	Result	PQL	MDL	Units		
EPA 8260B	Dibromochloromethane	Not detected	0.5	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	Dibromomethane	Not detected	2.4	0.20	ug/L	05/24/10	05/24/10
EPA 8260B	Dichlorodifluoromethane	Not detected	1.0	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	Ethylbenzene	Not detected	0.6	0.23	ug/L	05/24/10	05/24/10
EPA 8260B	Hexachlorobutadiene	Not detected	1.1	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	Isopropylbenzene	Not detected	0.5	0.16	ug/L	05/24/10	05/24/10
EPA 8260B	m&p-Xylene	Not detected	0.5	0.40	ug/L	05/24/10	05/24/10
EPA 8260B	Methylene chloride	Not detected	1.0	0.35	ug/L	05/24/10	05/24/10
EPA 8260B	n-Butylbenzene	Not detected	1.1	0.15	ug/L	05/24/10	05/24/10
EPA 8260B	n-Propylbenzene	Not detected	0.4	0.21	ug/L	05/24/10	05/24/10
EPA 8260B	Naphthalene	Not detected	0.4	0.36	ug/L	05/24/10	05/24/10
EPA 8260B	o-Xylene	Not detected	1.1	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	p-Isopropyltoluene	Not detected	1.2	0.12	ug/L	05/24/10	05/24/10
EPA 8260B	Sec-Butylbenzene	Not detected	1.3	0.12	ug/L	05/24/10	05/24/10
EPA 8260B	Styrene	Not detected	0.4	0.25	ug/L	05/24/10	05/24/10
EPA 8260B	TCE	3.8	1.0	0.16	ug/L	05/24/10	05/24/10
EPA 8260B	Tert-Butylbenzene	Not detected	1.4	0.13	ug/L	05/24/10	05/24/10
EPA 8260B	Tetrachloroethene	15	1.4	0.15	ug/L	05/24/10	05/24/10
EPA 8260B	Toluene	Not detected	1.1	0.17	ug/L	05/24/10	05/24/10
EPA 8260B	Trans-1,2-DCE	Not detected	0.6	0.19	ug/L	05/24/10	05/24/10
EPA 8260B	Trans-1,3-Dichloropropene	Not detected	1.0	0.18	ug/L	05/24/10	05/24/10
EPA 8260B	Trichlorofluoromethane	Not detected	0.8	0.24	ug/L	05/24/10	05/24/10
EPA 8260B	Vinyl chloride	Not detected	1.1	0.23	ug/L	05/24/10	05/24/10
EPA 8260B	Surrogate: 1,2-Dichloroethane-d4 (S)	77.1	69-139		%	05/24/10	05/24/10
EPA 8260B	Surrogate: 4-Bromofluorobenzene (S)	89.7	75-125		%	05/24/10	05/24/10
EPA 8260B	Surrogate: Dibromofluoromethane (S)	82.5	75-125		%	05/24/10	05/24/10
EPA 8260B	Surrogate: Toluene-D8 (S)	83.0	75-125		%	05/24/10	05/24/10

These results are preliminary and represent information available on 6/2/10 at 11:49am

Quant Method: S826AW.M Run #: 0524S20 Instrument: Sweetpea Sequence: S100521 Dilution Factor: 1 Initials: SV

Printed: 06/02/10 11:49:28 AM APPL-F1-SC-MCRes/MCPQL-REG MDLs

Metals Analysis

Parsons 8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 06/02/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61766 APPL ID: AY16360

Method	Analyte	Result	PQL	MDL	Units	DF	Prep Date	Analysis Date
6010B/3010A	Arsenic (As)	4.5 J	5.0	2.45	ug/L	1	06/03/10	06/03/10
6010B/3010A	Barium (Ba)	44.5	5.0	0.75	ug/L	1	06/03/10	06/03/10
6010B/3010A	Cadmium (Cd)	Not detected	5.0	0.51	ug/L	1	06/03/10	06/03/10
6010B/3010A	Chromium (Cr)	1.5 J	5.0	1.37	ug/L	1	06/03/10	06/03/10
6010B/3010A	Copper (Cu)	3.2 J	5.0	0.97	ug/L	1	06/03/10	06/03/10
6010B/3010A	Lead (Pb)	1.7 J	5.0	1.58	ug/L	1	06/03/10	06/03/10
6010B/3010A	Manganese (Mn)	11.2	5.0	1.23	ug/L	1	06/03/10	06/03/10
7470A/7470A	Mercury (Hg)	0.060 J	0.2	0.06	ug/L	1	06/03/10	06/03/10
6010B/3010A	Nickel (Ni)	Not detected	5.0	0.39	ug/L	1	06/03/10	06/03/10
6010B/3010A	Zinc (Zn)	13.3 J	50.0	2.30	ug/L	1	06/03/10	06/03/10

* Corrected by APPL to "Not Detected" .

J = Estimated value.

EPA 8260B - AFCEE 3.0 (Water)

Parsons

8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 06/02/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61766

APPL ID: AY16360

QCG: #826AW-100603AC-143837

Method	Analyte	Result	PQL	MDL	Units	Extraction Date	Analysis Date
method	Analyte	Result	I QL	MDE	onits	2000	2440
EPA 8260B	1,1,1,2-Tetrachloroethane	Not detected	0.5	0.13	ug/L	06/03/10	06/03/10
EPA 8260B	1,1,1-TCA	Not detected	0.8	0.14	ug/L	06/03/10	06/03/10
EPA 8260B	1,1,2,2-Tetrachloroethane	Not detected	0.4	0.10	ug/L	06/03/10	06/03/10
EPA 8260B	1,1,2-TCA	Not detected	1.0	0.20	ug/L	06/03/10	06/03/10
EPA 8260B	1,1-DCA	Not detected	0.4	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	1,1-DCE	Not detected	1.2	0.30	ug/L	06/03/10	06/03/10
EPA 8260B	1,1-Dichloropropene	Not detected	1.0	0.20	ug/L	06/03/10	06/03/10
EPA 8260B	1,2,3-Trichlorobenzene	Not detected	0.3	0.29	ug/L	06/03/10	06/03/10
EPA 8260B	1,2,3-Trichloropropane	Not detected	3.2	0.39	ug/L	06/03/10	06/03/10
EPA 8260B	1,2,4-Trichlorobenzene	Not detected	0.4	0.21	ug/L	06/03/10	06/03/10
EPA 8260B	1,2,4-Trimethylbenzene	Not detected	1.3	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	1,2-DCA	Not detected	0.6	0.14	ug/L	06/03/10	06/03/10
EPA 8260B	1,2-DCB	Not detected	0.3	0.17	ug/L	06/03/10	06/03/10
EPA 8260B	1,2-Dibromo-3-chloropropane	Not detected	2.6	0.76	ug/L	06/03/10	06/03/10
EPA 8260B	1,2-Dichloropropane	Not detected	0.4	0.17	ug/L	06/03/10	06/03/10
EPA 8260B	1,2-EDB	Not detected	0.6	0.20	ug/L	06/03/10	06/03/10
EPA 8260B	1,3,5-Trimethylbenzene	Not detected	0.5	0.12	ug/L	06/03/10	06/03/10
EPA 8260B	1,3-DCB	Not detected	1.2	0.11	ug/L	06/03/10	06/03/10
EPA 8260B	1,3-Dichloropropane	Not detected	0.4	0.17	ug/L	06/03/10	06/03/10
EPA 8260B	1,4-DCB	Not detected	0.3	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	1-Chlorohexane	Not detected	0.5	0.17	ug/L	06/03/10	06/03/10
EPA 8260B	2,2-Dichloropropane	Not detected	3.5	0.22	ug/L	06/03/10	06/03/10
EPA 8260B	2-Chlorotoluene	Not detected	0.4	0.14	ug/L	06/03/10	06/03/10
EPA 8260B	4-Chlorotoluene	Not detected	0.6	0.13	ug/L	06/03/10	06/03/10
EPA 8260B	Benzene	Not detected	0.4	0.16	ug/L	06/03/10	06/03/10
EPA 8260B	Bromobenzene	Not detected	0.3	0.16	ug/L	06/03/10	06/03/10
EPA 8260B	Bromochloromethane	Not detected	0.4	0.15	ug/L	06/03/10	06/03/10
EPA 8260B	Bromodichloromethane	Not detected	0.8	0.14	ug/L	06/03/10	06/03/10
EPA 8260B	Bromoform	Not detected	1.2	0.14	ug/L	06/03/10	06/03/10
EPA 8260B	Bromomethane	Not detected	1.1	0.24	ug/L	06/03/10	06/03/10
EPA 8260B	Carbon tetrachloride	Not detected	2.1	0.10	ug/L	06/03/10	06/03/10
EPA 8260B	Chlorobenzene	Not detected	0.4	0.21	ug/L	06/03/10	06/03/10
EPA 8260B	Chloroethane	Not detected	1.0	0.21	ug/L	06/03/10	06/03/10
EPA 8260B	Chloroform	Not detected	0.3	0.07	ug/L	06/03/10	06/03/10
EPA 8260B	Chloromethane	Not detected	1.3	0.31	ug/L	06/03/10	06/03/10
EPA 8260B	Cis-1,2-DCE	10	1.2	0.16	ug/L	06/03/10	06/03/10
EPA 8260B	Cis-1,3-Dichloropropene	Not detected	1.0	0.15	ug/L	06/03/10	06/03/10

Quant Method: C826AW.M Run #: 0603C16 Instrument: Chico Sequence: C100601 Dilution Factor: 1 Initials: GM

Printed: 06/07/10 8:57:08 AM APPL-F1-SC-MCRes/MCPQL-REG MDLs

EPA 8260B - AFCEE 3.0 (Water)

Parsons

8000 Centre Park Drive Ste 200 Austin, TX 78754

Attn: Tammy Chang

Project: 747145.03000 CSSA B3 EXW02

Sample ID: B3-EXW02

Sample Collection Date: 06/02/10

APPL Inc. 908 North Temperance Avenue Clovis, CA 93611

ARF: 61766

APPL ID: AY16360

QCG: #826AW-100603AC-143837

			50			Extraction	Analysis
Method	Analyte	Result	PQL	MDL	Units	Date	Date
EPA 8260B	Dibromochloromethane	Not detected	0.5	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	Dibromomethane	Not detected	2.4	0.20	ug/L	06/03/10	06/03/10
EPA 8260B	Dichlorodifluoromethane	Not detected	1.0	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	Ethylbenzene	Not detected	0.6	0.23	ug/L	06/03/10	06/03/10
EPA 8260B	Hexachlorobutadiene	Not detected	1.1	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	Isopropylbenzene	Not detected	0.5	0.16	ug/L	06/03/10	06/03/10
EPA 8260B	m&p-Xylene	Not detected	0.5	0.40	ug/L	06/03/10	06/03/10
EPA 8260B	Methylene chloride	Not detected	1.0	0.35	ug/L	06/03/10	06/03/10
EPA 8260B	n-Butylbenzene	Not detected	1.1	0.15	ug/L	06/03/10	06/03/10
EPA 8260B	n-Propylbenzene	Not detected	0.4	0.21	ug/L	06/03/10	06/03/10
EPA 8260B	Naphthalene	Not detected	0.4	0.36	ug/L	06/03/10	06/03/10
EPA 8260B	o-Xylene	Not detected	1.1	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	p-Isopropyltoluene	Not detected	1.2	0.12	ug/L	06/03/10	06/03/10
EPA 8260B	Sec-Butylbenzene	Not detected	1.3	0.12	ug/L	06/03/10	06/03/10
EPA 8260B	Styrene	Not detected	0.4	0.25	ug/L	06/03/10	06/03/10
EPA 8260B	TCE	5.8	1.0	0.16	ug/L	06/03/10	06/03/10
EPA 8260B	Tert-Butylbenzene	Not detected	1.4	0.13	ug/L	06/03/10	06/03/10
EPA 8260B	Tetrachloroethene	12	1.4	0.15	ug/L	06/03/10	06/03/10
EPA 8260B	Toluene	Not detected	1.1	0.17	ug/L	06/03/10	06/03/10
EPA 8260B	Trans-1,2-DCE	Not detected	0.6	0.19	ug/L	06/03/10	06/03/10
EPA 8260B	Trans-1,3-Dichloropropene	Not detected	1.0	0.18	ug/L	06/03/10	06/03/10
EPA 8260B	Trichlorofluoromethane	Not detected	0.8	0.24	ug/L	06/03/10	06/03/10
EPA 8260B	Vinyl chloride	Not detected	1.1	0.23	ug/L	06/03/10	06/03/10
EPA 8260B	Surrogate: 1,2-Dichloroethane-d4 (S)	97.1	69-139		%	06/03/10	06/03/10
EPA 8260B	Surrogate: 4-Bromofluorobenzene (S)	110	75-125		%	06/03/10	06/03/10
EPA 8260B	Surrogate: Dibromofluoromethane (S)	96.6	75-125		%	06/03/10	06/03/10
EPA 8260B	Surrogate: Toluene-D8 (S)	93.2	75-125		%	06/03/10	06/03/10

Quant Method:	C826AW.M
Run #:	0603C16
Instrument:	Chico
Sequence:	C100601
Dilution Factor:	1
Initials:	GM

Printed: 06/07/10 8:57:08 AM APPL-F1-SC-MCRes/MCPQL-REG MDLs


ATTACHMENT 4


EQUIPMENT INFORMATION

Grundfos Model 40S50-15 Submersible Pump Franklin Electric Motor Model 234 307 8602 SymCom Model 777-KW/HP PumpSaver Endress-Hauser Prowirl 72F Flow Meter Waterpilot FMX167 Level Probe

Easy Selection Chart Performance Curves and Technical Data

4-Inch Submersible Pumps







Materials of Construction

Grundfos Stainless Steel Submersible Pumps

4" Submersible Easy Selection Charts.



40S EASY SELECTION CHART


40310-3 1/2 20 203 203 1 <th1< th=""> 1 1 <</th1<>	SELECTI		HAR	TS									-	LOW	RANG	-											PU	MP OUT	
	Ratings are	e in GAL	LON	S PE	r Min	UTE-0	GPM)				DEDT		· ·				() 157											2 " NP	Γ
	DUMD	1				1			1		DEPT	н то г	PUMPI	NG WA	TERL	EVEL	(LIFT) IN FI	EET							1	1		
		нр	PSI		20	40	60	80	100	120	140	160	180	200	220	240	260	280	300	340	400	460	520	600	700	800	900	1000	110
40010 </td <td>-</td> <td></td> <td></td> <td>46.2</td> <td></td> <td>0.0</td> <td></td> <td></td> <td>0_0</td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td>	-			46.2																0.0			0_0						
<tt> Image: state Image: sta</tt>		1		_																									
Image: 10 10 10 10 10 10 10 10 10 10 10 10 10	40S10-3		40	92.4																									
Introder <td></td> <td></td> <td></td> <td>_</td> <td></td>				_																									
40515 1 0 0 1 0 1 <td></td> <td></td> <td>60</td> <td>_</td> <td></td>			60	_																									
And the set of the	HUT-OFF P	SI:			28	19	11																						
				_	57.0	50.0	07.0		41.0	24.0																			
Image: boling isong i	4001E E	1.1/2						18.0																					
	40315-5	1 1/2		_		_	15.0																						
Image: bit						11.0																							
HUT-OF Image A S S A S S S S				_	1.0																								
455	HUT-OFF P	SI:		0	52	44	35	26	18	9																			
455			0	0					54.0	49.0	40.0	29.0	15.0																
 4002007 92 93 93 93 94 94 94 94 94 94 95 95			<u> </u>				53.0	46.0																					
Image: black stateImage: st	40520-7	, .				52.0																							
Introde with the state with the stat	-0020-7	1		_	51.0	_				0.0																			
Image Image <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>0.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>									0.0																				
HUTOFF PS: N 0 7 68 59 51 42 33 25 66 7 10 10 10 <th< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td>10.0</td><td>2.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>-</td><td></td><td></td></th<>							10.0	2.0																			-		
40530-9 0<		<u>.</u>	00				50	E 1	40	20	25	16	-																-
493.0 1/2 6/2 1/2<	JIO I-OFF P	ы. I			11	60	59	51	42	33																	1		
 40.90 + 1 40.90 + 1 40.90 + 1 50.90 + 4.0 50.90 + 5.0 50.90 + 5.0<!--</td--><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>32.0</td><td>22.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td>														32.0	22.0														
Here Here <th< td=""><td></td><td></td><td>20</td><td>46.2</td><td></td><td></td><td></td><td></td><td>51.0</td><td>45.0</td><td>38.0</td><td>29.0</td><td>19.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></th<>			20	46.2					51.0	45.0	38.0	29.0	19.0																
Image: state	40S30-9	3	30	69.3				50.0	44.0	37.0	28.0	17.0																	
Intr - F I I I I<			40	92.4		54.0	50.0	43.0	35.0	26.0	15.0																		
 HUT-OFF PSI: 0 102 94 85 76 86 76 82 83 84 80 80<td></td><td></td><td>50</td><td>116</td><td>54.0</td><td>49.0</td><td>42.0</td><td>34.0</td><td>24.0</td><td>13.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td>			50	116	54.0	49.0	42.0	34.0	24.0	13.0																			
40550-12 5 0			60	139	48.0	41.0	33.0	23.0	11.0																				
40550-12 20 46.2 0 0 50 50 47.0 48.0 43.0 37.0 30.0 22.0 13.0 1 <th1< th=""> 1 1</th1<>	SHUT-OFF P	SI:		0	102	94	85	76	68	59	50	42	33	24	16	7													
40050-12 5 30 60.3 0 0 10 <			0	0									53.0	49.0	44.0	39.0	32.0	25.0	16.0										
40050-12 5 30 60.3 0 0 10 <			20	46.2							52.0	48.0	43.0		30.0														
Hat 40 92.4 1 51.0 60.0 41.0 35.0 28.0 20.0 11.0 1	40S50-12	5		_						51.0																			
Her 50 116 50 50. 50. 50. 30. 30. 30. 25.0 17.0 8.0 i< i i				_					51.0																				
HUT-OFF PSI: 0 130 48.0 49.0 48.0 92.0 78.7 78<70 61 52.7 44.9 55.0 48.0				_			54.0	50.0																					
HUT-OFF P3: · 0 130 120 130 104 96 87 78 70 61 52 44 35 26 18 - - -						53.0								0.0															
40550-16 20 46.2 0 0 0 51.0 48.0 45.0 40.0 35.0 30.0 24.0 0 <	SHUT-OFF P	SI:												61	52	44	35	26	18										
40S 0-10 5 30 69.3 0 0 51.0 48.0 40.0 35.0 28.0 18.0			0	0											52.0	49.0	46.0	42.0	37.0	26.0									
40 92.4 0 0 51.0 47.0 43.0 39.0 34.0 28.0 21.0 14.0 0 0 0 0<			20	46.2									51.0	48.0	45.0	40.0	35.0	30.0	24.0										
50 116 0 500 47.0 43.0 38.0 33.0 27.0 20.0 13.0 -<	40S50-15	5	30	69.3									48.0		40.0	35.0		23.0	16.0										
HUT-OFF PS: 0 130 0 50.0 46.0 42.0 37.0 32.0 26.0 19.0 12.0 10 <th< td=""><td></td><td></td><td></td><td>_</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>14.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></th<>				_														14.0											
HUT-OFF PS: 0 0 141 132 124 115 107 98 89 81 72 63 55 37 11 0 <t< td=""><td></td><td></td><td></td><td>_</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>13.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>				_													13.0												
40S75-21 0<			60	_													70			07									
40S75-21 7 1/2 30 66.2 53.0 51.0 48.0 43.0 32.0 19.0 53.0 51.0 48.0 43.0 32.0 19.0	DID I-OFF P	31:							141	132	124	115	107	98	89	81	72	63	55			20.0	15.0						
40S75-21 7 1/2 30 69.3 52.0 50.0 48.0 45.0 39.0 27.0 13.0				_		-		-									53.0	51.0	48.0				15.0						-
40 92.4 0 0 0 0 52.0 50.0 48.0 45.0 42.0 35.0 22.0 6.0 0	40\$75-21	7 1/2						-								52.0													
50 116 0 0 0 0 52.0 50.0 47.0 44.0 41.0 38.0 30.0 16.0 0				_											52.0	_	_												
inutron inutron <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>52.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>														52.0															
HUT-OFF PSI: 0 0 0 1 181 172 163 155 146 137 129 111 85 59 33 0				_									51.0																
40S75-25 7 1/2 20 46.2 0	HUT-OFF P	SI:		0									181	172	163	155	146												
40875-26 7 1/2 30 69.3 Image: constraint of the state of				_																									
40 92.4 0 <td>40077-0-</td> <td></td> <td>14.0</td> <td></td> <td></td> <td></td> <td></td> <td></td>	40077-0-																							14.0					
50 116 0	40575-25	7 1/2		_		<u> </u>		<u> </u>																					
intro-off PSI: 0 139 0						<u> </u>		<u> </u>		\vdash			<u> </u>				50.0						21.0				<u> </u>		
HUT-OFF PSI: 0 <t< td=""><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>\vdash</td><td></td><td></td><td></td><td> </td><td></td><td>52.0</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td></t<>										\vdash						52.0													
0 0		sı.	00	_		-																	00	47					-
40S100-30 20 46.2 50.0 44.0 30.0 20.0 10S100-30 30 69.3 50.0 44.0 30.0 20.0 <t< td=""><td></td><td>JI.</td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td></td><td>I</td><td></td><td>203</td><td>194</td><td>100</td><td>1//</td><td>001</td><td>134</td><td></td><td></td><td></td><td>27.0</td><td></td><td> </td><td></td><td></td></t<>		JI.												I		203	194	100	1//	001	134				27.0				
IOS 100-30 IO	105100-30																				54.0								-
40 92.4 0 <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td></td> <td><u> </u></td> <td></td> <td>-</td>									<u> </u>																				-
50 116 41.0 49.0 43.0 36.0 25.0 8.0																													
		1																											

* 6" Motor

See 40S performance curves for higher head models. SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE.



MODEL 40S



SPECIFICATIONS SUBJECT TO CHANGE WITHOUT NOTICE. 4" MOTOR STANDARD, 1-10 HP/3450 RPM. 6" MOTOR STANDARD,15-20 HP/3450 RPM. * Also available with 6" motor. Performance conforms to ISO 9906. 1999 (E) Annex A Minimum submergance is 5 feet.

TECHNICAL DATA

DIMENSIONS AND WEIGHTS

			MOTOR	DISCH.		DIMENSIONS IN INCHES			APPROX.	
MODEL NO.	FIG.	HP	SIZE	SIZE	A	В	С	D	E	SHIP WT.
40S10-3	Α	1	4"	2" NPT	24.6	11.8	12.8	3.8	3.9	32
40S15-5	Α	1 1/2	4"	2" NPT	29.7	13.6	16.1	3.8	3.9	37
40S20-7	Α	2	4"	2" NPT	34.5	15.1	19.4	3.8	3.9	41
40S30-9	Α	3	4"	2" NPT	43.3	20.6	22.7	3.8	3.9	65
40S50-12	Α	5	4"	2" NPT	51.3	23.6	27.7	3.8	3.9	78
40S50-15	А	5	4"	2" NPT	56.2	23.6	32.6	3.8	3.9	84
40S75-21*	Α	7 1/2	4"	2" NPT	74.6	29.6	45.0	3.8	3.9	120
40S75-25*	Α	7 1/2	4"	2" NPT	81.2	29.6	51.6	3.8	3.9	124
40S100-30*	Α	10	4"	2" NPT	103.7	43.9	59.8	3.8	3.9	181
40S150-37DS	Α	15	6"	2" NPT	99.5	28.0	71.5	5.4	5.4	244
40S150-44DS	Α	15	6"	2" NPT	111.0	28.0	83.0	5.4	5.4	340
40S200-50DS**	В	20	6"	2" MPT	136.0	30.6	105.4	5.4	5.5	319
40S200-58DS**	В	20	6"	2" MPT	149.2	30.6	118.6	5.4	5.5	334
40S200-66DS**	В	20	6"	2" MPT	162.4	30.6	131.8	5.4	5.5	394

NOTES: All models suitable for use in 4" wells, unless otherwise noted.

Weights include pump end with motor in lbs.

* Also available with 6" motor.

** Built into sleeve 2" MPT discharge, 6" min. well dia.

MATERIALS OF CONSTRUCTION


COMPONENT	CYLINDRICAL SHAFT (3-44 Stgs.)	DEEP SET (50-66 Stgs.)
Check Valve Housing	304 Stainless Steel	304 Stainless Steel
Check Valve	304 Stainless Steel	304 Stainless Steel
Diffuser Chamber	304 Stainless Steel	304 Stainless Steel
Impeller	304 Stainless Steel	304 Stainless Steel
Suction Interconnector	304 Stainless Steel	304 Stainless Steel
Inlet Screen	304 Stainless Steel	304 Stainless Steel
Pump Shaft	431 Stainless Steel	431 Stainless Steel
Straps	304 Stainless Steel	304 Stainless Steel
Cable Guard	304 Stainless Steel	304 Stainless Steel
Priming Inducer	304 Stainless Steel	304 Stainless Steel
Coupling	316/431 Stainless Steel **	329/416 Stainless Steel
Check Valve Seat	NBR/316 Stainless Steel	NBR/316 Stainless Steel
Top Bearing	NBR/316 Stainless Steel	NBR/316 Stainless Steel
Impeller Seal Ring	NBR/316 Stainless Steel	NBR/316 Stainless Steel
Intermediate Bearings	NBR/316 Stainless Steel	NBR/316 Stainless Steel
Shaft Washer	LCP (Vectra®)	LCP (Vectra®)
Split Cone	304 Stainless Steel	304 Stainless Steel
Split Cone Nut	304 Stainless Steel	304 Stainless Steel
Sleeve	Not Required	316 Stainless Steel
Sleeve Flange	Not Required	304 Stainless Steel


NOTES: Specifications are subject to change without notice.

 $\ensuremath{\mathsf{Vectra}}\xspace^{\ensuremath{\mathsf{B}}}$ is a registered trademark of Hoechast Calanese Corporation.

*Stainless Steel option available.

4-22







<u>Home > Markets > Water Systems > Products > Motors and Controls > products</u> > Product

Model: 234 307 8602

4-inch Motors - High Thrust



annericas viiamer SVSTEVLS

Motor Specifications: Horsepower: 5 Voltage: 200 Frequency: 60 Phase: Three-Phase **RPM:** 3450 Service Factor: 1.15 Rotation: CCW Facing Shaft End Poles: 2 Downward Thrust (Ibs): 1500 LBS (6500 N) Max. Ambient Temp.: 86°F / 30°C Duty Rating: Continuous at 0.25 ft/sec flow past motor Construction Materials: **Construction:** Water Well Length (inches): 23.2 Shipping Weight (lbs / 56 / 25.4 kg): Carton Size: 6 x 6 x 28 Stator Shell: 301 SS Stator Ends: Low Carbon Steel Shaft Extension: 17-4 SS Fasteners: 300 Series SS Seal: Nitrile Rubber Lip Seal Cover: Acetol Slinger: Nitrile Rubber Lead in Motor: YES Lead Wire (or Cable): XLPE* Lead Potting: Epoxy Diaphragm: Nitrile Rubber Diaphragm Cover: Gray Iron Diaphragm Cup: 316 SS Diaphragm Spring: 316 SS Filter: Delrin & Polyester

Terms | Contact Information

© 2010 Franklin Electric Co., Inc. All Rights Reserved. 400 E. Spring St., Bluffton, IN 46714 U.S.A. Tel: 260.824.2900 Fax: 260.824.2909

Features

- Digital programmability permits precise customization.
- Sixteen setpoints can be programmed for maximum protection.
- Last fault memory provides instant troubleshooting diagnostics.
- Voltage, current, last 4 faults, kW, hp and power factor are recordable when using communications package.
- An RS485 communication port comes standard for use with computerized systems using Modbus protocol.
- UL and CSA listed as an overload relay.

Applications

The Model 777-KW/HP can be used on ANY 3-phase motor. It has advantages over current monitors in low speed motor applications (less than 1800 rpm), lower power applications and in lightly loaded applications. Some examples include LOW SPEED MIXERS, CAN PUMPS, MAG DRIVE PUMPS, FRACTIONAL HORSEPOWER PUMPS and MOTORS, SUBMERSIBLE PUMPS AND COAL BED METHANE WELLS.

Description

The Model 777-KW/HP is a fully-programmable motor and pump protection relay with power-monitoring capability. Voltage, current and power measurements are displayed on the threedigit display, as well as fault information and setpoints. The display simplifies troubleshooting and : allows the user to easily and precisely configure setpoints. The Model 777-KW/HP has the following adjustable protection features:

- 1) Low voltage
- 2) High voltage
- 3) Voltage unbalance
- 4) UL listed/CSA approved overload
- 5) Trip class (5, 10, 15, 20, 30)
- 6) Current unbalance
- 7) Ground fault
- 8) Low power
- 9) High power (via network only)
- 10) Rapid-cycle timer
- 11) Fault/overload restart delay
- 12) Underload restart delay
- 13) Underpower/overpower trip delay

Other user adjustable features include:

1) CT/loop multiplier so overcurrent and power setpoints can be made in actual amps, kW or hp

- 2) Number of restarts after faults manual, automatic and semiautomatic options
- 3) Number of restarts after underload manual, automatic and semiautomatic options
- 4) Network address

Adding the optional RS485MS-2W communications module activates the built-in Modbus RTU bus : capabilities. The 777-KW/HP can communicate with the SymCom RM-1000 and RM-2000 remote : display modules, PLCs, RTUs, SCADA systems, PCs and other similar control devices. Real-time operating parameters can be gathered and setpoints can be viewed or modified via the RS-485 bus : using Modbus RTU protocol.







Protects 3-Phase Motors and Pumps from:

- Underload (Low KW or HP)
- High power
- Overload (UL listed)
- Jams
- Undervoltage
- Overvoltage
- Single-phasing
- Unbalance (voltage & current)
- Ground fault (Class II)
- Rapid cycling
- Phase reversal

Additional Features

- Fully programmable
- UL and CSA listed
- · CE marked
- Automatic or manual reset
- Tamper guard
- RS-485 communications port
- Surface or DIN rail mountable
- Alphanumeric LED diagnostic display
- Last fault memory
- · Up to 99 individually programmable addresses
- 5-year warranty
- Made in USA

New Features


- Network programmable
- · Ability to clear last fault
- · Remote setup,
- **Diagnostics and control**
- Remote data logging

ELECTRIC MOTOR WHOLESALE.COM (302) 653-1844 email: sales@electricmotorwholesale.com 11/05



Ð

TYPICAL WIRING DIAGRAM FOR MODEL 777-KW/HP (20-90 AMPS) & 777-LR-KW/HP (2-9 AMPS)




Wiring configuration based on motor amps.


Model	Full Load Amps	# of Loops	# of Conductors through A, B and C	MULT to Program (CT Ratio)
777-LR-KW/HP	1 - 2 2 - 9	1 0	2 1	2 1
777-KW/HP	8 - 12 12 - 25 25 - 90	2 1 0	3 2 1	3 2 1
External CTs required. See wiring diagram for external CTs	80 - 110 110 - 160 160 - 220 220 - 320 320 - 420 400 - 520 480 - 600 560 - 800	4 4 4 4 4 4 4	5 5 5 5 5 5 5 5 5 5	100 (100:5) 150 (150:5) 200 (200:5) 300 (300:5) 400 (400:5) 500 (500:5) 600 (600:5) 800 (800:5)



CURRENT TRANSFORMER WIRING DIAGRAM FOR MODEL 777-KW/HP (80-800 AMPS)



Overload Trip Classes



11/05




The Model 777-KW/HP has important advantages over current monitors in many protection applications. Any motor load that has a small or very non-linear change in current vs. load requires the use of a power monitor for under-load, dry-run and dead-head protection. The change in power vs. load is more linear for most motor loads and is greater in magnitude than the change in current in all motor loads. This is because power measurements take into account both power factor (pf) and current.

Small motors, those under 3 hp and especially fractional horsepower, exhibit small changes in current vs. load but the change in power is large. When larger motors are derated, run below their rated horsepower, the change in current is small vs. load, but again, the change in power is large and linear. Other typical applications include slower speed mixer or agitator motors up to 50 hp and beyond. These motors and others that run slower than around 3400 rpm usually have small current changes vs. load.

Magdrive and can pumps tend to be small horsepower, positive displacementtype pumps. These pumps need the high sensitivity of a power monitor to protect them from dry-run using the underpower feature and dead-head conditions using the underpower feature if the motor decouples from the pump and the overpower feature if the motor does not decouple.


The built-in UL Listed/CSA approved overload, current unbalance, reversephase, single-phase and other protection features are significant benefits over similar products. The Modbus communications capability allows this device to be directly integrated with the SymCom RM-1000 and RM-2000 remote displays or other remote monitoring and control equipment.




Advantages:

- Integrated UL Listed/CSA approved electronic overload relay
- Greater underload sensitivity than power factor or current monitors
- Built-in undervoltage, overvoltage and unbalance protection
- Digitally programmable
- Remote programmability
- Digital display
- Optional remote display
- Data logging capabilities

Dimensions for All 777-KW/HP Units







Specifications

Input Voltage Ranges and Low and High Voltage Setpoints			
	Low Setpoint (LV)	Nominal Voltage Range	High Setpoint (HV)
777-KW/HP	170-HV Setting	200-480 VAC	LV Setting - 528
777-LR-KW/HP	340-HV Setting	380-480 VAC	LV Setting - 528
777-HVR 777-HVR-LR	540-HV Setting	300-400 VAC	EV Setting - 526
777-575	450-HV Setting	480-600 VAC	LV Setting - 660
777-575-LR			
Nominal Motor Full Load Current and Overcurrent Setpoint	1		•
	Nom. Current Range	Overcurrent Setpoint (OC)	Ground Fault Setpoint (GF)
777, 777-HVR, 777-575	2-25A Looped	(20 to 100A)/MULT	OFF, (3 to 20A)/MULT
	25-90A Direct	20 to 100A	OFF, 3-20A
	80-800A Ext CTs 1-2.5A Looped	80-120% of CT Prim 1-5A	0FF, 10-30% of CT Prim 0.15-1A
777-LR, 777-HVR-LR, 777-575-LR	2-9A Direct	2-10A	0.3-2A
	2-5A Direct	2-104	0.5-24
Frequency	50/60 Hz		
Short Circuit	100 kA		
Power Consumption	10 Watts (max.)		
Output Contact Rating SPDT (Form C)			
All 777-XXX-XX KW/HP types except -HVR	Pilot duty rating: 480VA @		
	General purpose: 10A @ 2	40VAC	
	Max Voltage: 277VAC		
777-HVR-KW/HP	Pilot duty rating: 480VA @	9 BUUVAL	
777-HVR-LR-KW/HP Expected Life			
Expected Life Mechanical	1 x 10 ⁶ operations		
Electrical	1 x 10 ⁵ operations at rate	d load	
Accuracy at 25° C (77° F)	I A TO Operations at late		
Voltage	±1%		
Current	±3%(<100 Amps Direct)		
GF Current	±15%		
Timing	5% ± 1 second		
Repeatability	1		
Voltage	± 0.5% of nominal voltage		
Current	± 1% (<100 amps direct)		
Safety Marks			
UL	UL508, UL1053		
CSA CE	LR46510 IEC 60947-1, IEC 60947-5-1		
Standards Passed	TEC 80947-1, TEC 80947-3-		
Electrostatic Discharge (ESD)	IEC 1000-4-2, Level 3, 6k	/ contact_8kV air	
Radio Frequency Immunity (RFI), Conducted	IEC 1000-4-6, Level 3 10V		
Radio Frequency Immunity (RFI), Radiated	IEC 1000-4-3, Level 3 10V/m		
Fast Transient Burst	IEC 1000-4-4, Level 3, 3.5	kV input power	
Surge			
IEC	1000-4-5, Level 3, 2kV lir	ne-to-line; Level 4, 4kV line-to-g	ground
ANSI/IEEE		ave Compliance to 6kV line-line	
Hi-potential Test	Meets UL508 (2 x rated V		
Vibration		peak-to-peak, 2 hours, 3 axis	
Shock	IEC 68-2-27, 30g, 3 axis, 1	1ms duration, half-sine pulse	
fechanical			
Dimensions Terminal Torque	3.0"H x 5.1 " D x 3.6"W 7 inlb.		
Enclosure Material	Polycarbonate		
Weight	1.2 lbs.		
Maximum Conductor Size Through 777-KW/HP	0.65" with insulation		
nvironmental	Toroo with modulion		
Temperature Range	Ambient Operating: -20° t	o 70° C (-4° to 158°F)	
	Ambient Storage: -40° to		SymCom warrants its microco
Pollution Degree	3	· · · · · · · · · · · · · · · · · · ·	products against defects in materia for a period of five (5) years fr
Class of Protection	IP20, NEMA 1		manufacture. All other products i
Relative Humidity	10-95%, non-condensing p	oer IEC 68-2-3	SymCom shall be warranted ag material and workmanship for a p
rogrammable Operating Points	Range		years from the date of manufactu
LV, HV, OC, GF	See electrical specification	is above	information on warranty, liability, te cancellations, please refer to the
UB- Voltage Unbalance Threshold	2 - 15% or 999%		cancellations, please refer to the and Conditions of Sale document.
MULT- # of Loops or CT Ratio (XXX:5)	1-10 Loops or 100-800 Ra		
LP- Low Power Setting	See Power Ranges Below of	or 0=off	NOTES: SymCom's 777-KW/
CUB- Current Unbalance Threshold	2 - 25% or 999%	120, 20, 120	KW/HP can be preprogrammed
TC- Overcurrent Trip Class ** PD1 Papid Cycle Timer	5, J5, 10, J10, 15, J15, 20,	JLU, 3U, J3U	tion by applying 120 VAC betw
RD1- Rapid Cycle Timer RD2- Restart Delay After All Faults Except Underload (motor cool down timer)	0, 2 - 500 Seconds 2 - 500 Minutes		L2 terminals.
RD3- Restart Delay After Underload (dry-well recovery timer)	2 - 500 Minutes		 575 volt Model (MS 777-575 If J prefix is displayed in tr
#RU- Number of Restarts After Underload	0, 1, 2, 3, 4, A(Automatic)		** If J prefix is displayed in tri jam protection is enabled.
ADDR- RS485 Address	A01- A99		*** If "oc" is disabled in the #
#RF-Number of Restarts After All Faults Except Underload***	0, 1, oc1, 2, oc2, 3, oc3, 4	, oc4, A, ocA	overcurrent will be include
Low Power (LP) / Power Range Setting (PWS)	1 = 0.01 - 0.99 KW	5 = 0.01 - 0.99 HP	fault and the relay will autor
	2 = 1.00 - 9.95 KW	6 = 1.00 - 9.95 HP	after RD2 expires, otherwise
(PWS = LP Range)	3 = 10.0 - 99.5 KW	8 = 10.0 - 99.5 HP	is required after an overcurre
	4 = 100 - 650 KW	9 = 100 - 650 HP	

ntroller based or workmanship im the date of ianufactured by inst defects in priod of two (2) e. For complete ms returns, and SymCom Terms

P & 777-LR-prior to installa-en the L1 and

- KW/HP) class setting,
- RF setting, the as a normal natically restart , manual reset nt fault.

INSTALLATION INSTRUCTIONS FOR MODELS 777-KW/HP, 777-LR-KW/HP,777-575-KW/HP, 777-HVR-LR-KW/HP, 777-HVR-KW/HP POWER MONITOR/MOTOR PROTECTION RELAY BE SURE POWER IS DISCONNECTED PRIOR TO INSTALLATION! FOLLOW NATIONAL, STATE AND LOCAL CODES! READ THESE INSTRUCTIONS ENTIRELY BEFORE INSTALLATION.

The Model 777-KW/HP is a solid-state power monitor/motor protection relay. It is fully-programmable for customized protection. It is designed to protect three phase systems operating on voltages from 190 to 480 VAC (500-600VAC for 777-575-KW/HP). The output relay is a Form C contact, which can control a contactor or other device within the output relay contact rating. The unit can be programmed prior to installation by applying 120VAC to terminals 'L1' and 'L2' (except 777-575-KW/HP and 777-HVR-KW/HP). The unit can NOT be tested for proper operation using this voltage. For testing purposes, three phase power needs to be used with a minimum voltage of 190VAC (450VAC for 777-575-KW/HP).

DANGER!

4

HAZARDOUS VOLTAGES MAY BE PRESENT DURING INSTALLATION. Electrical shock can cause death or serious injury. Installation should be done by qualified personnel following all national, state and local electrical codes.

CONNECTIONS

- 1. Disconnect power and verify power is off.
- Using the four corner tabs or the DIN rail mount, mount the 777 directly above or below the contactor. To use the DIN rail mount, hook the top clip first then apply downward pressure until the lower clip 'clicks' onto the rail.
- 3. A) For amperage ranging from 25-90 amps (2-9 Amps -LR types), insert the motor conductors through the holes marked 'A', 'B', and 'C'. Make certain that the conductor through each hole corresponds to the right motor conductor, i.e. the 'A' phase conductor should go through the 'A' round hole. See Figure 1 for a typical wiring diagram.

B) For amperage less than 25 amps, loop the motor conductors according to Table 1.
Figure 3 shows an example of the looping required for current ranging from 8.1 to 12 amps (MULT=3).
C) For amperage greater than 90 amps, external CT's (current transformers) are required.
SymCom recommends CT's with terminals be used for ease of installation. All CT secondaries must make five passes through the round holes on the PumpSaver. See Figure 2 for a typical wiring diagram using external CT's.

NOTE: Pay close attention to this diagram to eliminate any power factor errors that will create errors in the horsepower measurements.

- 4. Connect the three phase power from the line side of the contactor to 'L1', 'L2', and 'L3' terminals using 12-18AWG copper wire (See Figure 1). Figure 1 is drawn for a power system wired in "ABC" phase sequence. For power systems with "ACB" phase sequence, switch L1 and L3 connections on 777-KW/HP input.
- 5. Connect the control circuit wires to the appropriate terminals. The relay is a fail safe design so the 'NO' contact should be in series with the coil on the contactor for motor control (see Figure 1). For alarm circuits, the 'NC' contact is in series with the alarm circuitry.

Visit our website at www.symcominc.com for our complete catalog and new product listings!



ELECTRIC MOTOR WHOLESALE.COM

Model	Full Load Amps	# of Loops	# of Conductors through A, B and C	MULT to Program (CT Ratio)
777-XXX-LR-KW/HP	1 - 2 2 - 9	1 0	2 1	2 1
777-KW/HP 777-HVR-KW/HP 777-575-KW/HP	2 - 2.5 2.5 - 3 3 - 3.5 3.5 - 4 4 - 5 5 - 6 6 - 8 8 - 12 12 - 25	9 8 7 6 5 4 3 2 1	10 9 8 7 6 5 4 3 2	10 9 8 7 6 5 4 3 2
External CTs required. See wiring diagram for external CTs.	25 - 90 80 - 110 110 - 160 160 - 220 220 - 320 320 - 420 400 - 520 480 - 600 560 - 800	0 4 4 4 4 4 4 4 4	1 5 5 5 5 5 5 5 5 5 5	1 100 (100:5) 150 (150:5) 200 (200:5) 300 (300:5) 400 (400:5) 500 (500:5) 600 (600:5) 800 (800:5)

Table 1: Wiring Configuration Based on Motor Full Load Amps




Figure 1: Typical Wiring Diagram for FLA of 26-90 ("ABC" phase sequence*) *For input power configuration of "ACB" phase sequence, invert the L1 and L3 terminals on the 777-KW/HP.




Figure 2: Typical Wiring Diagram Using External CTs.




Figure 3: Looping Example Showing Three Conductors (MULT=3 from Table 1) (No other necessary connections are shown.)

! WARNING !

UNEXPECTED OUTPUT ACTUATION CAN OCCUR. Use hard-wired safety inerlocks where personnel and/or equipment hazards exist. Failure to follow this instruction can result in death, injury or equipment damage.

PROGRAMMABLE PARAMETERS

The programmable parameters are the parameters which the user MUST program to provide the correct protection for the application. All parameters are actual values except for the "VUB" and the "CUB" settings. These are programmed as percentages. The range these parameters can be programmed to is found on the electrical specifications on page 11. See page 7 for programming examples.

- <u>LV/HV</u> The recommended settings for LV (low-voltage) and HV (high-voltage) according to the NEMA MG1 standard are ±10% of the motors nameplate voltage. For other settings the motor manufacturer should be contacted. Example: The motor nameplate voltage is 230 volts. If we take 90% and 110% of 230 we get 0.9 x 230= 207 volts for the LV setting and 230 x 1.1= 253 volts for the HV setting. These parameters are based on the average voltage going to the motor.
- <u>VUB</u> VUB (voltage unbalance) is factory set at 6%. The NEMA MG1 standard says a motor should not be operated above a 1% voltage unbalance without **DERATING** the motor. Most utility supplied power sources have a difficult time sustaining a 1% VUB. The motor manufacturer should be consulted for an exact VUB setting. A setting of 999 for VUB will disable the VUB protection and SP (single phase protection).
 - The VUB is calculated as follows:
 - %VUB = [(Maximum deviation from the average)/Average] x 100%
 - Example: Measured line-line voltages = 203, 210, and 212, so the average = (203+210+212)/3 = 208.3, the maximum deviation from the average is the biggest difference between the average voltage (208.3) and any one voltage reading, 212-208.3 = 3.7, 210-208.3 = 1.7 and 208.3-203 = 5.3, therefore the maximum deviation from the average is 5.3. The VUB is then = 5.3/208.3 x 100= 2.5%
- <u>MULT</u> MULT (multiplier) setting is found from table 1. The MULT setting is determined by the current the unit will be monitoring. This allows the unit to display the correct current. Changing this setting will also change the "OC", and "GF" set points.
- <u>OC</u> OC (overcurrent) is usually set at the service factor amperage (typically 100-115% of motor FLA) of the motor, which is determined by the motor manufacturer. If any one leg of current exceeds the oc setting, the unit will follow its overload trip curve. (see Figure 4).
- LP- LP (low power setting) is used to shut down the motor or pump on an underload condition. Setting LP to 0 disables the underload trip feature. LP is set in either kilowatts (KW) or horsepower (HP) depending on the PWS setting. NOTE: PWS must be set before setting LP.
- HP- HP (high power setting) is used to shut down the motor or pump on an overpower condition. The High Power trip uses the underload trip delay and dry well recovery timer (RD3) to delay trips and restarts. The HP and underload trip delay settings can only be adjusted from the SymCom Solutions software or another software utility that can send Modbus write commands. The 777-KW/HP is shipped from the factory with this feature disabled.
- <u>CUB</u> CUB (current unbalance) is factory set to 7%. SymCom recommends the motor manufacturer be contacted for an exact setting. The CUB is calculated the same way the VUB is determined above. The CUB protection can be disabled by programming a 999 in this setting. This will disable current unbalance protection and current single phasing protection.
- <u>TC</u> TC (trip class) is the parameter used to determine when the unit will trip when an overload condition is detected. For standard motors, the TC is typically set at 20. The motor manufacturer should be contacted for exact TC settings. Table 2 and Figure 4 show the range of TC settings and trip times.

- <u>RD1</u> RD1 (restart delay one) is the rapid cycle timer in seconds. This timer is initiated when power is first applied to the unit. If everything is okay (voltages are within the programmed limits and no SP or RP condition exists), after power is applied to the device and the RD1 time expires, the output relay will energize (the NO will close and the NC will open). Typically, this is set to 20-30 seconds. This will provide adequate protection for successive power outages or short cycling caused by other motor controls. This timer is also initiated when another control shuts the motor off (current goes to zero). If the user does not want the units' relay to de-energize when another control shuts the motor off, then RD1 should be set to zero. This will also assure that when an alarm circuit is used, an alarm will sound only when there is a true problem or when power is lost.
- RD2 RD2 (restart delay two) is the restart timer, in minutes, used when the unit has shut off due to a current unbalance, current single phasing, or an overload condition (if "oc" is the prefix to the number in #RF, see #RF description). This timer is known as a motor cool down timer. A setting of 5-10 minutes will give most motors adequate time to cool down after an overload condition. The motor manufacturer should be contacted for an exact value.
- **RD3-** Restart Delay 3 (Dry Well Recovery Timer) RD3 can be set from 2-500 minutes or to 'A' to enable the Automatic Dry Well Recovery Calculator. The RD3 timer causes a restart delay after an under load (LP) trip.

The Automatic Dry Well Recovery Calculator allows the 777 to automatically select a restart delay based on the run time of the last run cycle. Table 2 shows the next restart delay vs. run time. In general a longer run time produces a shorter restart delay. This feature allows the 777 to optimize running and rest times automatically.

Run time	Next Restart Delay (min)	Starts/Hr
> 1hr	6	10
30 min - 59.99 min	15	4
15 min - 29.99 min	30	2
< 15 min	60	1

Table 2: State Table

- **#RU** The #RU/ADDR is a dual function setting. #RU can only be set to 0, 1, 2, 3, 4, or A. ADDR settings have the following format: Axx. The "xx" is any number combination from 01-99. This is how to identify which parameter is being programmed. The #RU settings cover from the 7 o'clock position to the 11 o'clock position. ADDR settings start after the 11 o'clock position. #RU (# of restarts after an underload) is the number of restarts after a low power trip condition before the unit locks and requires a manual restart. This counter will be cleared one minute after start-up if the unit does not trip again on LPR. A setting of zero means no automatic restarts after an underload.
- <u>ADDR</u> ADDR (address) is the RS485 address of the particular device. This is only used when communicating with an RM-2000 (set ADDR=A01), RM-1000, a PLC, or PC. The ADDR can be programmed from A01-A99.
- #RF #RF (# of restarts after a fault) is the number of restarts allowed after a current unbalance, current single phasing, or an overload condition. A setting, which includes an "oc" prefix, will include over current in the number of successive restarts. If "oc" is not a prefix to the programmed setting, the unit will require a manual restart after an overcurrent. A setting of zero means the unit will not try to restart after a CUB, OC, or SP. A setting of "ocA" means the unit will always try to restart after a CUB, OC, or SP.
- PWS
 PWS (power scale) is the range setting for the LP setting.

 1=0.01 0.99 KW;
 2=1.00 9.95 KW;
 3=10.0 99.5 KW;
 4=100 650 KW

 5=0.01 1.30 HP;
 6=1.34 13.3 HP;
 7=13.4 133.0 HP;
 8=134 871 HP

 Settings
 1-4 will allow the LP setting to display in KW.
 Settings 5-8 will allow the LP setting to display in HP.

<u>GF</u> - GF (ground fault) is the maximum allowable current, which can flow to ground before the unit de-energizes its relay. This is a residual, class II ground fault system and should not be used for personnel safety. A typical setting for this is 10%-20% of the motor full load current. The real GF current level is programmed into the unit. The GF test procedure on the last page of the installation instructions must be conducted before the device is brought online.

PROGRAMMING

- 1. Rotate the mode select switch to the parameter to be programmed. SymCom recommends that "LV" be programmed first and then move clockwise through the positions to complete the process.
- 2. Press and hold the "RESET/PROGRAM" button.
- Rotate the "DISPLAY/PROGRAM" knob until the proper setting for the parameter that is being programmed is displayed in the LED display.
- 4. Release the "RESET/PROGRAM" button. This stores the new parameter in the nonvolatile memory. If the number changes back to what is was before programming, then the tamper guard is "on" and will need to be unlocked before programming can be completed. (See page 11 for tamper guard procedures.)
- 5. Continue steps 1-4 until all parameters are programmed.
- 6. The programming is now complete. Please see "Operations" section (p.6) for operating the unit.

Operation

The relay operation of the 777-KW/HP is a fail safe design. This means when everything is within the limits programmed into the unit, the relay will energize; the normally open (NO) contact will close and the normally closed (NC) contact will open. Once the unit has been wired and programmed, the unit is ready to operate. Turn the mode select to the "RUN" position. The display will show "RUN" alternating with some number (the numbers displayed will be the number corresponding to where the "DISPLAY/PROGRAM" knob is pointed). It will do this for the amount of time programmed into "RD1". After this time has expired, the relay will energize (normally open will close and normally closed contact will open). If something else is in the display, see the troubleshooting section for more information. If the mode select is taken out of the "RUN" position, the unit's relay will de-energize.

Trip Class	Application Description
5	Small fractional horsepower motors where acceleration times are almost instantaneous or where extremely quick trip times are required.
10	(Fast Trip) Hermetic refrigerant motors, compressors, submersible pumps and general purpose motors that reach rated speed in less than 4 seconds.
15	Specialized applications.
20	(Standard Trip) Most NEMA-rated general purpose motors will be protected by this setting.
30	(Slow Trip) Motors with long acceleration times (>10 seconds) or high inertia loads.
J Prefix	Programming any of the trip classes with the J Prefix will enable jam protection. This additional protection is enabled 1 minute after the motor starts and provides a 2 second trip time for motors exceeding 400% of the "OC" setting, regardless of trip class.

Table 3: Trip Class Descriptions




Figure 4: Overload Trip Curves

Programming Examples

Example

Pump To Be Protected: 3Ø, 460 Volt, 5 hp magnetic drive pump with a full load amperage rating of 7.1A and maximum service factor amps of 8.2. Use the following calculations and reasoning to determine the appropriate settings for this application. Use 777-LR-KW/HP from Table 1.

- LV- 460 x 0.90 = 414
- HV- 460 x 1.10 = 506
- VUB- Standard NEMA motor = 5
- MULT- From Table No. 1, Mult = 1 (777-LR-KW/HP)
- OC- Service Factor Amperage = 8.2
- LP- Normal pumping operation reads 2.86 KW Pump with a momentarily restricted flow (dead head) reads 1.8 KW Therefore setting is 2.0 KW (see PWS for proper range)
- CUB- Standard NEMA motor = 5
- TC- General purpose motor = 20
- RD1- To protect the pump from accidental rapid cycling, RD = 20 seconds.
- RD2- Because the motor may be hot from running in an unbalance or single phase condition, a motor cool down time of 10 minutes, RD2 = 10, should be appropriate.
- RD3/#RU- Because an underload (low power) would signal a serious problem in this application (dead head), #RU should be set = 0 for a manual reset. Therefore, RD3 does not have any function.
- #RF- Because an overload (overcurrent) fault signals a serious problem in this application (e.g., worn bearings), "oc" should not be included in the #RF setting so that a manual reset after an overload fault is required. A #RF=1 will give the system 1 chance to recover from an unbalance or single phasing problem before manual reset is required.
- PWS- LP setting is 2.0 KW: therefore range = 2(1.0 9.95).
- GF- A ground fault setting of 15% of full load amps will be a significant indicator that the motor should be evaluated for repair or replacement. Therefore, GF = 7.1A x 0.15 = 1.0.

System Display

The output display can show one of the following parameters when the "MODE SELECT" switch is pointed at the "RUN" position: kilowatt or horsepower, each line current, or each individual line-line voltage. The display is also used for programming the operating parameters of the device. The display also identifies what caused the unit to de-energize its relay or what is keeping the unit from energizing its relay. The last fault, not the current fault, can be displayed by pressing and holding the "RUN/RESET" button while the "MODE SELECT" switch is in the "RUN" position. When the unit trips off or is holding the motor off, the current fault condition will be shown in the display <u>without</u> pressing the button. Table 3 below lists the fault codes the unit could display.

Displayed Message	Meaning
ос	Tripped on Overcurrent
SP	Tripped on current single phasing or unit won't start because the voltage is sing phased.
ub	Tripped on current unbalance or unit won't start because the voltage is unbalanced.
LPR	Tripped on Low Power
CF	Tripped on Contactor Failure
GrF	Tripped on Ground Fault
HI	A high voltage condition exists.
Lo	A low voltage condition exists.
rP	Incoming phases have been reversed. Your motor may run backward if started.
oFF	A stop command was issued from a remote source.


Table 4: Fault Codes and Their Meaning

Communications Port / Remote Reset

The unit comes with a 9-pin sub-D connector for remote communications and/or for using a remotely located reset button.

If communications are desired, a communication module (part number RS485MS-2W) needs to be plugged into this 9-pin connector (this is mandatory when communicating with the unit). This module provides isolation, signal conditioning for compatibility with Modbus RTU and RS485 networks, and provides terminals for terminating the shielded communications cable. Up to 99 units can be installed on one RS485 network. Further information can be obtained at http://www.symcominc.com or by calling in your request.

A remote reset button can be hooked up to the communications module (pn RS485MS-2W) or can be hooked directly to the 9-pin connector using a male sub-D connector. It should be wired as shown in Figure 5.



Normally Open Push Button

Figure 5: Remote Reset Button Wiring Diagram

Troubleshooting

The PumpSaver will display a fault code alternating with a number or with "run" when it is in a trip condition. If the unit is showing a fault code (see Table 5) alternating with the word "run", then this indicates it has tripped on a current (amperage) condition. If the fault code is alternating with some number (voltage reading or zero) then the unit will not allow the motor to start because there is a problem with the incoming voltage. If the display is showing just a fault code, then the unit is in a mode that requires a manual reset. This could be because the number of restarts (#RF, #RU) has expired or is not allowed. If the display is showing 'off' then a stop command was issued through the communications network.

PROBLEM	SOLUTION
The unit will not start. Display alternates "rP" with the "DISPLAY / PROGRAM" switch parameter value.	The voltage inputs are reverse phased. If this is the initial start up, swap the leads connected to "L1" and "L3" on the 777-KW/HP to correct the problem. If the overload relay has been previously running, the power system has been reverse phased. Check the phase sequence of the incoming power lines. Note: "L1" must be tapped from conductor Phase A, "L2" from B, and "L3" from C for correct kilowatt measurements.
The unit will not start. Display alternates "SP", "ub", "HI", or "Lo" with the "DISPLAY / PROGRAM" switch parameter value.	The incoming voltage is not within the limits programmed in the "VUB", "HV", and "LV" settings. Adjust the "DISPLAY / PROGRAM" switch to read the incoming line voltage values. Correct the incoming power problem and check programmed limits to verify they are correct.
Display alternates "SP", "ub", or "oc" with "RUN"	The overload relay has tripped on the fault shown on the LED display and is timing down "RD2" before restarting.
Display alternates "LPR" with "RUN"	The overload relay has tripped on low power (LPS) and is timing down "RD3" before restarting. If LPS is not a normal condition for this installation, check for loss of liquid, closed valves, broken belts, etc.
Display is showing a solid "SP", "ub", or "oc"	The unit has tripped on the fault shown and a manual reset is required because of the programmed setting in "#RF". Check the system for problems that would produce the single phase, overload or current unbalance fault like a jam.
Display is showing a solid "LPR"	The unit has tripped on low power and a manual reset is required because of the setting in "#RU." Check the system for problems that would produce a loss of load like a broken belt or a pump is out of liquid.
Display is showing a solid "CF"	The unit has tripped on a single phasing of the current, but was not single phased by the incoming voltage. Check for damaged contacts or loose wiring.
Display is showing a solid "GrF"	A ground fault current greater than the programmed "GF" value has been detected. A manual reset is required. Check the motor for insulation breakdown.
Unit displays currents when the motor starts but reads "0" KW or HP and trips on "LPR"after 4 seconds.	The unit is not wired properly to calculate correct power factor. See Figures 1, 2 & 3 (pages 2 & 3) for proper wiring and review step 4 in connection instructions (page 1).
Display alternates "HPR" with "RUN"	The overload has tripped on high power and is timing down RD3.
Display is showing solid "HPR"	The overload has tripped on high power and requires a manual reset.
Unable to change parameters	See Tamper Guard Page 11

MODEL 777-KW/HP SPECIFICATIONS

Electrical Input Voltage Ranges and Low and High Voltage Setpoints			
Input Voltage Ranges and Low and High Voltage Setpoints			
	Low Setpoint (LV)	Nominal Voltage Range	High Setpoint (HV)
		200-480 VAC	
777-KW/HP	170-HV Setting	200-480 VAC	LV Setting - 528
777-LR-KW/HP			
777-HVR	340-HV Setting	380-480 VAC	LV Setting - 528
	o to the obtaining		Et obtailig beb
777-HVR-LR			
777-575	450-HV Setting	480-600 VAC	LV Setting - 660
	-		-
777-575-LR			
Nominal Motor Full Load Current and Overcurrent Setpoint			
	Nom. Current Range	Overcurrent Setpoint (OC)	Ground Fault Setpoint (GF)
777, 777-HVR, 777-575	2-25A Looped	(20 to 100A)/MULT	OFF, (3 to 20A)/MULT
	25-90A Direct	20 to 100A	OFF, 3-20A
	80-800 A Ext CTs	80-120% of CT Prim	OFF, 10-30% of CT Prim
777-LR, 777-HVR-LR, 777-575-LR	1-25A Looped	1-5A	0.15-1A
	2-9A Direct	2-10A	0.3-2A
		-	
Frequency	50-60 Hz		
	100 kA		
Short Circuit			
Power Consumption	10W (Maximum)		
Output Contact Rating SPDT (Form C)			
All 777-XXX-XX KW/HP types except -HVR	Pilot duty rating: 480 VA	@ 240 VAC	
1	General purpose: 10A @ 2-	40 VAC	
1		-	
	Max Voltage: 277 VAC	0.000.000	
777-HVR-KW/HP	Pilot duty rating: 480 VA	@ 600 VAC	
777-HVR-LR-KW/HP	1		
Expected Life			
Mechanical	1 x 10 ⁶ operations		
	1 x 10 ⁵ operations at rate	d lood	
Electrical	T X TO Operations at rate	u loau	
Accuracy at 25° C (77° F)			
Voltage	±1%		
Current	±3%(<100 Amps Direct)		
GF Current	±15%		
Timing	5% ± 1 second		
Repeatability			
Voltage	± 0.5% of nominal voltage		
Current	± 1% (<100 amps direct)		
Ground Fault Trip Delay			
101%-200% of Setpoint	8 sec. +/- 1 sec		
201%-300% of Setpoint	4 sec. +/- 1 sec		
301%-400% of Setpoint	3 sec. +/- 1 sec		
401% or Greater	2 sec. +/- 1 sec		
Current Unbalance Trip Delay	(30 seconds) / (% over s	etpoint) see examples below	
% Over Setpoint Trip Time	% Over Setpoint	Trip Time	
	5%	6 sec	
1% 30 sec	604	5 sec	
2% 15 sec	6%		
	10%	3 sec	
2% 15 sec			
2% 15 sec 3% 10 sec			
2% 15 sec 3% 10 sec Safety Marks	10%		
2% 15 sec 3% 10 sec Safety Marks	10%		
2% 15 sec 3% 10 sec Safety Marks UL	10%		
2% 15 sec 3% 10 sec Safety Marks UL CSA CSA	10% UL508, UL1053 LR46510	3 sec	
2% 15 sec 3% 10 sec Safety Marks UL	10%	3 sec	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE	10% UL508, UL1053 LR46510	3 sec	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5-	3 sec 1	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k	3 sec 1 cv contact, 8kv air	
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD)	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5-	3 sec 1 cv contact, 8kv air	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-6, Level 3 10	3 sec 1 cv contact, 8kv air V/m	
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated	10% UL508,UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6i IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10	3 sec 1 cv contact, 8kv air V/m V/m	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-6, Level 3 10	3 sec 1 cv contact, 8kv air V/m V/m	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Fast Transient Burst	10% UL508,UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6i IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10	3 sec 1 cv contact, 8kv air V/m V/m	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 3.	3 sec 1 cv contact, 8kv air V/m 5. kv input power	
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-2, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 3 6 000-4-5, Level 3, 2kv line	3 sec 1 vv contact, 8kv air V/m V/m J/m .5 kv input power -to-line; Level 4, 4kv line-to-grour	.d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge Surge	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-2, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 3 6 000-4-5, Level 3, 2kv line	3 sec 1 vv contact, 8kv air V/m V/m J/m .5 kv input power -to-line; Level 4, 4kv line-to-grour	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE ANSI/IEEE	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6H IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring Wi	3 sec 1 vv contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ve Compliance to 6kv line-line	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test	10% ULS08, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 0k IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3, 10 IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V	3 sec 1 vv contact, 8kv air V/m 5. kv input power -to-line; Level 4, 4kv line-to-groum we Compliance to 6kv line-line +1000V for 1 minute)	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE ANSI/IEEE	10% ULS08, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 0k IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3, 10 IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V	3 sec 1 vv contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ve Compliance to 6kv line-line	d
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k IEC 61000-4-5, Level 3 10 IEC 61000-4-4, Level 3, 3. IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring W3 Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC Hi-potential Test Vibration Shock Shock	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k IEC 61000-4-6, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring W3 Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm	3 sec 1 vv contact, 8kv air V/m 5. kv input power -to-line; Level 4, 4kv line-to-groum we Compliance to 6kv line-line +1000V for 1 minute)	d
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k IEC 61000-4-5, Level 3 10 IEC 61000-4-4, Level 3, 3. IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring W3 Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	۰d
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Mechanical	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, GH IEC 61000-4-3, Level 3, 10 IEC 61000-4-3, Level 3, 10 IEC 61000-4-4, Level 3, 2kV line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, Imm EC 68-2-27, 30g, 3 axis, 11n	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions	10% ULS08, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6k IEC 61000-4-2, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 3. IEC 61000-4-4, Level 3, 3. IEC 61000-4-4, Level 3, 2.kv line C62.41 Surge and Ring W: Meets ULS08 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm IEC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Inmunity (RFI), Conducted Radio Frequency Inmunity (RFI), Radiated Fast Transient Burst Surge IEC Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 61 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11rr 3.0"H x 5.1 " D x 3.6"W 7 inch•lb	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Inmunity (RFI), Conducted Radio Frequency Inmunity (RFI), Radiated Fast Transient Burst Surge IEC Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 61 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11rr 3.0"H x 5.1 " D x 3.6"W 7 inch•lb	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque Enclosure Material	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6H IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm IEC 68-2-27, 30g, 3 axis, 11 m 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 61 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11rr 3.0"H x 5.1 " D x 3.6"W 7 inch•lb	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CS CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque Enclosure Material Weight	10% UL508, UL1053 UA508, UL1053 UK46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 04 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 lbs	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL USA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque Enclosure Material Weight Weight	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 6H IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm IEC 68-2-27, 30g, 3 axis, 11 m 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque Enclosure Material Weight Maximum Conductor Size Through 777-KW/HP Environmental Environmental	10% UL508, UL1053 UA508, UL1053 UK46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 04 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 lbs	3 sec 1 v contact, 8kv air V/m V/m 5. kv input power -to-line; Level 4, 4kv line-to-groun ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis	d
2% 15 sec 3% 10 sec Safety Marks UL US CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque Enclosure Material Weight Weight	10% UL508,UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 60 IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3 10 IEC 61000-4-5, Level 3, 2kv line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm IEC 68-2-27, 30g, 3 axis, 11n S.0"H x 5.1 " D x 3.6"W 7 inch-lb Polycarbonate 1.2 lbs 0.65" with insulation	3 sec 1 vy contact, 8kv air V/m V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) 1 peak-to-peak, 2 hours, 3 axis is duration, half-sine pulse	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC ANSI/IEEE Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque Enclosure Material Weight Maximum Conductor Size Through 777-KW/HP Environmental Environmental	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-2, Level 3, 64 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, Imm EC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 lbs 0.65" with insulation Ambient Operating: -20" -	3 sec 1 v contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis ns duration, half-sine pulse 70° C (-4° - 158°F)	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge JEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque Enclosure Material Weight Maximum Conductor Size Through 777-KW/HP Environmental Temperature Range	10% UL508,UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 60 IEC 61000-4-6, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3 10 IEC 61000-4-5, Level 3, 2kv line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm IEC 68-2-27, 30g, 3 axis, 11n S.0"H x 5.1 " D x 3.6"W 7 inch-lb Polycarbonate 1.2 lbs 0.65" with insulation	3 sec 1 v contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis ns duration, half-sine pulse 70° C (-4° - 158°F)	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge JEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque Enclosure Material Weight Maximum Conductor Size Through 777-KW/HP Environmental Temperature Range	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 64 IEC 61000-4-2, Level 3, 64 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3 10 IEC 61000-4-3, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, Imm EC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 lbs 0.65" with insulation Ambient Operating: -20" -	3 sec 1 v contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis ns duration, half-sine pulse 70° C (-4° - 158°F)	d
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge IEC Hi-potential Test Vibration Shock Mechanical Dimensions Terminal Torque Enclosure Material Weight Waimum Conductor Size Through 777-KW/HP Environmental Temperature Range Pollution Degree Pollution Degree	10% UL508, UL1053 LR46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 60 IEC 61000-4-6, Level 3, 10 IEC 61000-4-3, Level 3, 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-5, Level 3, 2kv line C62.41 Surge and Ring Wi Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1nm IEC 68-2-27, 30g, 3 axis, 11n 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 Ibs 0.5" with insulation Ambient Operating: -20" - Ambient Operating: -20" - Ambient Storage: -40" - 86 3	3 sec 1 v contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) peak-to-peak, 2 hours, 3 axis ns duration, half-sine pulse 70° C (-4° - 158°F)	id
2% 15 sec 3% 10 sec Safety Marks UL UL CSA CE Standards Passed Electrostatic Discharge (ESD) Electrostatic Discharge (ESD) Radio Frequency Immunity (RFI), Conducted Radio Frequency Immunity (RFI), Radiated Fast Transient Burst Surge JEC ANSI/IEEE Hi-potential Test Vibration Shock Dimensions Terminal Torque Enclosure Material Weight Maximum Conductor Size Through 777-KW/HP Environmental Temperature Range	10% ULS08, UL1053 UL46510 IEC 60947-1, IEC 60947-5- IEC 61000-4-2, Level 3, 04 IEC 61000-4-3, Level 3 10 IEC 61000-4-4, Level 3, 10 IEC 61000-4-4, Level 3, 3. 6 000-4-5, Level 3, 2kv line C62.41 Surge and Ring W: Meets UL508 (2 x rated V IEC 68-2-6, 10-55Hz, 1mm EC 68-2-27, 30g, 3 axis, 11r 3.0"H x 5.1 " D x 3.6"W 7 inch•lb Polycarbonate 1.2 lbs 0.65" with insulation Ambient Operating: -20" - Ambient Storage: -40" - 86	3 sec 1 1 vv contact, 8kv air V/m 5 kv input power -to-line; Level 4, 4kv line-to-grour ave Compliance to 6kv line-line +1000V for 1 minute) 1 peak-to-peak, 2 hours, 3 axis is duration, half-sine pulse 70° C (-4° - 158°F) 0° C (-40° - 176°F)	d

MODEL 777-KW/HP SPECIFICATIONS CONTINUED

Programmable Operating Points	Range
LV, HV, OC, GF	See electrical specifications above
UB- Voltage Unbalance Threshold	2 - 15% or 999%
MULT- # of Loops or CT Ratio (XXX:5)	1-10 Loops or 100-800 Ratio
LP- Low Power Setting	See Power Ranges Below or 0=off
CUB- Current Unbalance Threshold	2 - 25% or 999%
TC- Overcurrent Trip Class **	5, J5, 10, J10, 15, J15, 20, J20, 30, J30
RD1- Rapid Cycle Timer	0, 2 - 500 Seconds
RD2- Restart Delay After All Faults Except Underload (motor cool down timer)	2 - 500 Minutes
RD3- Restart Delay After Underload (dry well recovery timer)	2 - 500 Minutes
#RU- Number of Restarts After Underload	0, 1, 2, 3, 4, A(Automatic)
ADDR- RS485 Address	A01- A99
#RF-Number of Restarts After All Faults Except Underload***	0, 1, oc1, 2, oc2, 3, oc3, 4, oc4, A, ocA
Low Power (LP) / Power Range Setting (PWS)	1 = 0.01 - 0.99 KW 5 = 0.01 - 0.99 HP
	2 = 1.00 - 9.95 KW 6 = 1.00 - 9.95 HP
(PWS = LP Range)	3 = 10.0 - 99.5 KW 8 = 10.0 - 99.5 HP
· - ·	4 = 100 - 650 KW 9 = 100 - 650 HP

NOTES: SymCom's Power Monitor/Motor Protection Relay can be preprogrammed prior to installation by applying 120

- VAC between the L1 and L2 terminals (except 575 Volt model). Power applied must be 110 VAC or greater.
 - 575 Volt Model.
 - ** If J Prefix is displayed in trip class setting, jam protection is enabled.
 - *** If "oc" is displayed in the #RF setting, then overcurrent will be included as a normal fault and the relay will automatically restart after RD2 expires, otherwise, manual reset is required after an overcurrent fault.
 - **** Given current range within nominal specified range and power factor must be > 60%

Clearing Last Fault

The last fault stored can be cleared on the PumpSaver.

This procedure is outline as follows:

- 1. Rotate the Mode Select Switch to 'GF'.
- 2. Press and hold the Reset/Program Button. Adjust the Display/Program adjustment until cLr appears on the display. Release the Reset/Program Button.

To verify the last fault was cleared, place the Mode Select switch in the Run position. Then press and hold the Reset/Program Button, cLr should be on the display.

Tamper Guard

The PumpSaver can be protected from unauthorized program changes by locking in the setpoints.

- This procedure is outlines as follows:
- 1. Rotate the Mode Select switch to 'GF'.
- 2. Rotate Display/Program adjustment fully clockwise.
- 3. Press and hold the Reset Button. Adjust the Display/Program adjustment until 'Loc' appears in the display.
- 4. Release the Reset Button.
- 5. Turn Mode Select switch to 'run'.

The program is now locked, but all settings can be viewed. The unit can be unlocked by following the procedure above except step three. This step should say: Press and hold the Reset Button. Adjust the Display/Program adjustment until 'unL' appears in the display.


Network Tamper Guard

The PumpSaver can be protected from unauthorized program changes by locking each set point via the network. These set points can only be unlocked if the password is known. This feature is only available with SymCom Solutions software. For more information please call the factory.

The GF test must be performed before installing the PumpSaver as required by UL1053 and NEC, ANSI/NFPA 70.

Ground Fault Testing Procedure

- 1. Disconnect power
- 2. Hook up the three line voltages to L1, L2, and L3 as required by the installation instructions.
- 3. Program the desired parameters into the unit. For test purposes, set MULT to one and GF to the minimum allowed setting.
- 4. Construct the circuit below, using an AC power supply. This circuit simulates a ground fault condition by generating a current in one of the phases. Alternate test circuits may be used. The only requirement is the current through the current transformer must be between 115% and 150% of the GF setting and pass through only one CT window.



- 5. The values of V and R will be determined by the current required to generate a GF trip condition: I = Vrms/R, where I = 115% of GF setting.
- 6. Place the unit in the run position, apply three phase power and allow the N.O. contact to close.
- 7. Energize the test circuit by pushing and holding the test push-button until the unit trips (within 8.5 seconds). The display should show GrF and the N.O. contacts should be open. Release the N.O. push button.
- 8. The results of the test are to be recorded on the test form provided. The form should be kept by those in charge of the buildings electrical installation in order to be available to the authority having jurisdiction.
- 9. Confirm programmed parameters and proceed with installation instructions.

Ground Fault Test Results*

Date


Performed by

<u>Results</u>

Location

*A copy of this form should be retained by buildings electrical foreman.

SymCom warrants its microcontroller based products against defects in material or workmanship for a period of five (5) years from the date of manufacture. All other products manufactured by SymCom shall be warranted against defects in material and workmanship for a period of two (2) years from the date of manufacture. For complete information on warranty, liability, terms, returns, and cancellations, please refer to the SymCom Terms and Conditions of Sale document.



Technical Information

Proline Prowirl 72F, 72W, 73F, 73W

Vortex flow measuring system Reliable flow measurement of gas, steam and liquids



Application

For the universal measurement of the volume flow of gases, steam and liquids.

The mass flow of steam, water (as per IAPWS-IF97 ASME), natural gas (as per AGA NX-19/AGA8-DC92 detailed method/AGA8 Gross Method 1/SGERG-88), compressed air, other gases and liquids can also be measured with the aid of integrated temperature measurement and by reading in external pressure values (optional).

Maximum range of applications thanks to:

- Fluid temperature range from -200 to +400 °C (-328 to +752 °F)
- Pressure ratings up to PN 250/Class 1500
- Sensor with integrated (optional) diameter reduction by one line size (R Style) or two line sizes (S Style)
- Dualsens version (optional) for redundant measurements with two sensors and electronics

Approvals for:

- ATEX, FM, CSA, TIIS, NEPSI, IEC
- HART, PROFIBUS PA, FOUNDATION Fieldbus
- Pressure Equipment Directive, SIL 2

Your benefits

The robust **Prowirl sensor**, tried and tested in over 100 000 applications, offers:

- High resistance to vibrations, temperature shocks, contaminated fluids and water hammer
- No maintenance, no moving parts, no zero-point drift ("lifetime" calibration)
- Software initial settings save time and costs

Additional possibilities:

- Complete saturated steam or liquid-mass measuring point in one single device
- Calculation of the mass flow from the measured variables volume flow and temperature in the integrated flow computer
- External pressure value read-in for superheated steam and gas applications (optional)
- External temperature value read-in for delta heat measurement (optional)



USA

Endress+Hauser, Inc. 2350 Endress Place Greenwood, IN 46143 USA

Tel. 317-535-7138 Fax 317-535-8498 Sales 888-ENDRESS Service 800-642-8737 inquiry@us.endress.com www.us.endress.com

Canada

Endress+Hauser Canada 1075 Sutton Drive Burlington, ON L7L 5Z8 Canada

Tel. 905-681-9292 800-668-3199 Fax 905-681-9444 www.ca.endress.com Endress+Hauser, México, S.A. de C.V.F Fernando Montes de Oca 21 Edificio A Piso 3 Fracc. Industrial San Nicolas 54030. Tlalnepantla de Baz Estado de México México Tel. +52 55 5321 2080

Fax +52 55 5321 2099 eh.mexico@mx.endress.com www.mx.endress.com

México

Instruments International

Endress+Hauser Instruments International AG Kaegenstrasse 2 4153 Reinach Switzerland

Tel. +41 61 715 81 00 Fax +41 61 715 25 00 www.endress.com info@ii.endress.com




People for Process Automation







Temperature





Technical Information

Waterpilot FMX167

Hydrostatic level measurement Reliable and robust level probe with ceramic measuring cell Compact device for level measurement in fresh water, wastewater and saltwater



Application

The Waterpilot FMX167 is a pressure sensor for hydrostatic level measurement. Three versions of FMX167 are available at Endress+Hauser:

- FMX167 with a stainless steel housing, outer diameter of 22 mm (0.87 in): Standard version suitable for drinking water applications and for use in bore holes and wells with small diameters
- FMX167 with a stainless steel housing, outer diameter of 42 mm (1.66 in): Heavy duty version, easy clean flush-mounted process diaphragm. Ideally suited to wastewater and sewage treatment plants
- FMX167 with a coated housing, outer diameter of 29 mm (1.15 in): Corrosion resistant version generally for use in saltwater, particularly for ship ballast water tanks.

Your benefits

- High mechanical resistance to overload and aggressive media
- High-precision, robust ceramic measuring cell with long-term stability
- Climate proofed sensor thanks to completely potted electronics and 2-filter pressure compensation system
- 4 to 20 mA output signal with integrated overvoltage protection
- Simultaneous measurement of level and temperature with optionally integrated Pt100 temperature sensor
- Usage in drinking water: KTW, NSF
- Approvals: ATEX, FM and CSA
- Marine certificate: GL, ABS
- Extensive range of accessories provides complete measuring point solutions



Additional documentation

Field of activities	 Pressure measurement: FA004P/00/EN Recording technology: FA014R/09/EN System components: FA016K/09/EN
Technical Information	 Technical Information Waterpilot FMX21 with 4 to 20 mA with HART output signal: TI431P/00/EN Technical Information Deltapilot M: TI437P/00/EN Temperature Head Transmitter iTEMP PCP TMT181: TI070R/09/EN
Operating Instructions	 Waterpilot FMX167: BA231P/00/EN Cable shortening kit: SD552P/00/A6
Safety instructions	 ATEX II 2 G Ex ia IIC T6: XA131P/00/A3 ATEX II 3 G Ex nA II T6: XA132P/00/A3
Installation/Control Drawings	 FM IS Class I, Div. 1, Groups A – D: ZD063P/00/EN CSA IS Class I, Div. 1, Groups A – D: ZD064P/00/EN
Drinking water approval	■ SD126P/00/A3

Instruments International

Endress+HauserInstruments International AG Kaegenstrasse 2 4153 Reinach Switzerland

Tel. +41 61 715 81 00 Fax +41 61 715 25 00 www.endress.com info@ii.endress.com



