

**Table 1.1  
Sampling Rationale for December 2002**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Sampling Frequency:	
DOM-2		NS		NS	NS	NS	As needed, once annually	Yes   Sampled in December 2002
FO-8	NS	NS		NS	NS	NS	As needed, once annually	VOCs detected are greater than 90% of the MCL (>4.5 ppb for PCE and TCE). Bottled water will be supplied and steps taken to install a GAC system. The well will be sampled quarterly following GAC installation.
FO-17	NS	NS		NS	NS	NS	As needed, once annually	
FO-22		NS	NS	NS	NS	Yes	As needed, once annually	
FO-J1						Yes	Qtrly, 1 year thru Jun 03	
FO-J1, EP	NS	NS	NS		NS	NS	As needed, once annually	
HS-2	NS					Yes	Qtrly, 1 year thru Sept 03	
HS-3	NS		NS		NS	NS	As needed, once annually	
I10-2						Yes	Qtrly, 1 year thru Sept 03	
I10-4	NS					Yes	Qtrly, 1 year thru Sept 03	
I10-5	NS	NS	NS	NS	NS	Yes	As needed, once annually	
I10-7	NS	NS		NS	NS	NS	As needed, once annually	
JW-6		NS	NS		NS	NS	As needed, once annually	VOCs detected are greater than 80% of the MCL (>4.0 ppb for PCE and TCE). The well will be placed on a monthly sampling schedule.
JW-9						Yes	Qtrly, 1 year thru Dec 02	
JW-9-A2*	NS	NS	NS	NS	NS	Yes/FT	As needed, once annually	
JW-12		NS	NS	NS	NS	Yes	As needed, once annually	
JW-13		NS	NS	NS	NS	Yes	As needed, once annually	
JW-14						Yes	Qtrly, 1 year thru Sep 03	
JW-26	NS	NS		NS		Yes	Qtrly, 1 year through Mar 03	
LS-1						Yes	Qtrly, 1 year thru Sep 03	
LS-2						Yes	Qtrly, 1 year thru Sep 03	
LS-2/LS-3-A1	NS	NS	NS	NS	FT	NS	Bi-annually (Mar & Sept)	
LS-3						Yes	Qtrly, 1 year thru Sep 03	
LS-2/LS-3-A2	NS	NS		NS		NS	Bi-annually (Mar & Sept)	
LS-4						Yes	Qtrly, 1 year thru Sep 03	
LS-5						Yes	Qtrly, 1 year thru Sep 03	
LS-6						Yes	Qtrly, 1 year thru Sep 03	
LS-6-A2				NS		NS	Bi-annually (Mar & Sept)	
LS-7						Yes	Qtrly, 1 year thru Sep 03	
LS-7-A2				NS		NS	Bi-annually (Mar & Sept)	
OFR-1	NS					Yes	Qtrly, 1 year thru Sep 03	No VOCs detected. Sample on an as needed basis.
OFR-2	NS	NS				Yes	Qtrly, 1 year thru Sep 03	
OFR-3						Yes	Qtrly, 1 year thru Sep 03	
OFR-3-A2	NS	NS		NS		NS	Bi-annually (Mar & Sept)	
RFR-3	NS	NS	NS	NS	NS	Yes	As needed, once annually	
RFR-6		NS	NS	NS	NS	Yes	As needed, once annually	
RFR-7		NS	NS		NS	NS	As needed, once annually	
RFR-8		NS	NS		NS	NS	As needed, once annually	
RFR-9			NS		NS	NS	As needed, once annually	
RFR-10						Yes	Qtrly, 1 year thru Sep 03	
RFR-10-A2				NS		NS	Bi-annually (Mar & Sept)	This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months. A1 - after GAC canister # 1 A2 - after GAC canister #2
RFR-11						Yes	Qtrly, 1 year thru Sep 03	
RFR-11-A2				NS		NS	Bi-annually (Mar & Sept)	
RFR-12						Yes	Qtrly, 1 year thru Sep 03	
Total samples to collect Dec 2002:							27	FT   First event for sampling by CSSA.
Total wellhead samples:							26	
Total post filtration system samples:							1	
Total number of samples:							27	

\*JW-9-A2 was sampled after treatment by the filtration system installed by the well owner  
This system is not a CSSA-installed GAC.