

**Table 1.1
Sampling Rationale for June 2003**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Jun-03	Sampling Frequency:
DOM-2	NS	As needed, once annually							
FO-8	NS	As needed, once annually							
FO-17	NS	As needed, once annually							
FO-22	NS	As needed, once annually							
FO-J1	NS	Yes	Qtrly, 1 year thru Mar 04						
FO-J1, EP	NS	suggest removing from list							
HS-2	NS	Yes	Qtrly, 1 year thru Mar 04						
HS-3	NS	Yes	As needed, once annually						
I10-2	NS	Yes	Qtrly, 1 year thru Mar 04						
I10-4	NS	Yes	Qtrly, 1 year thru Sept 03						
I10-5	NS	As needed, once annually							
I10-7	NS	Yes	As needed, once annually						
I10-7-NP	NS	As needed							
JW-6	NS	Yes	As needed, once annually						
JW-8	NS	FT	First Sample						
JW-9	NS	Yes	Qtrly						
JW-9-A2*	NS	As needed							
JW-12	NS	As needed, once annually							
JW-13	NS	Yes	As needed, once annually						
JW-14	NS	Yes	Qtrly, 1 year thru Mar 04						
JW-14-NP	NS	As needed							
JW-26	NS	Yes	Qtrly, 1 year thru Mar 04						
JW-27	NS	FT	First Sample						
JW-29	NS	FT	First Sample						
JW-30	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-1	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-2	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-2/LS-3-A1	NS	Bi-annually (Mar & Sept)							
LS-3	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-2/LS-3-A2	NS	Bi-annually (Mar & Sept)							
LS-4	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-5	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-6	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-6-A2	NS	Bi-annually (Mar & Sept)							
LS-7	NS	Yes	Qtrly, 1 year thru Mar 04						
LS-7-A2	NS	Bi-annually (Mar & Sept)							
LS-7-NP	NS	As needed							
OFR-1	NS	Yes	Qtrly, 1 year thru Mar 04						
OFR-2	NS	Yes	Qtrly, 1 year thru Mar 04						
OFR-3	NS	Yes	Qtrly, 1 year thru Mar 04						
OFR-3-A2	NS	Bi-annually (Mar & Sept)							
OFR-4	NS	FT	First Sample						
RFR-3	NS	As needed, once annually							
RFR-6	NS	As needed, once annually							
RFR-7	NS	As needed, once annually							
RFR-8	NS	Yes	As needed, once annually						
RFR-9	NS	Yes	As needed, once annually						
RFR-10	NS	Yes	Qtrly, 1 year thru Mar 04						
RFR-10-A2	NS	Bi-annually (Mar & Sept)							
RFR-11	NS	Yes	Qtrly, 1 year thru Mar 04						
RFR-11-A2	NS	Bi-annually (Mar & Sept)							
RFR-12	NS	Yes	Qtrly, 1 year thru Mar 04						
Total samples to collect June 2003:									27
Total Pre GAC									27
Total Post GAC									0
First Time Samples									4
Total number of samples:									31

Yes To be sampled in June 2003

VOCs detected are greater than 90% of the MCL (>4.5 ppb for PCE and TCE). Bottled water will be supplied and steps taken to install a GAC system. The well will be sampled quarterly following GAC installation.

VOCs detected are greater than 80% of the MCL (>4.0 ppb for PCE and TCE). The well will be placed on a monthly sampling schedule.

VOCs detected are less than 80% of the MCL (<4.0 ppb and >0.11 ppb for PCE & <4.0 ppb >0.14 ppb for TCE). Four quarters of concentrations below the MDL detections will be necessary to remove the well from quarterly sampling.

No VOCs detected. Sample on an as needed basis.

NS Not sampled for that event.

This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months.
A1 - after GAC canister #1
A2 - after GAC canister #2

FT First event for sampling by CSSA.

*JW-9-A2 is sampled after treatment by the filtration system installed by the well owner. This system is not a CSSA-installed GAC.