

**Table I.1  
Sampling Rationale for March 2003**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Sampling Frequency:	
DOM-2	Yes	NS	Yes	NS	NS	NS	Yes	As needed, once annually	Yes To be sampled in March 2003
FO-8	NS	NS	Yes	NS	NS	NS	Yes	As needed, once annually	VOCs detected are greater than 90% of the MCL (>4.5 ppb for PCE and TCE). Bottled water will be supplied and steps taken to install a GAC system. The well will be sampled quarterly following GAC installation.
FO-17	NS	NS	Yes	NS	NS	NS	Yes	As needed, once annually	
FO-22	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
FO-J1	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Jun 03	
FO-J1, EP	NS	NS	NS	Yes	NS	NS	NS	As needed, once annually	
HS-2	NS	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Sept 03	
HS-3	NS	Yes	NS	NS	NS	NS	NS	As needed, once annually	
I10-2	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
I10-4	NS	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Sept 03	
I10-5	NS	NS	NS	NS	NS	NS	NS	As needed, once annually	
I10-7	NS	NS	NS	NS	NS	NS	NS	As needed, once annually	
I10-7-NP	NS	NS	NS	NS	NS	NS	FT		
JW-6	Yes	NS	NS	Yes	NS	NS	NS	As needed, once annually	VOCs detected are greater than 80% of the MCL (>4.0 ppb for PCE and TCE). The well will be placed on a monthly sampling schedule.
JW-9	Yes	Yes	Yes	Yes	Yes	Yes	Yes	As needed, once annually	
JW-9-A2	NS	NS	NS	NS	NS	NS	NS	As needed, once annually	
JW-12	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
JW-13	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
JW-14	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
JW-14-NP	NS	NS	NS	NS	NS	NS	FT		
JW-26	NS	NS	Yes	NS	NS	NS	Yes	Qtrly, 1 year through Jun 03	
JW-30	NS	NS	NS	NS	NS	NS	FT		
LS-1	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-2	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-2 POST	NS	NS	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
LS-3	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-3 POST	NS	NS	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
LS-4	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-5	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-6	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-6 POST	Yes	Yes	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
LS-7	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
LS-7 POST	Yes	Yes	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
LS-7-NP	NS	NS	NS	NS	NS	NS	FT		
OFR-1	NS	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	No VOCs detected. Sample on an as needed basis.
OFR-2	NS	NS	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
OFR-3	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
OFR-3 POST	NS	NS	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
RFR-3	NS	NS	NS	NS	NS	NS	NS	As needed, once annually	
RFR-6	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
RFR-7	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
RFR-8	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
RFR-9	Yes	NS	NS	NS	NS	NS	NS	As needed, once annually	
RFR-10	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
RFR-10 POST	Yes	Yes	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	This well has a GAC filtration unit installed. A Post GAC sample must be collected in the quarter following GAC maintenance, or every six months.
RFR-11	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	
RFR-11 POST	Yes	Yes	Yes	NS	NS	NS	Yes	Bi-annually (Mar & Sept)	
RFR-12	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Qtrly, 1 year thru Dec 03	FT First event for sampling by CSSA.
Total samples to collect March 2003:								35	
Total Pre GAC								25	
Total Post GAC								7	
Total Non-Purged								3	