

**APPENDIX C**  
**PRE- AND POST-GAC SAMPLE COMPARISONS FOR**  
**WELLS LS-6, LS-7, RFR-10, RFR-11, LS-2/LS-3 AND OFR-3**

**Pre- and Post-GAC Sample Comparisons for  
Wells LS-6, LS-7, RFR-10, RFR-11, LS-2/LS-3 and OFR-3**

LS-2/LS-3					LS-6				
	PCE (µg/L)		TCE (µg/L)			PCE (µg/L)		TCE (µg/L)	
Date	Pre	Post	Pre	Post	Date	Pre	Post	Pre	Post
03/18/02	2.9/1.3	NA	0.29/0.63	NA	08/15/01	GAC UNIT INSTALLED			
04/2002	GAC UNIT INSTALLED				08/30/01	5.7	ND	0.57	ND
04/11/02	0.82/1.53	ND	ND/ND	ND	09/19/01	6.7	ND	0.35	ND
06/12/02	2.22/1.06	NA	0.31/0.20	NA	09/27/01	20.0	NA	0.38	NA
09/17/02	2.62/2.9	ND	0.17/0.21	ND	12/18/01	1.97	ND	ND	ND
03/12/03	4.25/3.99	ND	0.30/0.35	ND	03/18/02	2.7	ND	0.2	ND
9/9/03	2.21/1.37	ND	0.39/0.14	ND	09/16/02	1.58	ND	0.1	ND
3/3/04	0.98/1.09	ND	0.11/0.17	ND	03/12/03	4.19	ND	0.21	ND
9/21/04	1.41/1.81	0.59F/ND	0.26F/0.24F	0.22F/ND	9/11/03	2.49	ND	0.38	ND
3/23/05	2.25/1.74	0.74/ND	0.40F/0.19F	0.33F/ND	3/1/04	3.61	ND	0.47	ND
					9/20/04	2.08	ND	ND	ND
					3/21/05	4.22	ND	0.41F	ND

LS-7					OFR-3				
	PCE (µg/L)		TCE (µg/L)			PCE (µg/L)		TCE (µg/L)	
Date	Pre	Post	Pre	Post	Date	Pre	Post	Pre	Post
08/07/01	GAC UNIT INSTALLED				03/19/02	12.15	NA	5.65	NA
08/08/01	NA	ND	NA	ND	04/16/02	9.38	NA	3.77	NA
08/30/01	1.1	NA	ND	NA	4/30/02	GAC UNIT INSTALLED			
09/19/01	4.5	ND	0.81	ND	04/30/02	NA	ND	NA	ND
09/27/01	6.6	NA	0.68	NA	06/11/02	10.22	NA	6.24	NA
12/18/01	1.4	ND	ND	ND	09/16/02	2.96	ND	2.59	ND
03/18/02	2.7	ND	0.24	ND	03/12/03	2.81	ND	3.25	ND
09/16/02	2.41	ND	0.34	ND	9/11/03	10.82	ND	6.42	ND
03/12/03	4.01	ND	0.41	ND	3/1/04	2.87	ND	1.98	ND
9/11/03	3.47	ND	0.34	ND	9/20/04	1.61	ND	1.67	ND
3/1/04	3.1	ND	0.33	ND	3/21/05	1.35F	ND	2.08	ND
9/20/04	2.77	ND	ND	ND					
3/21/05	2.32	ND	0.31F	ND					

NA – not applicable (post-GAC not sampled during this event)

ND – indicates analyte was not detected at or above the MDL.

**Pre- and Post-GAC Sample Comparisons, cont'd:**

RFR-10					RFR-11				
	PCE (µg/L)		TCE (µg/L)			PCE (µg/L)		TCE (µg/L)	
Date	Pre	Post	Pre	Post	Date	Pre	Post	Pre	Post
10/09/01	GAC UNIT INSTALLED				10/04/01	16.0	NA	0.35	NA
10/12/01	20.89	ND	8.21	ND	10/12/01	16.73	NA	0.58	NA
12/17/01	9.02	ND	5.85	ND	10/16/01	GAC UNIT INSTALLED			
03/18/02	4.5	ND	2.2	ND	10/25/01	NA	ND	NA	ND
09/16/02	9.19	ND	4.84	ND	12/17/01	12.44	ND	ND	ND
03/12/03	13.88	ND	8.37	ND	03/19/02	5.71	ND	1.05	ND
9/11/03	24.56	ND	10.07	ND	09/16/02	8.44	ND	0.67	ND
3/1/04	23.23	ND	10.25	ND	03/12/03	10.02	0.07F	0.12	ND
9/20/04	18.76	ND	7.99	ND	9/11/03	0.99	ND	1.63	ND
3/21/05	8.03	ND	5.19	ND	3/4/04	0.99	ND	1.25	ND
					9/20/04	1.93	ND	1.05	ND
					3/21/05	4.84	ND	0.32F	ND

NA – not applicable (post-GAC not sampled during this event)

ND – indicates analyte was not detected at or above the MDL.