

**Table 1.1
Sampling Rationale for March 2005**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Jun-03	Sep-03	Dec-03	Mar-04	Jun-04	Sep-04	Dec-04	Mar-05	Sampling Frequency:	
DOM-2	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	As needed, once annually
FO-8	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	As needed, once annually
FO-17	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
FO-22	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
FO-J1	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
HS-1	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Sample if well is online.
HS-2	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
HS-3	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
I10-2	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
I10-4	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
I10-5	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
I10-7	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, furthest clean well south-west
JW-6	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
JW-7	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
JW-8	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
JW-9	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Mar 05
JW-9-A2*	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed
JW-12	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	As needed, once annually
JW-13	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
JW-14	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
JW-26	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
JW-27	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	As needed, once annually
JW-28	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
JW-29	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, due to location
JW-30	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
LS-1	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Well is offline
LS-2	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
LS-2/LS-3-A1	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Bi-annually (Mar & Sept)
LS-3	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Qtrly, 1 year thru Dec 05
LS-2/LS-3-A2	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS	Yes	Bi-annually (Mar & Sept)

VOCs detected are greater than 90% of the MCL. Monthly sampling, followed by quarterly sampling after GAC installation.	VOCs detected are greater than 80% of the MCL. The well will be placed on a monthly sampling schedule.	Yes	To be sampled in March 2005
VOCs detected are less than 80% of the MCL (<4.0 ppb and >0.11 ppb for PCE & <4.0 ppb >0.14 ppb for TCE). Four quarters of concentrations below the MDL detections will be necessary to remove the well from quarterly sampling.	This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months. A1 - after GAC canister #1 A2 - after GAC canister #2 *JW-9-A2 is the well owner's filtration system, not a CSSA-installed GAC.	FT	First event for sampling by CSSA.
		NS	Not sampled for that event.
		No VOCs detected. Sample on an as needed basis.	

**Table 1.1
Sampling Rationale for March 2005**

Well ID	Sep-01	Dec-01	Mar-02	Jun-02	Sep-02	Dec-02	Mar-03	Jun-03	Sep-03	Dec-03	Mar-04	Jun-04	Sep-04	Dec-04	Mar-05	Sampling Frequency:
LS-4															Yes	Qtrly, 1 year thru Dec 05
LS-5															Yes	Qtrly, 1 year thru Dec 05
LS-6															Yes	Qtrly, 1 year thru Dec 05
LS-6-A2				NS		NS		NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
LS-7															Yes	Qtrly, 1 year thru Dec 05
LS-7-A2				NS		NS		NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
OFR-1	NS														Yes	Qtrly, 1 year thru Dec 05
OFR-2	NS	NS													Yes	Qtrly, 1 year thru Sept 05
OFR-3															Yes	Qtrly, 1 year thru Dec 05
OFR-3-A2	NS	NS		NS		NS		NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
OFR-4	NS	NS	NS	NS	NS	NS	NS			NS		NS	NS	NS	Yes	As needed, once annually
RFR-3	NS	NS	NS	NS	NS	NS	NS	NS	NS						NS	As needed, once annually
RFR-4	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
RFR-5	NS	NS	NS	NS	NS	NS	NS	NS	NS	NS		NS	NS	NS	Yes	As needed, once annually
RFR-6		NS	NS	NS	NS		NS	NS	NS		NS	NS	NS		NS	As needed, once annually
RFR-7		NS	NS		NS	NS	NS	NS	NS		NS	NS	NS		NS	As needed, once annually
RFR-8		NS	NS		NS	NS	NS		NS	NS		NS	NS		NS	As needed, once annually
RFR-9			NS		NS	NS	NS			NS	NS	NS		NS	NS	As needed, once annually
RFR-10															Yes	Qtrly, 1 year thru Dec 05
RFR-10-A2				NS		NS		NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
RFR-10-B2				NS	NS	NS	NS	NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
RFR-11															Yes	Qtrly, 1 year thru Dec 05
RFR-11-A2				NS		NS		NS		NS		NS		NS	Yes	Bi-annually (Mar & Sept)
RFR-12															Yes	Qtrly, 1 year thru Dec 05
RFR-13												Well Installed			Yes	Qtrly, 1 year thru Dec 05

Total samples to collect March 2005:	40
Total Pre GAC	31
Total Post GAC	8
First Time Samples	1
Total number of samples:	40

	VOCs detected are greater than 90% of the MCL. Monthly sampling, followed by quarterly sampling after GAC installation.		VOCs detected are greater than 80% of the MCL. The well will be placed on a monthly sampling schedule.	Yes	To be sampled in March 2005
	VOCs detected are less than 80% of the MCL (<4.0 ppb and >0.11 ppb for PCE & <4.0 ppb >0.14 ppb for TCE). Four quarters of concentrations below the MDL detections will be necessary to remove the well from quarterly sampling.		This well has a GAC filtration unit installed by CSSA. Post GAC samples are collected every six months. A1 - after GAC canister #1 A2 - after GAC canister #2 *JW-9-A2 is the well owner's filtration system, not a CSSA-installed GAC.	FT	First event for sampling by CSSA.
				NS	Not sampled for that event.
					No VOCs detected. Sample on an as needed basis.