

Table 2. Groundwater Analytical Results, April and June 1995

Well Number	Sample Date	Bromodichloro-		Dichloro-		Dibromo-		Dichloro-		trans-1,2-		cis-1,2-	
		methane (ug/L)	Chloroform (ug/L)	methane (ug/L)	ene chloride (ug/L)	ene chloride (ug/L)	ene chloride (ug/L)	ethene (ug/L)	ethene (ug/L)	ethene (ug/L)	ethene (ug/L)	ethene (ug/L)	ethene (ug/L)
1	3/30/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/13/95	<3	7	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
2	4/6/95	<0.6	<0.6	<0.8	<0.6	1	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/13/95	<3	<3	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
3	4/6/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/13/95	<3(<3)	<3(<3)	<4(<4)	<3(<3)	<5(<5)	<2(<2)	<4(<4)	<4(<4)	<4(<4)	<4(<4)	<5(<5)	<5(<5)
4	4/6/95	<0.6	<0.6	<0.8	<0.6	2.1	0.9	<0.8	0.9	<0.8	<0.8	<1.0	<1.0
	6/13/95	<3	<3	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
9	3/30/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/12/95	<3	<3	<4	<3	<5	<3	<4	<4	<4	<4	<5	<5
10	3/30/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/12/95	<3	<3	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
11	3/30/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
	6/12/95	<3	<3	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
16	4/6/95	<0.6	<0.6	<0.8	<0.6	170	170	<0.8	170	<0.8	270	<1.0	<1.0
	4/7/95	<0.6(<0.6)	<0.6(<0.6)	<0.8(<0.8)	<0.6(<0.6)	170(160)	170(170)	<0.8(<0.8)	170(170)	<0.8(<0.8)	280(290)	<1.0(<1.0)	<1.0(<1.0)
Upper Glen Rose	6/14/95	<3	<3	<4	<3	39	45	<4	45	<4	38	<5	<5
	4/6/95	<0.6	<0.6	<0.8	<0.6	110	130	<0.8	130	<0.8	240	<1.0	<1.0
D	6/14/95	<3	<3	<4	<3	64	99	<4	99	<4	120	<5	<5
	4/7/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
G	6/14/95	<3	<3	<4	<3	<5	<2	<4	<4	<4	<4	<5	<5
	4/7/95	<0.6	<0.6	<0.8	<0.6	<1.0	<0.4	<0.8	<0.4	<0.8	<0.8	<1.0	<1.0
I	6/14/95	<3(<3)	<3(<3)	<4(<4)	<3(<3)	<5(<5)	<2(<2)	<4(<4)	<2(<2)	<4(<4)	<4(<4)	<5(<5)	<5(<5)

Notes: Analytes detected above laboratory detection limits are shown in bold font. All well water samples were collected through well pump or via bailer. Duplicate sample results are shown in parentheses next to well sample results.

< = minimum detection limit

ug/L = micrograms per liter

* Chlorination byproducts in water supply well (referenced in SDWA drinking water regulations as THMs, or trihalomethanes). MCL for total concentration of THMs is 100 ug/L.